

SCHWERIN, Germany

WMO: 101620

Lat: 53.6425N

Lon: 11.3872E

Elev: 60

StdP: 100.61

Time Zone: 1.00 (EUC)

Period: 82-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-12.3	-9.3	-15.7	1.0	-10.8	-13.4	1.2	-8.1	14.7	5.8	12.5	6.5	1.7	90	0.599

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.7	27.8	18.6	26.0	17.9	24.1	17.1	19.8	25.5	18.8	24.1	17.9	22.7	3.5	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.8	12.9	21.9	16.7	12.0	20.8	15.8	11.3	20.2	56.8	25.6	53.4	24.0	50.5	22.7	23.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.5	10.0	8.7	-12.1	31.4	5.5	2.3	-16.1	33.0	-19.3	34.4	-22.4	35.7	-26.3	37.4		
(5)			-12.6	22.3	5.4	0.7	-16.4	22.8	-19.6	23.2	-22.6	23.6	-26.5	24.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.8	0.5	0.4	4.0	7.5	12.5	15.3	17.5	17.2	13.6	9.6	4.6	2.1	(6)
(7)		DBStd	7.16	5.42	4.61	3.66	3.48	3.62	3.42	3.16	2.98	2.60	3.35	3.33	3.70	(7)
(8)		HDD10.0	1318	296	269	187	92	16	1	0	0	2	47	164	246	(8)
(9)		HDD18.3	3560	554	503	444	326	185	105	54	59	144	269	413	504	(9)
(10)		CDD10.0	873	0	1	2	16	92	159	233	223	110	36	1	0	(10)
(11)		CDD18.3	72	0	0	0	0	3	13	29	24	2	0	0	0	(11)
(12)		CDH23.3	553	0	0	0	1	36	104	233	167	13	0	0	0	(12)
(13)		CDH26.7	109	0	0	0	0	2	23	47	36	1	0	0	0	(13)
(14)	Wind	WSAvg	3.9	4.8	4.2	4.2	3.7	3.4	3.5	3.6	3.4	3.8	3.9	4.3	4.5	(14)
(15)	Precipitation	PrecAvg	656	56	47	43	37	50	65	71	71	54	50	53	60	(15)
(16)		PrecMax	910	117	124	115	74	97	128	156	160	149	117	111	141	(16)
(17)		PrecMin	474	1	7	7	1	10	9	20	14	14	27	5	16	(17)
(18)		PrecStd	116	29	23	24	18	21	32	37	36	32	21	26	30	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.7	13.1	16.4	21.2	26.4	29.8	30.4	29.6	25.1	20.7	12.7	11.4	(19)
(20)			MCWB	8.9	10.2	10.9	13.6	16.6	18.4	19.8	19.7	18.2	16.4	10.3	9.3	(20)
(21)		2%	DB	8.9	10.2	12.8	18.3	24.2	26.3	27.8	27.4	22.2	18.0	11.3	10.0	(21)
(22)			MCWB	7.5	8.0	9.0	11.7	15.6	17.5	18.7	18.8	16.5	14.4	9.7	8.5	(22)
(23)		5%	DB	7.8	7.7	10.5	15.8	21.7	23.8	26.1	25.1	19.9	16.0	10.2	8.8	(23)
(24)			MCWB	6.4	5.9	7.6	10.4	14.4	16.5	18.1	18.1	15.1	13.0	8.9	7.5	(24)
(25)		10%	DB	6.7	6.0	9.0	13.4	19.3	21.8	23.9	22.9	18.0	14.4	9.1	7.5	(25)
(26)			MCWB	5.3	4.5	6.8	9.1	13.4	15.5	17.3	17.2	14.4	11.9	7.9	6.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.1	10.6	11.3	14.2	17.7	20.7	21.4	21.1	19.1	16.8	11.2	9.8	(27)
(28)			MCDWB	10.0	12.8	15.4	19.8	24.9	25.6	27.3	27.6	23.4	19.7	12.3	10.8	(28)
(29)		2%	WB	7.7	8.0	9.5	12.3	16.2	18.7	20.0	19.5	17.4	15.0	9.9	8.8	(29)
(30)			MCDWB	8.7	10.0	12.2	17.1	22.2	24.2	25.8	25.3	20.9	17.5	11.0	9.9	(30)
(31)		5%	WB	6.7	6.1	8.1	10.8	15.1	17.5	18.8	18.6	16.1	13.4	9.0	7.6	(31)
(32)			MCDWB	7.7	7.5	10.1	15.1	21.1	22.3	24.4	23.7	19.2	15.3	10.1	8.7	(32)
(33)		10%	WB	5.4	4.6	6.8	9.5	13.8	16.1	17.7	17.7	14.8	12.2	8.0	6.3	(33)
(34)			MCDWB	6.6	5.8	8.7	13.0	18.2	20.9	22.9	21.9	17.2	14.0	9.0	7.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.4	5.1	6.1	7.8	8.9	8.3	8.7	8.4	7.2	6.2	4.3	3.9	(35)
(36)			MCDBR	4.7	6.4	8.7	11.6	12.7	11.8	12.3	11.6	10.2	8.2	5.5	4.7	(36)
(37)			MCWBR	4.5	5.1	6.0	6.6	6.4	5.5	5.8	5.4	5.7	5.3	4.7	4.5	(37)
(38)		5% WB	MCDBR	4.6	6.4	8.0	10.4	11.5	10.5	11.0	10.2	9.1	7.5	5.1	4.6	(38)
(39)			MCWBR	4.6	5.3	6.0	6.5	6.2	5.6	6.0	5.2	6.0	5.4	4.7	4.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.317	0.338	0.372	0.408	0.402	0.400	0.419	0.414	0.382	0.358	0.335	0.308	(40)	
(41)		taud	2.322	2.320	2.258	2.212	2.278	2.306	2.271	2.298	2.368	2.405	2.374	2.316	(41)	
(42)		Ebn at Noon	643	751	800	818	846	850	824	805	785	721	617	574	(42)	
(43)		Edh at Noon	59	81	106	126	124	122	124	115	95	74	57	50	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.56	1.23	2.43	4.03	5.07	5.35	5.02	4.15	3.04	1.66	0.70	0.42	(44)	
(45)		RadStd	0.07	0.17	0.24	0.55	0.63	0.40	0.70	0.32	0.34	0.21	0.07	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (54 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-146	N/A	N/A

Nomenclature: See separate page