

TETEROW, Germany

WMO: 101770

Lat: 53.767N

Lon: 12.617E

Elev: 164

StdP: 14.61

Time Zone: 1.00 (EUC)

Period: 82-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	10.2	15.6	5.4	7.3	11.8	10.5	9.5	16.4	36.0	43.5	31.8	44.1	4.4	90	0.666

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.3	83.6	66.6	80.0	64.8	76.5	63.7	68.5	79.6	66.4	76.8	64.6	73.9	10.3	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.6	91.9	72.1	62.6	85.5	69.4	61.0	80.5	68.0	32.8	79.3	31.1	76.8	29.7	73.8	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.2	25.5	22.8	DB	8.3	91.1	10.8	6.0	0.5	95.4	-5.8	98.9	-11.9	102.3	-19.7	106.6	(4)
(5)			WB	7.4	73.1	11.8	1.1	-1.1	73.9	-8.0	74.6	-14.7	75.2	-23.3	76.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.6	33.5	32.1	38.5	45.1	54.5	59.5	63.6	63.4	56.2	49.0	39.5	35.2
	DBStd	13.03	9.32	8.32	6.99	6.28	6.13	5.87	5.50	5.45	4.57	6.27	6.34	6.74
	HDD50	2438	510	502	358	172	24	1	0	0	3	92	316	460
	HDD65	6474	975	921	821	597	331	186	93	97	267	495	766	925
	CDD50	1570	0	1	2	26	162	287	422	417	190	62	1	0
	CDD65	128	0	0	0	0	4	21	51	49	3	0	0	0
	CDH74	1315	0	0	0	0	77	245	542	424	26	1	0	0
	CDH80	328	0	0	0	0	5	67	137	116	3	0	0	0
Wind	WSAvg	10.9	13.8	11.8	12.0	10.4	9.2	8.6	9.0	9.1	10.6	11.3	12.0	12.5
Precipitation	PrecAvg	24.1	1.9	1.5	1.6	1.3	2.1	2.5	2.7	2.5	2.1	1.8	1.9	2.1
	PrecMax	30.8	3.8	3.5	4.0	2.6	4.0	4.9	12.3	6.1	6.1	3.0	4.4	4.5
	PrecMin	16.6	0.0	0.3	0.3	0.2	0.5	0.1	0.2	0.9	0.5	0.9	0.3	0.6
	PrecStd	3.5	1.0	0.7	0.8	0.6	0.9	1.1	2.1	1.1	1.2	0.6	0.9	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.5	55.8	60.7	70.3	80.6	87.3	88.3	88.6	77.6	69.9	55.1	51.9
		MCWB	49.1	51.2	51.4	57.0	62.7	65.9	69.2	67.6	64.6	62.4	52.0	48.8
	2%	DB	48.0	50.2	54.6	64.5	75.7	80.6	83.5	83.0	72.1	64.6	51.9	49.9
		MCWB	45.7	46.7	48.5	53.6	61.5	63.7	67.1	66.0	61.6	58.6	49.4	47.8
	5%	DB	46.1	45.5	50.8	60.1	71.6	76.2	80.1	78.8	67.7	60.9	49.8	47.5
		MCWB	44.0	42.5	45.9	51.2	59.2	62.9	65.3	64.3	59.5	55.8	47.7	45.5
	10%	DB	44.2	42.6	47.8	56.1	67.2	72.3	76.1	74.4	64.4	57.8	47.7	44.9
		MCWB	42.1	40.1	44.2	49.0	56.8	60.8	63.7	63.1	57.9	53.6	45.7	43.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.1	51.8	52.7	58.2	65.5	69.5	71.4	71.1	66.2	62.9	52.5	49.9
		MCDB	51.0	55.3	58.9	67.8	75.5	80.7	82.1	83.7	75.0	67.8	54.1	51.1
	2%	WB	46.2	46.6	49.5	54.6	62.7	66.3	68.8	68.1	63.4	59.3	49.9	48.0
		MCDB	47.5	49.3	53.9	62.6	73.2	77.0	81.4	77.7	69.6	63.5	51.7	49.5
	5%	WB	44.4	43.1	46.7	52.0	60.1	63.9	66.3	66.0	60.9	56.6	47.9	45.7
		MCDB	46.0	45.2	50.0	59.1	69.8	73.9	77.5	75.8	65.3	59.8	49.6	47.3
	10%	WB	42.3	40.3	44.4	49.6	57.7	61.8	64.4	64.1	58.7	54.1	46.0	43.4
		MCDB	44.0	42.4	47.5	55.5	65.3	70.6	73.3	73.1	63.1	57.0	47.5	45.0
Mean Daily Temperature Range	5% DB	MDBR	7.6	9.2	11.3	15.2	18.3	17.2	18.3	17.4	13.8	12.1	8.1	7.1
		MCDBR	8.2	11.4	15.9	21.7	26.4	25.7	26.3	24.7	19.8	16.5	9.9	8.8
		MCWBR	7.8	9.6	11.2	12.9	14.5	12.3	12.1	11.3	11.2	10.9	8.9	8.4
	5% WB	MCDBR	8.1	11.4	15.0	20.4	23.6	22.5	24.0	21.7	16.4	14.4	9.6	8.5
MCWBR		8.1	10.1	11.1	12.8	14.3	11.8	12.2	10.7	11.1	10.3	8.8	8.3	
Clear-Sky Solar Irradiance	taub	0.314	0.337	0.371	0.396	0.392	0.390	0.409	0.405	0.373	0.359	0.336	0.307	
	taud	2.316	2.312	2.255	2.258	2.305	2.330	2.298	2.320	2.393	2.392	2.368	2.310	
	Ebn at Noon	204	238	254	264	271	272	264	258	252	227	194	181	
	Edh at Noon	19	26	34	38	38	38	38	36	29	24	18	16	
All-Sky Solar Radiation	RadAvg	180	386	770	1299	1633	1728	1607	1341	975	519	221	125	
	RadStd	21	57	82	174	190	133	213	105	100	70	25	11	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (46 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-274	N/A	N/A

Nomenclature: See separate page