

AHLHORN, Germany

WMO: 102180

Lat: 52.883N

Lon: 8.233E

Elev: 184

StdP: 14.60

Time Zone: 1.00 (EUC)

Period: 86-95

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	12.4	17.4	8.8	8.7	13.9	13.1	10.8	19.5	32.6	47.0	29.7	45.0	6.6	70	0.596

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.6	85.1	66.7	80.9	65.1	77.3	63.4	68.8	81.1	66.8	77.5	64.9	74.7	8.1	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.4	91.1	73.4	62.7	85.7	71.5	60.9	80.5	69.6	33.0	80.7	31.3	76.9	29.9	74.7	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.2	21.9	19.4	10.4	90.5	9.8	4.9	3.4	94.0	-2.3	96.8	-7.8	99.6	-14.9	103.1		
(5)			DB	9.9	71.7	8.9	2.7	3.5	73.6	-1.7	75.2	-6.7	76.8	-13.2	78.8	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.1	36.2	35.6	41.2	46.7	54.8	59.1	64.8	63.4	56.8	49.1	42.0	38.5
	DBStd	12.16	9.06	9.00	7.29	6.86	6.74	5.96	5.90	5.53	4.23	6.02	6.55	6.88
	HDD50	1993	430	406	280	147	28	2	0	0	3	90	247	360
	HDD65	5957	894	824	738	551	322	196	80	99	248	493	691	821
	CDD50	1661	1	2	8	46	177	276	457	416	207	63	5	3
	CDD65	153	0	0	0	1	7	20	73	50	2	0	0	0
	CDH74	1616	0	0	0	13	110	238	716	513	26	0	0	0
	CDH80	445	0	0	0	0	7	44	233	158	3	0	0	0
(14) Wind	WSAvg	9.0	11.6	10.6	10.7	8.6	7.9	7.4	7.5	7.7	7.9	8.6	9.3	10.5
(15) Precipitation	PrecAvg	30.7	2.7	2.2	2.1	1.7	2.3	2.8	3.2	2.9	2.8	2.5	2.6	3.0
	PrecMax	42.8	5.4	4.3	5.0	4.2	4.4	5.6	7.3	6.0	6.9	8.5	5.3	6.1
	PrecMin	23.3	0.3	0.6	0.4	0.0	0.9	0.7	1.2	0.8	0.4	0.5	0.1	0.7
	PrecStd	4.7	1.4	1.1	1.2	0.9	1.1	1.3	1.4	1.3	1.5	1.5	1.3	1.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.8	58.7	64.3	75.9	80.6	84.5	91.1	91.1	78.7	69.8	57.5	55.5
		MCWB	49.7	51.7	52.1	59.8	61.8	66.2	68.5	67.5	65.7	60.1	52.9	51.1
	2%	DB	51.4	53.4	58.6	68.4	77.2	80.5	86.2	84.2	71.8	64.5	55.1	53.4
		MCWB	47.2	47.6	49.8	55.2	60.0	64.3	67.9	65.5	62.4	57.2	51.5	49.8
	5%	DB	48.5	49.6	54.0	63.0	73.3	76.3	82.1	79.3	68.1	61.1	53.2	50.4
		MCWB	45.5	45.6	47.6	53.1	58.5	62.6	66.7	64.4	60.1	55.4	50.0	47.4
	10%	DB	46.4	46.5	51.4	58.6	68.2	71.8	77.2	75.3	64.7	58.6	50.4	48.3
		MCWB	43.8	43.3	46.5	51.0	56.7	61.0	64.5	63.2	57.8	53.9	47.8	46.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.7	51.8	52.7	59.9	64.1	70.9	70.9	69.9	67.5	61.0	54.2	52.2
		MCDB	53.2	57.3	60.7	73.6	76.1	80.2	84.5	83.5	74.8	66.6	56.3	54.6
	2%	WB	48.0	48.6	50.6	56.9	61.3	66.1	69.4	67.4	63.5	58.1	52.2	50.1
		MCDB	50.4	52.9	56.4	66.9	73.9	75.7	82.8	80.1	69.4	63.3	54.6	52.7
	5%	WB	45.7	45.5	48.9	54.1	59.3	63.5	67.5	65.7	61.1	55.9	50.4	47.9
		MCDB	48.2	48.7	53.5	61.8	70.8	73.8	78.8	76.4	66.8	60.5	52.6	50.2
	10%	WB	43.5	43.4	46.8	51.3	57.3	61.2	65.5	64.0	59.2	54.3	48.5	45.9
		MCDB	45.9	46.0	50.8	57.8	67.3	70.5	75.4	73.4	64.0	58.2	50.5	48.3
(35) Mean Daily Temperature Range	5% DB	MDBR	8.8	11.0	13.0	16.1	18.5	16.9	18.6	18.1	14.6	13.0	10.1	8.0
		MCDBR	10.2	13.7	18.6	23.2	25.7	25.0	26.1	26.0	20.3	16.9	12.0	10.2
		MCWBR	9.0	10.3	11.8	13.0	13.0	12.6	11.4	11.9	12.1	11.3	9.6	8.9
	5% WB	MCDBR	9.7	12.7	16.7	21.0	23.4	22.5	23.1	22.2	16.6	15.3	10.1	9.6
		MCWBR	9.2	10.1	11.5	12.2	13.0	12.3	11.3	11.5	11.0	10.8	9.0	8.9
(40) Clear-Sky Solar Irradiance	taub		0.323	0.343	0.374	0.407	0.406	0.405	0.419	0.411	0.385	0.358	0.338	0.316
	taud		2.337	2.333	2.264	2.219	2.256	2.281	2.255	2.292	2.356	2.405	2.363	2.327
	Ebn at Noon		207	240	255	261	267	269	262	257	250	232	199	186
	Edh at Noon		19	26	34	40	40	40	40	37	31	24	19	16
(44) All-Sky Solar Radiation	RadAvg		195	410	766	1264	1558	1649	1577	1316	954	542	240	151
	RadStd		20	60	87	146	160	126	204	100	113	54	25	14

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (50 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-229	N/A	N/A

Nomenclature: See separate page