

DIEPHOLZ, Germany

WMO: 103210

Lat: 52.5881N

Lon: 8.3425E

Elev: 43

StdP: 100.81

Time Zone: 1.00 (EUC)

Period: 94-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -9.2	(c) -7.0	(d) -11.9	(e) 1.4	(f) -7.8	(g) -9.6	(h) 1.7	(i) -6.0	(j) 13.2	(k) 7.9	(l) 11.9	(m) 7.4	(n) 3.5	(o) 80	(p) 0.557

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	29.7	19.5	27.5	18.9	25.4	18.0	20.7	27.0	19.7	25.5	18.8	24.0	3.5	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	13.5	22.7	17.7	12.7	21.6	16.9	12.1	20.9	59.6	27.1	56.6	25.7	53.5	24.0	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.4	(b) 9.1	(c) 8.0	(e) -13.1	(f) 33.2	(g) 4.4	(h) 1.7	(i) -16.3	(j) 34.5	(k) -18.9	(l) 35.5	(m) -21.4	(n) 36.4	(o) -24.6	(p) 37.7		
(a) 10.4	(b) 9.1	(c) 8.0	(e) -13.4	(f) 22.6	(g) 4.4	(h) 0.9	(i) -16.6	(j) 23.3	(k) -19.2	(l) 23.8	(m) -21.6	(n) 24.4	(o) -24.9	(p) 25.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.7	1.7	2.7	5.0	9.2	13.0	15.7	18.1	17.9	14.2	9.9	5.7	2.1
	DBStd	6.95	4.77	4.34	3.66	3.74	3.37	3.31	3.24	3.02	2.84	3.60	3.55	4.65
	HDD10.0	1116	257	206	157	59	10	0	0	0	2	47	133	246
	HDD18.3	3260	514	438	412	274	168	93	45	46	128	261	378	503
	CDD10.0	988	1	1	3	36	103	173	251	244	127	44	4	1
	CDD18.3	92	0	0	0	0	3	15	38	32	4	0	0	0
	CDH23.3	944	0	0	0	6	43	151	391	304	48	1	0	0
	CDH26.7	267	0	0	0	0	5	34	127	95	6	0	0	0
Wind	WSAvg	3.5	4.2	4.2	4.0	3.4	3.2	3.2	3.1	2.9	3.1	3.5	3.6	3.9
Precipitation	PrecAvg	736	67	52	49	43	55	66	74	74	63	62	62	69
	PrecMax	1015	123	116	124	107	114	148	167	157	148	218	124	159
	PrecMin	581	7	19	7	1	20	21	33	20	9	11	3	16
	PrecStd	119	32	27	29	22	25	29	33	34	35	37	32	30
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	13.5	17.4	24.1	27.1	30.3	32.9	32.4	27.7	21.2	15.2	13.0
		MCWB	10.6	10.4	11.5	14.5	18.1	20.0	20.2	20.2	19.1	16.7	12.7	11.5
	2%	DB	11.0	11.4	14.8	21.0	24.2	27.2	30.1	29.2	24.7	18.5	13.5	11.1
		MCWB	9.3	9.5	10.2	13.7	16.0	19.0	20.1	19.0	18.2	15.1	12.0	9.8
	5%	DB	9.4	10.1	12.6	18.6	22.1	24.9	27.6	26.8	21.8	16.8	12.1	9.6
		MCWB	8.2	8.5	9.4	12.2	15.0	17.7	19.1	18.6	16.6	14.2	10.6	8.4
	10%	DB	8.0	8.8	10.9	16.2	19.9	22.5	25.2	24.2	19.5	15.3	10.8	8.3
		MCWB	6.9	7.2	8.4	11.3	14.0	16.6	18.1	17.8	15.5	13.3	9.4	7.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.2	11.1	12.8	15.8	19.2	21.3	22.2	21.7	20.1	17.1	13.3	11.7
		MCDB	12.2	12.6	15.9	21.3	25.2	27.9	29.6	28.3	25.4	20.2	14.3	12.8
	2%	WB	9.7	9.9	11.2	14.2	17.3	19.9	20.8	20.4	18.5	15.7	12.1	10.0
		MCDB	10.8	11.2	13.6	19.6	22.6	25.8	27.5	26.3	23.3	17.9	13.5	11.0
	5%	WB	8.2	8.6	9.9	13.1	15.8	18.6	19.8	19.4	17.2	14.6	10.7	8.6
		MCDB	9.2	9.9	12.3	17.5	20.3	23.4	25.8	24.6	21.0	16.3	11.9	9.5
	10%	WB	6.9	7.3	8.5	11.8	14.5	17.3	18.9	18.4	16.1	13.5	9.6	7.2
		MCDB	8.0	8.6	10.6	15.7	18.6	21.2	24.2	23.0	18.9	15.1	10.6	8.2
Mean Daily Temperature Range	5% DB	MDBR	4.7	5.3	7.3	9.5	9.6	9.6	9.7	9.8	9.1	7.7	5.4	4.5
		MCDBR	5.4	6.2	10.8	13.9	13.5	13.7	14.6	14.4	12.8	9.3	6.5	5.4
		MCWBR	4.7	4.9	7.0	7.4	6.9	6.7	6.1	6.2	7.0	6.4	5.3	4.8
	5% WB	MCDBR	5.1	5.6	9.3	11.7	11.5	12.2	12.9	11.8	11.4	8.6	6.0	5.3
		MCWBR	4.6	4.7	6.5	6.7	6.6	6.5	5.8	5.7	6.6	6.3	5.2	4.9
Clear-Sky Solar Irradiance	taub	0.324	0.344	0.376	0.410	0.410	0.409	0.423	0.415	0.388	0.359	0.339	0.317	
	taud	2.347	2.337	2.263	2.213	2.248	2.271	2.246	2.284	2.351	2.407	2.370	2.335	
	Ebn at Noon	659	758	803	821	841	844	824	808	786	732	632	593	
	Edh at Noon	61	82	107	127	129	127	128	117	98	76	60	52	
All-Sky Solar Radiation	RadAvg	0.63	1.32	2.40	3.95	4.84	5.15	4.93	4.13	3.01	1.73	0.78	0.49	
	RadStd	0.06	0.19	0.28	0.46	0.51	0.39	0.65	0.31	0.36	0.17	0.08	0.05	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (53 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page