

WIESENBURG, Germany

WMO: 103680

Lat: 52.1206N

Lon: 12.4586E

Elev: 616

StdP: 14.37

Time Zone: 1.00 (EUC)

Period: 94-04

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.4	14.7	5.3	7.4	11.8	10.6	9.7	16.4	27.8	38.7	25.4	35.0	12.5	90	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.4	85.6	66.2	81.6	64.6	78.1	63.6	68.3	79.8	66.5	77.0	64.9	74.6	8.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.5	92.8	71.7	63.0	88.1	70.2	61.4	83.2	68.6	32.9	79.8	31.4	77.1	30.2	74.9	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
23.2	20.3	18.0	DB	6.3	91.4	5.4	3.4	2.4	93.9	-0.7	95.9	-3.8	97.9	-7.7	100.4
			WB	5.7	71.7	5.4	1.4	1.9	72.7	-1.3	73.5	-4.3	74.3	-8.2	75.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.5	31.2	34.1	38.7	46.4	55.1	59.9	64.2	65.3	56.3	48.0	38.3	31.5	
	DBStd	14.06	8.71	8.77	6.54	7.96	6.65	6.54	6.31	6.08	5.85	6.91	6.50	8.26	
	HDD50	2624	584	446	355	161	25	1	0	0	9	120	351	572	
	HDD65	6578	1049	865	816	558	313	181	92	73	266	528	800	1037	
	CDD50	1717	0	1	4	54	184	299	442	475	200	57	1	0	
	CDD65	196	0	0	0	1	7	29	69	83	7	0	0	0	
	CDH74	1795	0	0	0	15	91	301	639	693	56	0	0	0	
	CDH80	494	0	0	0	1	8	90	206	185	4	0	0	0	
Wind	WSAvg	8.5	8.9	10.3	9.9	8.6	7.8	7.6	7.6	7.6	8.0	8.8	8.5	9.0	
Precipitation	PrecAvg	24.0	1.9	1.5	1.6	1.2	2.3	2.4	2.8	2.6	2.1	1.7	1.9	2.0	
	PrecMax	33.2	3.8	2.8	3.9	3.3	5.0	5.0	8.0	5.9	5.7	4.3	4.1	4.0	
	PrecMin	16.8	0.2	0.4	0.3	0.0	0.3	1.0	0.7	0.8	0.6	0.3	0.0	0.6	
	PrecStd	4.3	0.9	0.7	0.9	0.7	1.3	1.1	1.6	1.4	1.3	0.9	0.9	0.8	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.2	55.0	61.4	76.1	81.1	88.8	90.0	90.1	79.8	69.7	55.1	52.2	
		MCWB	47.4	49.3	51.3	59.1	62.3	68.1	65.1	67.5	63.5	61.3	51.6	48.9	
	2%	DB	47.9	51.9	56.0	68.1	76.5	81.7	86.0	84.5	74.7	63.6	52.3	48.6	
		MCWB	44.7	47.5	48.9	55.5	61.4	65.2	65.8	65.7	61.8	57.5	49.5	46.3	
	5%	DB	44.8	49.1	52.0	63.7	71.5	76.8	81.1	81.3	70.1	60.3	49.9	45.4	
		MCWB	42.1	45.7	47.8	53.8	59.1	62.9	65.0	64.5	60.2	55.7	47.3	43.6	
	10%	DB	41.8	46.4	48.6	59.6	67.4	72.1	76.7	77.8	66.2	57.3	47.4	42.4	
		MCWB	39.8	43.2	44.7	51.4	56.9	61.5	63.5	63.8	58.5	54.0	45.5	40.6	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.3	50.2	52.7	61.1	65.0	69.8	70.3	70.5	64.7	62.1	52.3	49.6
			MCDB	50.5	53.3	57.8	72.3	76.3	83.6	83.4	83.2	74.6	69.4	53.6	51.2
2%		WB	45.3	48.4	50.3	57.6	62.6	67.0	68.0	68.4	63.1	58.5	50.1	46.3	
		MCDB	47.5	51.4	54.8	66.1	74.1	79.2	78.9	79.0	72.4	62.2	51.9	48.1	
5%		WB	42.2	45.9	47.9	54.7	60.2	64.8	66.1	66.5	61.3	56.3	47.6	43.8	
		MCDB	44.5	48.5	51.7	62.0	69.2	74.0	77.0	76.2	68.7	59.4	49.5	45.4	
10%		WB	39.9	43.4	45.1	52.0	58.1	62.6	64.5	64.8	59.2	54.4	45.6	40.6	
		MCDB	41.7	46.1	48.1	58.4	65.3	70.5	74.1	74.2	64.3	56.9	47.2	41.9	
Mean Daily Temperature Range		5% DB	MDBR	8.0	9.8	11.6	15.5	16.8	16.7	16.8	17.4	14.0	11.7	8.2	7.3
			MCDBR	10.9	11.7	16.5	21.5	23.6	24.2	24.3	23.7	20.2	14.8	10.4	9.1
	MCWBR		8.7	8.7	11.1	11.9	12.2	11.1	9.1	9.1	10.0	9.5	8.1	7.9	
	5% WB	MCDBR	10.5	10.0	15.1	19.9	20.9	21.5	20.3	20.1	18.0	13.9	10.4	9.1	
		MCWBR	8.8	7.9	10.8	11.4	11.5	11.4	9.2	9.0	9.7	9.6	8.8	8.3	
Clear-Sky Solar Irradiance	taub	0.314	0.337	0.376	0.407	0.407	0.403	0.423	0.416	0.380	0.360	0.336	0.309		
	taud	2.358	2.340	2.249	2.223	2.263	2.296	2.249	2.284	2.366	2.396	2.395	2.363		
	Ebn at Noon	216	245	256	262	268	270	262	257	253	233	206	197		
	Edh at Noon	19	26	35	40	40	39	41	37	31	25	19	16		
All-Sky Solar Radiation	RadAvg	212	431	754	1254	1546	1647	1548	1334	969	547	254	160		
	RadStd	24	74	88	161	184	132	202	110	114	64	34	17		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (44 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.86	N/A	N/A	N/A	N/A

Nomenclature: See separate page