

GOERLITZ, Germany

WMO: 104990

Lat: 51.1622N

Lon: 14.9506E

Elev: 786

StdP: 14.28

Time Zone: 1.00 (EUC)

Period: 82-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.4	12.3	1.0	5.9	7.9	6.9	8.1	13.5	31.3	41.4	29.0	38.1	5.9	70	0.601

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.0	83.8	65.6	80.2	64.6	77.2	63.6	68.1	79.7	66.3	76.9	64.8	74.4	7.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.2	92.7	72.1	62.5	87.2	70.1	60.9	82.2	68.6	32.8	80.0	31.4	76.7	30.2	74.6	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.5	24.3	21.2	4.6	90.3	10.1	3.2	-2.7	92.6	-8.7	94.5	-14.4	96.3	-21.7	98.6
			4.1	72.0	10.0	1.8	-3.1	73.3	-9.0	74.3	-14.6	75.4	-21.8	76.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.5	31.1	30.9	39.3	46.0	55.0	60.1	64.1	63.9	56.9	49.2	38.8	34.0
	DBStd	13.99	10.10	9.76	7.61	6.96	6.56	6.07	5.63	6.24	5.46	7.20	6.58	7.31
	HDD50	2589	586	535	336	160	29	1	0	0	4	102	338	498
	HDD65	6532	1051	954	796	570	315	172	87	97	252	490	786	962
	CDD50	1694	0	1	5	40	184	304	438	431	210	79	2	0
	CDD65	159	0	0	0	0	4	24	59	63	8	1	0	0
	CDH74	1462	0	0	0	0	46	233	559	574	50	0	0	0
	CDH80	325	0	0	0	0	2	40	124	157	2	0	0	0
	WSAvg	9.3	12.7	10.9	10.6	8.2	7.3	7.2	6.8	6.6	7.9	9.6	11.5	12.2
	PrecAvg	26.4	1.9	1.5	1.9	1.4	2.4	2.8	3.4	3.2	2.2	1.7	2.0	1.9
(15) Precipitation	PrecMax	38.1	4.1	3.1	4.5	2.6	4.7	8.2	8.1	8.9	5.6	3.8	4.2	3.3
	PrecMin	16.5	0.1	0.1	0.7	0.0	0.7	1.3	0.2	0.3	0.8	0.3	0.0	0.6
	PrecStd	4.6	1.0	0.8	1.0	0.7	1.1	1.5	1.9	1.7	1.2	0.9	1.0	0.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.3	56.3	62.1	70.9	78.8	84.6	87.4	90.6	79.5	71.3	55.9	52.5
		MCWB	46.1	48.3	51.1	55.9	62.3	65.6	67.6	68.1	64.2	60.4	50.0	47.0
	2%	DB	47.0	50.9	56.9	66.2	74.6	80.0	83.6	84.4	74.5	66.4	52.3	49.4
		MCWB	44.2	45.6	48.3	54.1	59.5	64.0	65.1	66.7	62.3	57.6	48.3	46.1
	5%	DB	44.7	45.6	52.9	62.1	71.6	76.3	80.0	79.9	70.9	62.8	49.7	46.9
		MCWB	42.0	41.4	45.9	51.6	58.4	62.9	64.9	64.8	60.3	55.4	46.5	44.2
	10%	DB	42.5	41.9	49.5	58.5	68.2	72.7	76.8	76.5	67.1	59.8	47.3	44.1
		MCWB	39.7	38.7	44.3	49.9	56.9	60.8	63.4	63.7	59.2	53.7	44.4	41.9
	0.4%	WB	46.8	49.3	52.8	57.5	64.3	68.8	70.7	70.3	65.9	61.9	51.2	48.1
		MCDB	49.5	54.5	59.8	67.7	74.1	78.0	83.9	83.5	75.3	69.2	54.3	50.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	44.5	45.6	49.0	55.3	61.6	66.0	68.1	68.1	63.7	58.9	48.9	46.3
		MCDB	46.5	50.5	55.2	64.6	71.8	77.0	78.9	81.5	71.8	64.1	51.6	48.7
	5%	WB	42.3	41.7	47.0	52.6	59.7	64.3	66.2	66.3	61.8	56.4	46.8	44.5
		MCDB	44.4	44.9	51.7	60.7	68.5	74.2	76.6	77.0	68.6	61.7	49.3	46.8
	10%	WB	39.9	39.0	45.1	50.3	57.7	62.2	64.4	64.6	60.0	54.2	44.8	42.1
		MCDB	42.0	42.2	49.3	56.7	66.4	70.5	74.2	73.9	66.2	59.1	47.1	44.0
(35) Mean Daily Temperature Range	5% DB	MDBR	8.0	9.9	11.9	15.6	17.7	16.6	18.0	18.1	15.0	13.1	8.6	7.4
		MCDBR	9.5	13.7	17.4	21.7	24.0	23.1	24.6	23.9	21.1	17.1	11.4	8.8
		MCWBR	8.2	9.7	11.3	12.5	12.1	10.9	10.8	10.7	10.9	10.2	8.4	7.1
	5% WB	MCDBR	9.3	12.6	15.9	19.7	20.2	19.7	21.3	21.1	17.9	14.8	11.0	8.4
		MCWBR	8.5	9.4	10.9	12.0	11.3	10.3	10.6	10.4	10.1	9.5	8.7	7.1
(40) Clear-Sky Solar Irradiance	taub		0.308	0.331	0.372	0.415	0.415	0.412	0.430	0.424	0.384	0.360	0.334	0.303
	taud		2.351	2.329	2.258	2.199	2.241	2.278	2.234	2.271	2.353	2.393	2.402	2.381
	Ebn at Noon		225	251	259	261	266	268	260	255	253	237	213	208
	Edh at Noon		20	27	35	41	42	40	42	38	31	25	19	17
(44) All-Sky Solar Radiation	RadAvg		241	467	789	1290	1564	1665	1581	1391	996	571	267	176
	RadStd		38	81	110	177	180	133	191	135	134	79	40	19

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (49 neighbors)	+0.76	N/A	N/A	N/A	N/A	+0.65	N/A	N/A	+95	+32	

Nomenclature: See separate page