

IDAR-OBERSTEIN, Germany

WMO: 106180

Lat: 49.6928N

Lon: 7.3264E

Elev: 1234

StdP: 14.05

Time Zone: 1.00 (EUC)

Period: 94-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.7	17.4	8.8	9.0	16.0	13.2	11.3	20.3	30.1	44.2	27.1	43.8	4.2	60	0.569

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.0	85.6	66.2	81.7	64.7	78.2	63.3	67.8	81.4	66.2	78.4	64.6	75.5	7.5	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.3	91.2	71.3	61.8	86.3	70.1	60.4	81.9	68.9	32.8	81.7	31.5	78.4	30.3	75.4	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.9	19.3	16.9	DB	5.2	91.3	5.6	3.0	1.2	93.5	-2.1	95.3	-5.2	97.0	-9.3	99.2	
			WB	5.3	70.6	5.4	1.5	1.4	71.7	-1.8	72.5	-4.8	73.4	-8.8	74.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	48.0	32.1	34.8	40.2	47.5	54.5	60.4	63.4	63.1	56.3	48.5	40.5	33.8	(6)
(7)		DBStd	13.00	8.31	7.70	6.98	6.92	6.49	6.25	5.91	5.65	5.45	6.71	6.45	7.85	(7)
(8)		HDD50	2357	556	425	309	128	30	2	0	0	8	109	289	501	(8)
(9)		HDD65	6337	1020	845	768	525	330	165	105	102	265	511	735	966	(9)
(10)		CDD50	1627	0	0	5	53	169	314	414	408	197	63	4	0	(10)
(11)		CDD65	135	0	0	0	0	5	27	54	45	4	0	0	0	(11)
(12)		CDH74	1830	0	0	0	9	98	348	676	609	89	1	0	0	(12)
(13)		CDH80	514	0	0	0	0	13	76	207	205	13	0	0	0	(13)
(14)	Wind	WSAvg	7.0	7.9	8.6	7.7	6.8	6.7	6.3	6.6	6.1	6.0	6.4	6.8	8.1	(14)
(15)	Precipitation	PrecAvg	31.3	3.0	2.6	2.3	1.9	2.4	2.5	2.6	2.7	2.3	2.7	2.8	3.5	(15)
(16)		PrecMax	42.9	9.2	8.2	6.9	5.2	5.7	5.8	7.7	6.1	5.0	9.2	5.9	10.1	(16)
(17)		PrecMin	21.5	0.4	0.2	0.4	0.1	0.5	0.8	1.0	0.3	0.7	0.6	0.2	0.2	(17)
(18)		PrecStd	5.3	1.7	1.8	1.5	1.0	1.2	1.4	1.5	1.4	1.1	1.7	1.3	2.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.7	54.1	65.2	75.1	81.7	86.6	89.9	93.5	82.0	71.4	58.1	51.8	(19)
(20)		MCWB	49.1	46.3	50.6	56.2	63.8	66.5	67.8	66.8	63.9	60.9	53.2	49.5		(20)
(21)		2%	DB	49.3	50.3	59.7	70.4	76.5	81.8	85.6	85.4	76.2	65.4	54.1	49.7	(21)
(22)		MCWB	47.2	44.9	48.5	54.8	61.0	65.1	66.5	65.8	62.4	57.8	50.7	47.4		(22)
(23)		5%	DB	46.5	47.6	55.2	65.7	72.7	77.9	81.6	80.6	71.5	61.5	51.7	47.3	(23)
(24)		MCWB	44.4	44.1	46.9	52.4	58.5	63.2	64.9	64.0	60.3	55.9	49.3	45.3		(24)
(25)		10%	DB	43.8	45.4	51.4	61.3	68.5	74.2	77.3	76.4	67.3	58.4	49.3	44.9	(25)
(26)		MCWB	41.8	42.6	46.0	50.4	56.3	61.7	63.3	62.8	58.3	54.5	47.2	43.3		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.1	48.2	52.6	58.3	66.2	68.8	69.9	69.2	66.2	62.1	54.0	50.2	(27)
(28)		MCDWB	51.0	51.1	61.0	72.4	77.6	81.5	84.8	85.1	76.7	68.1	56.6	51.2		(28)
(29)		2%	WB	47.3	46.2	50.3	55.6	62.7	66.8	67.8	67.4	63.7	59.2	51.5	47.6	(29)
(30)		MCDWB	49.1	49.0	56.8	67.2	74.4	78.7	82.0	81.2	73.3	64.1	53.6	49.2		(30)
(31)		5%	WB	44.4	44.5	48.3	53.5	59.9	64.7	66.1	65.5	61.5	56.8	49.4	45.6	(31)
(32)		MCDWB	46.2	47.0	53.9	63.2	69.8	75.6	78.6	77.4	69.6	60.4	51.3	47.1		(32)
(33)		10%	WB	41.9	42.7	46.4	51.5	57.4	62.7	64.2	63.9	59.4	54.7	47.3	43.2	(33)
(34)		MCDWB	43.7	45.3	51.1	59.9	66.0	72.3	74.5	74.5	65.7	58.0	48.9	44.7		(34)
(35)	Mean Daily Temperature Range	MDBR	8.7	11.0	14.9	18.9	19.5	20.4	20.0	20.4	18.7	14.6	9.3	7.9		(35)
(36)		5% DB	MCDBR	9.9	14.7	22.9	27.7	27.7	27.6	28.7	30.3	26.7	19.5	13.0	8.7	(36)
(37)		MCWBR	8.5	10.3	13.6	13.8	13.6	13.1	12.2	12.9	13.8	12.2	9.6	7.6		(37)
(38)		5% WB	MCDBR	9.5	11.8	19.2	23.9	24.8	24.8	25.8	25.1	22.3	17.1	11.4	8.8	(38)
(39)		MCWBR	8.7	8.9	12.1	12.4	12.8	12.3	11.7	11.6	12.3	11.0	9.0	8.0		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.309	0.336	0.367	0.393	0.400	0.403	0.401	0.397	0.371	0.358	0.331	0.307		(40)
(41)		taud	2.418	2.364	2.295	2.266	2.271	2.289	2.284	2.323	2.377	2.401	2.415	2.410		(41)
(42)		Ebn at Noon	235	254	265	270	272	272	270	266	261	242	222	217		(42)
(43)		Edh at Noon	20	27	34	39	41	40	40	36	31	26	20	18		(43)
(44)	All-Sky Solar Radiation	RadAvg	254	484	860	1349	1594	1774	1682	1440	1080	622	286	198		(44)
(45)		RadStd	38	91	131	169	164	158	176	148	130	59	32	30		(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(46)
(47)	Regional (51 neighbors)	(m) N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page