

PFRDSFELD, Germany

WMO: 106260

Lat: 49.850N

Lon: 7.600E

Elev: 396

StdP: 96.66

Time Zone: 1.00 (EUC)

Period: 86-96

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-10.1	-8.0	-13.1	1.3	-8.2	-11.1	1.5	-6.7	13.3	5.8	11.6	4.0	3.4	70	0.579

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	28.2	18.4	26.6	17.8	24.9	17.1	19.7	26.1	18.7	24.7	17.7	23.4	3.8	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.2	12.9	22.3	16.2	12.1	21.1	15.4	11.5	20.2	58.2	25.8	54.7	24.7	51.4	23.5	22.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.0	9.6	8.4	DB	-12.4	31.9	3.0	2.7	-14.6	33.9	-16.4	35.5	-18.1	37.0	-20.3	39.0	(4)
(5)			WB	-12.6	21.4	3.1	1.0	-14.8	22.1	-16.7	22.7	-18.4	23.3	-20.7	24.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.7	0.4	0.3	4.3	7.8	12.4	15.0	17.9	17.5	13.2	9.0	3.9	1.7	(6)	
	DBStd	7.32	4.45	4.52	3.99	4.01	3.72	3.71	3.54	3.67	2.87	3.57	3.53	3.99	(7)	
	HDD10.0	1372	298	272	180	90	19	3	0	0	4	63	184	259	(8)	
	HDD18.3	3621	557	505	434	316	185	114	53	59	156	289	434	517	(9)	
	CDD10.0	884	0	0	4	24	94	152	244	233	100	32	1	1	(10)	
	CDD18.3	90	0	0	0	0	2	12	39	34	2	0	0	0	(11)	
	CDH23.3	727	0	0	0	1	15	96	323	279	14	0	0	0	(12)	
	CDH26.7	149	0	0	0	0	1	7	72	70	1	0	0	0	(13)	
(14) Wind	WSAvg	3.4	4.2	3.6	4.1	3.3	3.1	3.0	3.0	2.8	3.1	3.2	3.3	4.0	(14)	
(15) Precipitation	PrecAvg	629	50	46	43	39	56	58	65	60	48	53	53	58	(15)	
	PrecMax	884	166	122	125	85	124	147	182	118	111	155	96	166	(16)	
	PrecMin	457	7	7	4	0	12	12	22	9	14	10	2	7	(17)	
	PrecStd	102	30	27	28	20	28	30	35	28	25	29	24	31	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.3	13.0	17.8	22.6	25.1	27.8	31.0	31.8	25.8	20.5	12.2	12.1	(19)	
		MCWB	8.3	8.9	11.6	13.1	15.6	18.4	19.7	19.2	16.5	15.5	10.2	10.6	(20)	
	2%	DB	9.0	10.1	14.2	19.8	23.1	26.0	28.5	28.2	22.2	17.4	11.1	10.3	(21)	
		MCWB	7.8	7.7	9.2	12.1	14.5	17.7	18.7	18.4	16.2	13.6	9.7	9.1	(22)	
	5%	DB	7.8	8.1	11.9	17.0	21.2	24.2	26.9	26.2	20.1	15.3	10.0	9.0	(23)	
		MCWB	6.9	6.7	8.4	10.8	13.9	16.6	18.0	17.8	15.3	12.9	8.6	8.1	(24)	
	10%	DB	6.3	6.1	10.0	14.7	19.8	22.0	25.0	24.2	18.1	14.0	8.9	7.3	(25)	
		MCWB	5.4	5.0	7.3	9.7	13.5	15.8	17.2	16.9	14.0	12.2	7.8	6.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.0	9.6	12.1	14.1	17.2	20.4	21.0	20.3	19.0	16.3	11.0	11.0	(27)	
		MCDB	9.9	12.1	17.2	20.6	22.0	25.6	28.0	27.9	22.6	19.3	11.7	11.8	(28)	
	2%	WB	7.8	8.1	10.0	12.6	15.5	18.8	19.9	19.3	17.1	14.4	9.9	9.5	(29)	
		MCDB	8.6	9.8	12.7	18.7	21.2	23.3	26.4	26.5	20.7	16.3	11.1	10.3	(30)	
	5%	WB	6.6	6.6	8.9	11.2	14.5	17.4	18.8	18.4	15.8	13.3	8.9	8.1	(31)	
		MCDB	7.3	7.9	11.0	16.3	20.2	22.8	25.1	24.8	19.2	15.1	9.8	8.9	(32)	
	10%	WB	5.4	5.1	7.5	9.9	13.7	16.1	17.7	17.5	14.7	12.3	7.7	6.5	(33)	
		MCDB	6.2	5.9	9.8	13.9	18.8	21.0	23.6	23.2	17.6	13.8	8.5	7.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.6	5.6	7.4	8.8	9.5	9.1	9.9	10.1	8.2	6.8	5.2	4.3	(35)	
		MCDBR	6.2	8.1	10.4	11.9	12.0	12.1	12.5	12.8	11.0	8.8	6.3	5.5	(36)	
	5% WB	MCWBR	5.4	6.0	6.4	6.4	6.4	6.0	5.7	5.9	6.3	5.8	5.0	5.0	(37)	
		MCWBR	5.8	7.8	9.1	11.0	10.7	10.8	11.3	11.4	9.9	8.1	5.6	5.3	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.311	0.338	0.370	0.393	0.399	0.402	0.402	0.397	0.371	0.360	0.333	0.309	(40)	
		taud	2.410	2.354	2.281	2.262	2.273	2.288	2.279	2.321	2.374	2.391	2.401	2.400	(41)	
	Ebn at Noon	Ebn at Noon	734	796	829	849	859	857	851	837	822	760	694	677	(42)	
		Edh at Noon	64	86	109	123	127	127	126	115	98	82	64	56	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.79	1.52	2.69	4.23	4.99	5.54	5.25	4.50	3.36	1.94	0.90	0.62	(44)	
	RadStd	RadStd	0.12	0.28	0.41	0.53	0.51	0.50	0.56	0.46	0.41	0.19	0.10	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (51 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page