

HOF PLAUEN, Germany

WMO: 106850

Lat: 50.3122N

Lon: 11.8761E

Elev: 567

StdP: 94.70

Time Zone: 1.00 (EUC)

Period: 90-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-14.1	-11.0	-17.8	0.8	-13.1	-14.2	1.2	-9.1	12.2	5.1	11.0	2.9	3.1	20	0.603

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	28.1	18.0	26.0	17.2	24.1	16.2	18.9	25.8	18.0	24.3	17.2	22.5	3.3	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.8	12.8	21.0	15.9	12.1	20.0	15.1	11.4	19.2	55.9	25.5	53.1	24.3	50.4	22.6	21.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.5	8.4	7.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.5	-1.3	-1.4	3.5	7.6	11.1	14.6	16.6	16.7	12.5	7.1	3.3	-1.2
	DBStd	7.69	4.38	5.51	4.16	4.34	3.86	3.48	3.18	3.37	2.97	4.20	3.31	4.36
	HDD10.0	1673	351	318	202	96	33	3	0	1	8	109	202	349
	HDD18.3	4017	609	552	458	322	224	122	73	74	177	347	452	607
	CDD10.0	750	0	0	2	24	69	141	204	207	82	19	1	0
	CDD18.3	53	0	0	0	1	1	9	19	22	1	0	0	0
	CDH23.3	574	0	0	0	4	14	97	204	237	18	0	0	0
	CDH26.7	135	0	0	0	0	1	19	53	61	1	0	0	0
Wind	WSAvg	3.5	4.0	4.0	3.6	3.2	3.2	3.1	2.9	2.8	2.9	3.5	4.0	4.3
Precipitation	PrecAvg	763	59	52	52	44	62	76	90	75	66	56	64	66
	PrecMax	980	123	131	127	86	148	122	154	197	129	153	142	170
	PrecMin	574	3	10	11	5	8	29	29	21	25	19	0	23
	PrecStd	108	27	28	29	19	33	27	32	38	26	28	32	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.1	12.8	17.1	22.0	25.0	29.1	30.2	31.1	25.9	21.0	12.9	9.1
		MCWB	7.3	8.1	9.2	12.1	15.1	18.4	18.8	19.2	16.7	14.3	10.3	7.0
	2%	DB	7.2	9.4	14.8	19.9	22.9	26.1	28.1	28.2	22.9	17.3	10.9	7.0
		MCWB	6.3	6.1	8.2	11.4	14.4	16.9	18.1	18.0	15.0	12.6	9.0	5.5
	5%	DB	5.9	6.9	12.1	17.9	20.9	23.9	25.2	26.0	20.8	15.1	9.2	5.3
		MCWB	4.9	5.0	7.0	10.7	13.2	16.1	16.9	17.5	14.5	11.8	7.6	4.3
	10%	DB	4.8	5.1	9.8	15.2	18.8	21.6	23.3	23.8	18.2	13.1	7.9	4.0
		MCWB	3.9	3.3	6.6	9.6	12.2	15.1	16.4	16.3	13.6	10.6	6.7	3.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.7	8.6	10.2	13.1	16.2	19.1	20.2	20.3	17.5	14.8	10.6	7.6
		MCDB	8.3	12.0	14.7	20.0	23.3	26.1	27.3	27.9	23.8	18.1	12.4	8.6
	2%	WB	6.3	6.6	8.9	11.9	14.8	17.9	18.8	19.1	16.0	13.5	9.4	5.5
		MCDB	7.1	8.7	13.0	18.6	21.1	23.7	25.8	25.9	20.7	17.2	10.8	6.4
	5%	WB	4.9	5.0	7.8	11.1	13.8	16.9	18.0	18.1	15.0	11.9	8.0	4.3
		MCDB	5.6	6.4	11.4	16.6	19.6	22.4	23.9	24.7	19.2	14.4	9.2	5.0
	10%	WB	3.6	3.3	6.6	10.0	12.7	15.9	17.1	17.1	14.1	10.8	6.6	3.2
		MCDB	4.3	4.7	9.3	14.8	17.6	20.3	21.9	22.4	18.0	13.0	7.6	3.9
Mean Daily Temperature Range	5% DB	MDBR	4.1	5.6	7.6	9.2	9.5	9.5	10.1	10.6	9.0	7.4	4.6	4.2
		MCDBR	5.0	8.5	12.7	13.2	13.6	13.9	14.3	14.3	13.3	10.4	6.1	5.2
		MCWBR	4.4	5.8	7.3	6.6	6.6	6.3	6.2	6.0	6.8	6.2	4.8	4.6
	5% WB	MCDWR	4.7	8.0	11.2	11.9	12.0	12.1	12.2	12.8	11.2	9.6	5.5	4.8
MCWBR		4.4	5.9	6.8	6.4	6.5	6.0	5.7	6.1	6.2	6.0	4.6	4.5	
Clear-Sky Solar Irradiance	taub	0.290	0.312	0.351	0.388	0.391	0.392	0.404	0.397	0.366	0.341	0.316	0.288	
	taud	2.406	2.365	2.332	2.274	2.295	2.314	2.278	2.318	2.385	2.449	2.462	2.421	
	Ebn at Noon	755	825	849	853	865	866	847	835	824	782	717	701	
	Edh at Noon	62	83	103	121	124	123	126	115	97	76	59	53	
All-Sky Solar Radiation	RadAvg	0.80	1.57	2.61	4.08	4.86	5.31	5.04	4.37	3.14	1.85	0.88	0.61	
	RadStd	0.15	0.24	0.35	0.53	0.57	0.45	0.56	0.44	0.44	0.23	0.12	0.07	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (49 neighbors)	N/A	N/A	N/A	N/A	+0.33	+0.39	N/A	N/A	+57	+21

Nomenclature: See separate page