

SAARBRUCKEN, Germany

WMO: 107080

Lat: 49.2128N

Lon: 7.1078E

Elev: 320

StdP: 97.54

Time Zone: 1.00 (EUC)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.1	-6.0	-12.8	1.3	-6.2	-9.8	1.7	-4.6	13.2	8.2	11.8	7.6	3.1	70	0.538

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	30.8	19.6	28.2	18.8	26.8	18.3	20.5	28.0	19.7	26.7	18.8	25.1	3.3	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	13.5	22.9	17.1	12.7	22.1	16.2	12.0	21.2	60.3	28.6	57.5	26.7	54.7	25.2	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.9	8.6	7.6	-11.3	33.7	2.9	1.5	-13.4	34.8	-15.1	35.7	-16.8	36.5	-18.9	37.6		
(5)			-11.7	22.5	3.0	1.1	-13.9	23.3	-15.6	24.0	-17.3	24.6	-19.5	25.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.4	1.6	2.1	6.0	10.6	13.6	17.5	19.4	18.3	15.1	11.0	6.0	2.9	(6)
(7)		DBStd	7.32	4.14	4.17	4.08	3.97	3.80	3.64	3.55	3.39	3.13	3.84	3.81	4.05	(7)
(8)		HDD10.0	1052	262	221	132	39	9	1	0	0	1	36	129	221	(8)
(9)		HDD18.3	3058	520	454	382	232	154	58	30	43	107	229	371	478	(9)
(10)		CDD10.0	1193	1	1	8	59	121	226	292	257	153	66	9	1	(10)
(11)		CDD18.3	158	0	0	0	1	7	34	64	42	9	1	0	0	(11)
(12)		CDH23.3	1388	0	0	0	13	71	298	579	352	72	2	0	0	(12)
(13)		CDH26.7	410	0	0	0	1	14	81	194	111	10	0	0	0	(13)
(14)	Wind	WSAvg	3.5	4.2	4.0	4.1	3.3	3.0	3.1	2.9	3.0	3.3	3.7	4.2	(14)	
(15)	Precipitation	PrecAvg	851	70	62	63	56	73	72	78	76	67	91	87	(15)	
(16)		PrecMax	1192	176	165	170	127	187	152	198	260	164	196	199	287	(16)
(17)		PrecMin	536	10	11	8	14	13	0	14	14	20	4	16	2	(17)
(18)		PrecStd	163	36	40	33	28	38	38	42	46	38	41	43	61	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.9	14.0	19.1	25.1	28.8	31.8	33.9	28.1	23.1	16.8	12.8	(19)	
(20)			MCWB	10.3	8.2	10.5	15.0	18.8	20.4	20.4	20.2	18.4	16.2	13.4	10.0	(20)
(21)		2%	DB	10.2	10.8	16.9	22.8	25.1	29.0	31.0	29.9	25.8	20.8	14.2	11.1	(21)
(22)			MCWB	8.6	7.3	9.6	13.2	16.6	19.0	19.4	19.9	17.7	15.4	11.6	9.3	(22)
(23)		5%	DB	8.9	9.1	14.1	20.2	22.9	26.8	28.9	27.0	23.1	18.1	12.9	9.9	(23)
(24)			MCWB	7.7	6.9	8.8	12.2	15.2	18.7	18.9	18.7	16.6	14.4	10.9	8.3	(24)
(25)		10%	DB	7.1	7.8	12.0	17.9	20.8	24.8	26.8	24.9	21.0	16.1	11.8	8.2	(25)
(26)			MCWB	6.4	6.2	8.0	11.3	14.6	17.7	18.1	17.4	15.9	13.4	10.0	7.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.6	9.4	11.9	15.7	19.7	21.7	21.4	21.5	19.5	17.0	14.0	11.0	(27)
(28)			MCDWB	11.7	11.3	16.2	23.2	27.0	29.5	29.1	29.5	25.7	21.0	15.6	12.0	(28)
(29)		2%	WB	9.3	8.1	10.6	14.1	17.8	20.2	20.2	20.2	18.3	15.8	12.2	9.6	(29)
(30)			MCDWB	10.3	10.1	14.8	21.2	23.9	26.7	28.4	27.3	24.0	19.3	14.0	10.9	(30)
(31)		5%	WB	7.6	7.0	9.6	12.7	16.2	19.2	19.6	19.3	17.4	14.7	11.1	8.5	(31)
(32)			MCDWB	8.5	8.7	13.2	19.0	20.8	25.1	27.2	25.8	22.3	17.6	12.9	9.5	(32)
(33)		10%	WB	6.2	5.8	8.6	11.7	14.8	18.2	18.7	18.4	16.2	13.8	9.9	7.3	(33)
(34)			MCDWB	7.0	7.2	11.7	17.0	19.3	23.7	25.2	23.9	20.0	16.3	11.7	8.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.4	5.5	8.0	9.7	9.5	9.9	9.7	9.2	7.4	5.0	4.3	(35)	
(36)			MCDBR	5.3	8.0	11.8	13.2	12.8	13.0	13.5	13.4	12.6	9.9	6.6	5.4	(36)
(37)			MCWBR	4.5	5.5	6.6	6.5	6.2	6.0	5.2	5.7	6.0	5.8	4.7	4.3	(37)
(38)		5% WB	MCDWB	5.1	6.9	9.8	12.0	11.3	11.6	11.7	11.6	10.7	8.7	6.2	5.0	(38)
(39)			MCWBR	4.6	5.1	5.9	6.1	5.9	5.8	5.0	5.3	5.6	5.4	4.8	4.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.308	0.334	0.361	0.389	0.399	0.403	0.400	0.396	0.371	0.355	0.328	0.306	(40)	
(41)		taud	2.436	2.391	2.327	2.280	2.279	2.299	2.296	2.334	2.380	2.420	2.440	2.429	(41)	
(42)		Ebn at Noon	750	811	845	856	861	858	854	840	825	773	714	698	(42)	
(43)		Edh at Noon	64	84	105	122	127	126	124	114	99	81	63	56	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.84	1.58	2.79	4.29	5.07	5.71	5.39	4.63	3.50	2.03	0.95	0.67	(44)	
(45)		RadStd	0.13	0.29	0.43	0.56	0.54	0.49	0.54	0.48	0.40	0.18	0.10	0.10	(45)	

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (51 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page