

LECHFELD, Germany

WMO: 108560

Lat: 48.1850N

Lon: 10.8508E

Elev: 562

StdP: 94.75

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.2	-10.2	-14.8	1.1	-13.0	-11.6	1.5	-9.4	12.8	8.0	11.3	6.4	1.9	180	0.548

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	30.2	19.1	28.1	18.4	26.4	17.8	19.9	28.1	19.1	26.6	18.3	25.3	2.9	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.1	13.0	22.7	16.2	12.3	21.6	15.7	11.9	21.2	59.2	28.3	56.4	26.7	53.9	25.4	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	7.9	6.7	-17.2	33.0	3.5	1.7	-19.7	34.2	-21.7	35.2	-23.7	36.1	-26.2	37.3		
(5)			-17.3	21.6	3.4	1.5	-19.8	22.6	-21.8	23.5	-23.7	24.3	-26.2	25.4	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.8	-0.7	0.4	4.2	8.4	12.9	16.5	18.3	18.0	13.4	9.2	3.7	0.5	(6)
(7)		DBStd	7.84	4.87	5.03	4.26	3.85	3.57	3.64	3.21	3.18	3.39	3.92	4.07	4.46	(7)
(8)		HDD10.0	1427	332	268	182	74	13	1	0	0	8	62	193	294	(8)
(9)		HDD18.3	3589	590	501	437	299	172	77	42	46	151	283	439	552	(9)
(10)		CDD10.0	981	0	1	3	26	102	197	256	247	110	38	3	0	(10)
(11)		CDD18.3	102	0	0	0	0	3	22	39	34	3	1	0	0	(11)
(12)		CDH23.3	1303	0	0	0	5	72	296	461	413	53	3	0	0	(12)
(13)		CDH26.7	356	0	0	0	0	9	74	142	127	4	0	0	0	(13)
(14)	Wind	WSAvg	2.9	3.3	3.3	3.6	3.0	2.9	2.6	2.7	2.5	2.6	2.7	2.9	3.2	(14)
(15)	Precipitation	PrecAvg	947	51	47	62	62	105	116	119	110	79	67	66	62	(15)
(16)		PrecMax	1286	119	101	149	141	213	214	248	220	152	167	151	130	(16)
(17)		PrecMin	705	1	14	19	10	7	50	20	41	23	16	0	2	(17)
(18)		PrecStd	131	30	24	31	34	48	43	49	47	36	34	35	31	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.3	15.1	19.1	24.1	28.0	31.5	32.7	33.1	27.1	23.0	16.8	12.0	(19)
(20)			MCWB	7.9	8.4	10.2	13.2	17.1	19.5	19.9	19.2	17.4	15.3	11.4	8.1	(20)
(21)		2%	DB	10.1	11.9	16.2	21.1	25.3	28.9	30.2	29.9	24.9	20.1	13.9	10.0	(21)
(22)			MCWB	6.8	6.8	9.2	12.1	16.3	18.9	19.1	18.9	17.0	14.4	10.1	7.4	(22)
(23)		5%	DB	8.1	9.7	13.7	18.9	23.0	26.8	28.0	27.8	22.8	17.9	11.7	8.5	(23)
(24)			MCWB	5.4	6.0	8.2	11.5	15.1	18.0	18.5	18.2	16.2	13.2	8.8	6.1	(24)
(25)		10%	DB	6.1	7.6	11.2	16.7	20.8	24.8	25.9	25.5	20.2	15.6	9.8	7.0	(25)
(26)			MCWB	4.2	4.8	7.2	10.2	13.9	17.1	17.8	17.8	15.0	12.3	7.7	5.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.8	9.0	11.2	14.1	18.4	20.8	20.9	20.7	18.6	15.8	12.0	8.9	(27)
(28)			MCDWB	11.2	13.9	17.4	22.1	25.7	28.9	30.0	29.2	25.0	21.2	15.6	11.0	(28)
(29)		2%	WB	7.0	7.5	9.7	12.8	16.9	19.5	19.9	19.6	17.5	14.7	10.5	7.7	(29)
(30)			MCDWB	9.5	11.2	14.5	20.0	24.0	27.1	28.4	27.6	23.5	19.3	13.4	9.8	(30)
(31)		5%	WB	5.6	6.1	8.6	11.7	15.6	18.5	19.0	18.8	16.5	13.6	9.1	6.4	(31)
(32)			MCDWB	7.8	9.2	13.1	17.8	22.1	25.6	26.5	26.2	21.7	17.1	11.3	8.1	(32)
(33)		10%	WB	4.2	4.7	7.5	10.5	14.4	17.5	18.2	18.0	15.4	12.5	7.9	5.1	(33)
(34)			MCDWB	6.0	7.2	11.0	15.8	19.8	23.8	24.9	24.9	19.5	15.3	9.7	6.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.6	8.2	9.7	11.5	11.3	11.4	11.5	10.5	9.3	6.9	6.2	(35)	
(36)			MCDBR	8.9	12.1	14.7	16.8	16.2	15.9	16.1	16.0	15.2	13.3	11.1	8.6	(36)
(37)			MCWBR	6.3	7.8	8.8	8.9	8.2	7.4	6.7	6.7	7.8	8.0	7.7	6.1	(37)
(38)		5% WB	MCDBR	8.3	10.8	13.0	15.1	14.7	14.3	14.4	14.3	13.3	12.0	10.1	7.7	(38)
(39)			MCWBR	6.1	7.3	8.0	8.4	7.7	6.8	6.3	6.3	7.1	7.5	7.3	5.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.292	0.316	0.349	0.381	0.391	0.396	0.399	0.393	0.369	0.341	0.312	0.287	(40)	
(41)		taud	2.455	2.389	2.353	2.290	2.298	2.315	2.300	2.335	2.380	2.450	2.486	2.468	(41)	
(42)		Ebn at Noon	790	842	865	868	871	867	858	847	833	801	756	748	(42)	
(43)		Edh at Noon	64	85	103	121	125	124	124	115	100	79	62	56	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.08	1.96	3.08	4.30	4.96	5.56	5.36	4.71	3.41	2.17	1.17	0.88	(44)	
(45)		RadStd	0.14	0.26	0.38	0.57	0.57	0.49	0.49	0.47	0.41	0.26	0.15	0.11	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.38	N/A	N/A	N/A	N/A	+0.64	N/A	N/A	N/A	N/A
(47)	Regional (84 neighbors)	N/A	N/A	N/A	N/A	+0.40	+0.40	N/A	N/A	+58	+20

Nomenclature: See separate page