

FURSTENFELDBRUCK, GermanyWMO: **108580**Lat: **48.206N**Lon: **11.267E**Elev: **1703**StdP: **13.81**Time Zone: **1.00 (EUC)**Period: **82-98**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.8	10.2	3.1	6.8	5.4	7.8	8.7	11.0	32.8	47.3	28.4	42.4	2.8	60	0.559

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.0	84.3	66.0	80.7	64.6	77.4	63.0	67.4	81.0	65.8	78.4	64.2	75.3	6.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.5	90.2	73.9	60.9	85.1	71.2	59.3	80.3	69.3	32.7	81.1	31.5	78.8	30.2	75.5	73.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.9	20.7	17.3	0.1	90.5	8.4	3.1	-5.9	92.7	-10.8	94.5	-15.6	96.3	-21.6	98.5		
(5)			0.0	70.7	8.3	1.9	-6.0	72.1	-10.8	73.2	-15.5	74.2	-21.5	75.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.1	30.4	29.9	39.2	45.4	53.8	59.2	64.8	63.5	57.3	49.3	37.5	33.9
	DBStd	14.26	10.72	10.11	7.96	6.15	6.58	6.23	5.57	5.61	6.05	6.73	7.40	7.94
	HDD50	2697	608	563	344	161	40	3	0	0	7	94	376	501
	HDD65	6670	1073	983	799	587	349	194	73	96	241	487	824	964
	CDD50	1651	0	1	10	24	157	279	459	418	226	72	3	2
	CDD65	147	0	0	0	0	1	20	67	49	10	0	0	0
	CDH74	1635	0	0	0	0	44	224	727	531	104	5	0	0
	CDH80	383	0	0	0	0	2	32	210	132	7	0	0	0
Wind	WSAvg	6.4	7.8	6.8	7.8	7.0	6.4	5.7	5.6	5.4	5.5	5.7	5.8	6.7
Precipitation	PrecAvg	38.2	2.1	1.9	2.4	2.5	4.3	5.0	4.8	4.5	3.1	2.7	2.6	2.4
	PrecMax	48.7	5.4	4.0	5.5	6.1	8.7	7.6	9.8	7.8	5.9	5.4	5.9	4.8
	PrecMin	28.4	0.1	0.5	0.8	0.7	0.4	2.2	0.9	1.9	0.9	0.8	0.0	0.0
	PrecStd	4.6	1.2	0.9	1.3	1.4	1.9	1.6	1.9	1.7	1.3	1.2	1.3	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.3	60.4	69.6	69.6	78.6	84.6	91.1	89.2	80.8	73.5	59.4	57.0
		MCWB	46.4	49.3	53.2	53.6	59.9	67.3	69.3	66.9	63.7	60.2	50.9	47.2
	2%	DB	49.8	52.9	61.1	66.1	74.8	80.3	85.8	83.9	77.1	68.0	55.3	53.3
		MCWB	44.4	45.3	49.2	51.9	58.9	64.0	66.8	65.5	62.7	57.3	49.1	46.5
	5%	DB	46.7	46.7	55.6	62.3	71.4	76.7	81.0	80.3	73.2	62.9	51.7	49.6
		MCWB	42.1	41.5	46.0	50.3	56.6	62.3	65.1	64.6	61.8	54.3	46.9	44.6
	10%	DB	44.1	42.8	51.4	58.7	67.7	73.0	77.4	76.7	69.4	59.0	48.2	45.0
		MCWB	40.0	39.0	44.3	48.7	55.8	60.7	63.5	63.2	59.7	53.1	44.9	41.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.1	49.8	53.6	54.5	62.5	68.1	70.8	68.3	65.8	61.1	52.4	50.2
		MCDB	53.5	60.1	69.1	65.8	72.9	82.4	86.5	82.6	77.2	70.9	58.3	55.0
	2%	WB	44.5	45.9	49.5	53.0	59.7	65.3	68.3	66.8	63.7	58.1	49.4	47.0
		MCDB	49.2	52.0	59.4	64.2	71.8	77.2	81.9	80.8	74.2	66.2	53.8	52.0
	5%	WB	42.1	41.7	47.1	50.8	57.6	63.2	66.3	65.2	62.0	55.3	47.5	44.2
		MCDB	46.0	45.8	55.1	60.4	68.5	74.6	79.1	77.9	71.7	61.8	51.3	48.3
	10%	WB	39.7	38.9	44.7	49.0	56.0	61.1	64.5	63.6	60.0	53.4	44.9	41.8
		MCDB	43.1	42.2	50.0	57.4	66.0	70.8	75.7	74.4	67.7	58.1	48.0	45.3
Mean Daily Temperature Range	5% DB	MDBR	11.8	13.7	15.4	17.4	18.8	18.3	20.0	19.8	18.4	15.5	12.3	10.5
		MCDBR	13.8	20.6	23.9	26.9	27.0	25.9	28.0	27.8	24.7	23.6	18.1	16.1
		MCWBR	10.1	14.2	14.2	15.3	14.3	13.1	12.6	12.2	13.2	14.4	12.9	11.3
	5% WB	MCDBR	13.3	18.9	22.1	23.6	23.3	23.5	24.8	23.9	22.1	21.1	17.1	14.4
		MCWBR	10.0	13.4	13.6	13.9	12.9	12.5	12.0	11.3	12.1	13.5	12.6	10.7
Clear-Sky Solar Irradiance	taub	0.297	0.321	0.354	0.389	0.398	0.403	0.406	0.400	0.377	0.347	0.317	0.292	
	taud	2.451	2.384	2.344	2.273	2.282	2.302	2.286	2.323	2.366	2.443	2.480	2.467	
	Ebn at Noon	248	265	272	273	274	273	270	266	262	252	238	235	
	Edh at Noon	20	27	33	39	40	40	40	37	32	25	20	18	
All-Sky Solar Radiation	RadAvg	341	619	975	1363	1575	1765	1701	1493	1080	686	371	276	
	RadStd	45	83	119	180	181	156	154	150	131	81	49	36	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (86 neighbors)	+0.67	N/A	N/A	N/A	+0.67	+0.68	N/A	N/A	+110	+36	

Nomenclature: See separate page