

PASSAU, Germany

WMO: 108930

Lat: 48.583N

Lon: 13.467E

Elev: 1342

StdP: 14.00

Time Zone: 1.00 (EUC)

Period: 82-92

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.6	11.3	1.7	6.3	9.3	6.5	8.1	14.8	22.2	38.4	18.3	36.0	1.7	40	0.506

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.6	84.4	65.9	81.3	64.9	78.4	63.7	68.2	80.8	66.5	77.8	65.2	75.2	4.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.9	93.3	71.8	62.6	89.1	70.2	61.4	85.4	68.9	33.1	80.7	31.9	78.1	30.7	75.4	73.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.4	12.3	10.4	DB	2.6	90.5	8.6	3.7	-3.6	93.2	-8.6	95.3	-13.5	97.4	-19.7	100.0	
			WB	2.2	71.4	8.5	1.5	-3.9	72.5	-8.9	73.3	-13.6	74.1	-19.8	75.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.3	28.8	30.2	39.2	46.6	55.9	60.0	65.2	64.6	57.7	48.7	37.3	31.7
	DBStd	14.59	9.03	8.35	7.34	6.39	6.77	5.89	5.55	5.93	5.35	6.55	6.06	6.88
	HDD50	2777	658	554	340	141	27	1	0	0	4	103	383	566
	HDD65	6649	1123	974	799	553	287	170	67	81	228	504	832	1031
	CDD50	1779	0	0	6	38	209	302	473	453	233	64	1	0
	CDD65	175	0	0	0	0	4	21	75	68	7	0	0	0
	CDH74	1824	0	0	0	1	66	239	770	666	80	2	0	0
	CDH80	421	0	0	0	0	1	32	204	178	6	0	0	0
Wind	WSAvg	3.6	3.5	3.8	4.2	4.5	4.2	3.6	3.4	3.2	3.1	3.3	3.2	3.3
Precipitation	PrecAvg	37.4	3.0	2.6	2.9	2.0	3.5	3.9	4.3	3.9	3.0	2.6	2.8	3.0
	PrecMax	52.0	6.8	5.7	8.0	4.1	6.0	6.0	7.4	10.4	5.7	6.7	5.7	6.6
	PrecMin	26.1	0.4	0.5	0.6	0.1	0.6	1.4	1.5	0.9	1.1	0.7	0.0	0.8
	PrecStd	5.4	1.7	1.4	2.0	1.0	1.6	1.4	1.6	2.0	1.3	1.5	1.5	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.9	55.8	66.6	72.6	78.9	83.5	89.7	90.3	79.7	72.9	55.3	50.1
		MCWB	43.6	45.8	52.2	55.0	60.3	64.5	68.2	68.1	65.2	60.5	47.4	46.6
	2%	DB	44.7	49.2	59.7	68.2	75.8	80.3	85.2	84.5	76.3	67.8	51.8	46.1
		MCWB	41.7	43.2	48.5	53.7	59.3	63.9	66.5	66.4	63.3	57.4	47.4	43.3
	5%	DB	41.9	44.0	55.0	63.9	72.8	76.6	81.7	81.1	72.9	63.0	48.4	43.7
		MCWB	39.8	39.9	46.0	50.9	57.5	62.5	65.0	65.4	61.9	55.3	44.5	41.8
	10%	DB	39.3	40.3	50.3	59.8	69.6	72.7	78.4	77.5	68.6	58.9	45.5	40.9
		MCWB	37.6	37.4	43.8	49.2	56.3	60.3	64.0	64.2	59.3	53.4	42.5	39.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.5	47.3	53.3	57.5	63.9	67.8	70.7	70.4	66.9	61.6	50.9	46.5
		MCDB	47.3	52.6	64.5	68.6	74.0	78.9	84.6	85.6	76.4	69.1	53.5	49.6
	2%	WB	42.3	43.8	49.5	54.4	60.9	65.7	68.2	68.3	64.9	58.6	48.2	44.0
		MCDB	44.2	48.8	56.5	66.0	71.2	76.2	81.0	81.5	73.8	65.6	51.1	45.7
	5%	WB	40.1	40.5	47.2	52.1	59.0	63.7	66.6	66.5	62.9	56.1	45.2	42.0
		MCDB	41.6	43.8	53.5	61.2	69.2	73.4	78.0	78.1	70.1	61.3	47.4	43.7
	10%	WB	37.7	37.8	44.8	50.0	57.3	61.6	65.1	65.0	60.7	53.9	43.1	39.3
		MCDB	39.4	40.0	49.0	57.9	67.0	70.5	75.4	74.6	66.6	58.3	45.0	40.8
Mean Daily Temperature Range	5% DB	MDBR	9.3	12.7	15.2	17.7	18.9	17.4	19.6	19.1	17.7	15.7	10.1	8.2
		MCDBR	11.7	18.7	24.4	26.4	25.1	24.7	26.7	26.6	24.9	23.0	14.8	11.6
		MCWBR	9.3	12.1	13.3	13.4	11.5	11.3	10.9	11.1	12.6	13.3	10.4	9.3
	5% WB	MCDBR	10.9	17.0	21.6	23.3	21.9	21.9	23.3	23.3	22.1	20.7	13.0	11.2
		MCWBR	9.0	11.7	12.6	12.6	10.4	10.9	10.4	10.5	11.6	12.6	9.6	9.2
Clear-Sky Solar Irradiance	taub	0.298	0.323	0.363	0.397	0.403	0.406	0.415	0.408	0.381	0.351	0.324	0.297	
	taud	2.391	2.345	2.301	2.251	2.269	2.295	2.271	2.307	2.352	2.420	2.450	2.438	
	Ebn at Noon	243	262	268	270	272	272	267	264	259	249	232	229	
	Edh at Noon	21	28	34	40	41	40	41	37	32	26	20	18	
All-Sky Solar Radiation	RadAvg	316	609	947	1371	1596	1760	1696	1487	1061	662	335	239	
	RadStd	53	83	117	175	190	153	160	152	140	74	39	28	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (87 neighbors)	+0.83	N/A	N/A	N/A	+0.67	+0.70	N/A	N/A	+112

Nomenclature: See separate page