

FUERSTENZELL, GermanyWMO: **108950**Lat: **48.5451N**Lon: **13.3532E**Elev: **1574**StdP: **13.88**Time Zone: **1.00 (EUC)**Period: **98-13**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.0	14.9	6.0	7.9	13.3	10.8	10.1	17.6	30.0	45.4	25.4	42.2	4.0	50	0.527

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.8	84.3	66.7	81.1	65.9	78.2	64.6	68.9	79.9	67.4	77.8	65.9	75.7	5.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.1	98.6	73.2	63.7	93.5	71.2	62.5	89.5	69.7	34.0	79.8	32.7	78.1	31.5	75.9	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.5	18.3	15.1	DB	5.1	89.4	4.9	2.5	1.5	91.3	-1.3	92.7	-4.1	94.1	-7.7	96.0	(4)
(5)			WB	4.5	72.0	4.7	1.4	1.1	73.1	-1.7	73.9	-4.3	74.7	-7.7	75.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.8	29.1	31.5	39.5	49.0	57.1	62.3	65.2	64.7	57.1	48.3	38.1	30.5
	DBStd	14.83	8.19	8.00	7.70	7.54	6.82	6.94	6.05	5.75	6.04	6.74	6.92	6.92
	HDD50	2712	649	519	331	107	16	2	0	0	10	113	362	603
	HDD65	6508	1113	939	791	482	259	132	75	78	244	519	808	1068
	CDD50	1904	0	0	6	76	235	373	472	455	223	59	5	0
	CDD65	222	0	0	0	1	13	52	81	67	7	1	0	0
	CDH74	1789	0	0	0	11	121	425	661	523	47	1	0	0
	CDH80	386	0	0	0	1	11	91	168	113	2	0	0	0
Wind	WSAvg	6.3	6.3	7.1	8.3	6.8	6.5	5.9	5.9	5.4	5.6	5.7	5.8	6.1
Precipitation	PrecAvg	37.4	3.0	2.6	2.9	2.0	3.5	3.9	4.3	3.9	3.0	2.6	2.8	3.0
	PrecMax	52.0	6.8	5.7	8.0	4.1	6.0	6.0	7.4	10.4	5.7	6.7	5.7	6.6
	PrecMin	26.1	0.4	0.5	0.6	0.1	0.6	1.4	1.5	0.9	1.1	0.7	0.0	0.8
	PrecStd	5.4	1.7	1.4	2.0	1.0	1.6	1.4	1.6	2.0	1.3	1.5	1.5	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.0	52.3	63.0	75.0	81.5	87.0	89.1	88.2	78.6	70.8	59.9	49.9
		MCWB	47.4	45.3	49.9	56.7	64.0	67.3	68.1	68.5	65.0	60.1	53.0	46.4
	2%	DB	47.1	48.5	59.0	70.4	77.5	82.6	84.4	82.9	74.7	64.6	53.8	44.9
		MCWB	44.4	43.5	48.9	54.9	61.3	66.6	66.7	66.5	62.9	57.4	49.6	42.8
	5%	DB	43.4	45.2	55.2	66.5	73.8	79.1	81.0	79.7	71.4	61.2	50.4	42.0
		MCWB	41.2	41.2	47.0	53.3	59.9	65.3	66.0	65.4	61.5	56.0	47.9	40.4
	10%	DB	40.1	42.1	51.2	62.6	69.8	75.5	77.5	76.4	68.1	57.9	47.1	39.4
		MCWB	38.4	39.1	45.4	51.4	57.9	63.4	65.0	64.1	60.0	54.2	45.6	38.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.3	46.5	52.0	59.0	66.5	70.9	70.8	70.7	67.4	61.9	53.5	46.9
		MCDB	52.0	50.6	59.4	71.1	78.1	81.9	83.3	83.0	75.5	67.8	58.8	49.3
	2%	WB	44.6	44.0	49.7	56.2	63.3	68.3	68.7	68.3	64.2	58.9	50.4	43.1
		MCDB	46.9	48.0	56.7	67.0	73.8	78.9	80.0	78.7	72.0	62.8	52.9	44.6
	5%	WB	41.3	41.4	48.0	54.1	61.1	66.5	67.2	66.6	62.6	56.7	48.1	40.5
		MCDB	43.1	44.6	54.0	64.6	71.0	76.5	77.9	76.8	69.3	60.4	49.9	41.7
	10%	WB	38.5	39.2	45.9	52.0	59.1	64.5	65.7	65.1	60.9	54.6	45.5	38.3
		MCDB	40.1	42.0	50.8	61.1	67.8	73.0	75.3	74.0	66.6	57.5	47.0	39.3
Mean Daily Temperature Range	5% DB	MDBR	7.7	9.5	13.1	16.5	16.7	16.3	16.8	16.4	14.8	12.3	8.0	7.3
		MCDBR	10.9	14.1	20.8	22.7	23.2	22.5	23.3	22.5	20.9	17.1	13.0	10.8
		MCWBR	8.6	10.0	12.2	11.2	11.0	9.4	9.3	9.4	10.7	10.7	9.1	8.8
	5% WB	MCDBR	10.0	13.1	18.3	21.0	20.6	20.4	20.4	20.4	18.0	15.1	12.1	10.2
		MCWBR	8.2	9.8	11.5	11.2	10.3	9.0	9.0	9.4	10.0	10.2	9.1	8.7
Clear-Sky Solar Irradiance	taub	0.295	0.319	0.357	0.389	0.396	0.399	0.407	0.401	0.375	0.346	0.320	0.294	
	taud	2.405	2.360	2.319	2.269	2.284	2.308	2.283	2.320	2.364	2.432	2.462	2.449	
	Ebn at Noon	246	264	271	272	274	274	269	266	261	251	234	232	
	Edh at Noon	21	27	34	39	40	40	40	37	32	25	20	18	
All-Sky Solar Radiation	RadAvg	318	611	950	1372	1597	1762	1699	1488	1062	664	337	240	
	RadStd	53	83	117	175	191	153	160	153	140	74	39	28	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (87 neighbors)	+0.85	N/A	N/A	N/A	N/A	+0.68	+0.67	N/A	N/A	+117

Nomenclature: See separate page