

NEUHAUSEN OB ECK, Germany

WMO: 109210

Lat: 47.983N

Lon: 8.900E

Elev: 804

StdP: 92.03

Time Zone: 1.00 (EUC)

Period: 84-93

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.9	-11.9	-15.9	1.0	-14.2	-13.1	1.3	-10.9	10.8	2.5	9.7	1.9	3.2	70	0.585

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	26.9	17.9	25.1	17.1	23.8	16.4	18.8	25.0	17.7	23.6	16.9	22.5	3.2	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.2	12.7	21.8	15.2	11.9	20.5	14.2	11.2	19.4	56.8	25.3	53.3	23.4	50.3	22.4	22.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.4	6.4	-16.7	30.1	5.1	1.1	-20.5	30.9	-23.5	31.6	-26.4	32.2	-30.1	33.0		
(5)			-16.8	20.8	5.2	1.1	-20.5	21.6	-23.5	22.3	-26.4	22.9	-30.2	23.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.2	-2.1	-1.3	2.8	6.2	10.6	13.2	16.4	16.5	13.0	8.5	2.1	-0.3	(6)
(7)		DBStd	7.69	5.27	4.83	4.38	3.78	4.10	3.51	3.20	3.40	3.34	3.95	3.93	4.16	(7)
(8)		HDD10.0	1739	375	316	225	124	45	9	1	1	9	77	237	319	(8)
(9)		HDD18.3	4108	633	549	481	364	240	157	76	76	161	306	487	578	(9)
(10)		CDD10.0	713	0	0	3	9	63	106	199	202	101	29	1	0	(10)
(11)		CDD18.3	41	0	0	0	0	1	3	17	18	2	0	0	0	(11)
(12)		CDH23.3	393	0	0	0	0	4	32	154	185	16	1	0	0	(12)
(13)		CDH26.7	60	0	0	0	0	0	1	26	33	0	0	0	0	(13)
(14)	Wind	WSAvg	2.8	2.9	3.0	3.2	3.1	3.1	2.9	2.7	2.6	2.7	2.7	2.7	2.7	(14)
(15)	Precipitation	PrecAvg	848	55	52	51	58	91	97	101	84	66	65	62	67	(15)
(16)		PrecMax	1009	144	129	172	121	157	166	185	162	112	125	131	160	(16)
(17)		PrecMin	644	4	12	12	3	25	40	46	24	24	4	1	1	(17)
(18)		PrecStd	103	37	30	34	30	36	30	34	32	25	32	32	37	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.1	13.8	18.9	20.9	24.0	26.2	29.2	29.9	25.8	22.2	13.8	11.0	(19)
(20)			MCWB	7.2	7.7	10.9	11.9	15.4	17.6	18.6	19.2	17.4	14.7	9.8	6.9	(20)
(21)		2%	DB	7.9	9.2	14.2	18.2	21.2	24.0	26.9	27.2	23.2	19.1	11.1	8.9	(21)
(22)			MCWB	5.7	5.7	8.3	10.8	13.8	16.6	18.1	17.6	16.1	13.4	8.2	6.2	(22)
(23)		5%	DB	5.9	7.0	11.8	15.8	19.9	22.0	25.0	25.2	21.6	16.2	9.1	7.0	(23)
(24)			MCWB	4.5	4.4	6.9	9.4	13.2	15.4	17.2	17.1	15.2	12.2	7.3	5.3	(24)
(25)		10%	DB	4.1	4.9	9.1	13.0	17.9	19.9	23.1	23.8	19.2	14.1	7.8	5.2	(25)
(26)			MCWB	3.0	3.5	5.8	8.1	11.9	14.2	16.5	16.4	14.1	11.0	6.4	4.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.6	8.2	10.9	12.4	16.3	19.3	20.4	20.1	18.1	15.1	10.7	8.5	(27)
(28)			MCDWB	9.7	12.9	18.0	19.4	22.0	24.6	26.5	27.4	23.9	20.9	13.5	10.3	(28)
(29)		2%	WB	5.8	6.0	8.7	11.1	14.6	17.2	19.0	18.7	16.7	13.8	8.9	6.5	(29)
(30)			MCDWB	7.1	8.5	13.8	17.5	20.3	22.6	24.8	25.5	22.2	18.4	10.3	8.2	(30)
(31)		5%	WB	4.4	4.7	7.4	9.8	13.5	15.9	17.9	17.6	15.6	12.6	7.5	5.2	(31)
(32)			MCDWB	5.5	6.6	10.9	14.9	18.8	21.3	23.6	23.8	20.3	16.1	8.9	6.5	(32)
(33)		10%	WB	3.0	3.3	6.1	8.5	12.5	14.6	16.9	16.7	14.6	11.3	6.2	3.9	(33)
(34)			MCDWB	3.8	4.8	8.4	12.4	17.2	19.0	22.2	22.6	18.5	14.0	7.4	4.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.2	7.2	8.1	9.0	9.5	10.3	10.7	9.6	8.3	6.5	5.9	(35)	
(36)			MCDBR	8.2	11.1	12.5	13.7	12.6	12.4	13.3	13.8	12.6	12.2	9.4	8.8	(36)
(37)			MCWBR	6.6	7.8	7.7	8.1	7.2	6.6	7.2	6.8	7.0	7.6	7.2	6.6	(37)
(38)		5% WB	MCDWB	7.2	9.4	11.0	12.7	11.3	11.4	11.9	12.5	11.4	11.8	8.4	7.5	(38)
(39)			MCWBR	5.9	7.0	6.9	7.8	6.9	6.4	6.7	6.5	6.6	7.5	6.8	5.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.281	0.304	0.335	0.366	0.377	0.381	0.382	0.377	0.354	0.330	0.302	0.278	(40)	
(41)		taud	2.473	2.416	2.385	2.325	2.326	2.342	2.330	2.362	2.411	2.470	2.502	2.474	(41)	
(42)		Ebn at Noon	810	861	884	885	885	881	874	864	852	818	775	767	(42)	
(43)		Edh at Noon	63	83	100	117	122	121	121	112	97	78	61	56	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.06	1.86	3.06	4.28	5.00	5.72	5.45	4.76	3.54	2.19	1.19	0.86	(44)	
(45)		RadStd	0.13	0.28	0.43	0.61	0.52	0.50	0.49	0.48	0.37	0.23	0.15	0.14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (108 neighbors)		N/A	N/A	N/A	N/A	+0.42	+0.37	N/A	N/A	+51	+11

Nomenclature: See separate page