

FRIEDRICHSHAFEN, Germany

WMO: 109350

Lat: 47.671N

Lon: 9.511E

Elev: 417

StdP: 96.42

Time Zone: 1.00 (EUC)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.2	-7.0	-13.2	1.3	-7.3	-10.0	1.7	-5.8	11.3	6.4	10.1	5.1	3.5	30	0.498

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	31.0	20.1	29.0	19.2	27.1	18.8	21.2	28.2	20.2	26.7	19.4	25.7	2.8	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	14.4	24.7	18.0	13.6	22.9	17.1	12.8	22.0	63.4	28.2	60.2	27.0	57.2	25.5	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	7.3	6.2	-11.7	34.0	2.3	1.2	-13.4	34.8	-14.7	35.5	-16.0	36.2	-17.7	37.0		
(5)			-12.1	22.9	2.4	1.1	-13.8	23.7	-15.2	24.4	-16.5	25.0	-18.2	25.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.1	0.8	1.1	5.8	10.2	13.7	18.0	19.7	19.1	14.8	10.3	5.5	1.9	(6)
(7)		DBStd	7.61	3.75	4.32	3.65	3.85	3.65	3.54	3.14	3.16	2.90	3.37	3.36	3.53	(7)
(8)		HDD10.0	1152	284	250	134	45	9	0	0	0	1	38	140	251	(8)
(9)		HDD18.3	3159	542	483	388	246	147	48	22	29	111	248	385	509	(9)
(10)		CDD10.0	1203	1	0	4	50	124	241	301	283	146	49	5	0	(10)
(11)		CDD18.3	169	0	0	0	1	4	40	65	54	6	0	0	0	(11)
(12)		CDH23.3	1629	0	0	0	13	68	411	621	468	46	2	0	0	(12)
(13)		CDH26.7	488	0	0	0	2	9	127	208	140	2	0	0	0	(13)
(14)	Wind	WSAvg	2.4	2.6	2.6	2.9	2.5	2.5	2.3	2.3	2.0	2.2	2.1	2.3	2.3	(14)
(15)	Precipitation	PrecAvg	995	57	58	58	80	99	124	118	124	76	63	80	57	(15)
(16)		PrecMax	1235	113	161	122	162	178	202	238	304	240	133	212	126	(16)
(17)		PrecMin	786	18	8	14	26	32	53	52	54	21	12	20	4	(17)
(18)		PrecStd	115	25	34	30	32	41	44	51	59	54	37	47	32	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.9	14.1	19.2	25.0	27.9	32.2	34.0	32.8	26.9	22.0	18.2	12.9	(19)
(20)			MCWB	8.6	7.9	10.5	14.1	16.7	21.2	20.1	19.9	18.9	14.3	10.8	9.2	(20)
(21)		2%	DB	9.2	11.1	17.0	22.8	25.1	30.0	31.1	30.1	24.9	19.2	14.9	10.2	(21)
(22)			MCWB	7.0	6.6	9.4	12.9	15.8	19.1	20.1	20.5	18.3	14.3	10.9	7.5	(22)
(23)		5%	DB	7.2	9.1	14.8	20.8	23.1	27.9	29.0	28.1	22.8	17.2	12.2	8.2	(23)
(24)			MCWB	5.6	5.8	8.5	12.4	14.9	18.5	19.1	19.7	17.1	13.3	9.7	6.4	(24)
(25)		10%	DB	6.0	7.0	12.2	18.1	21.1	25.2	27.0	26.0	20.8	15.8	10.8	7.0	(25)
(26)			MCWB	4.6	4.4	7.4	11.2	14.3	17.5	18.7	19.2	16.2	12.9	8.7	5.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	9.3	11.5	15.0	18.5	22.8	21.7	22.5	19.8	15.9	12.0	9.3	(27)
(28)			MCDWB	11.1	12.7	17.2	22.8	25.7	30.7	29.6	29.0	25.1	20.3	15.9	11.5	(28)
(29)		2%	WB	7.1	7.2	9.9	13.7	17.0	20.6	21.0	21.3	18.6	14.7	10.7	8.0	(29)
(30)			MCDWB	8.7	10.5	15.7	20.5	22.9	27.6	28.6	27.6	23.6	18.3	14.1	10.0	(30)
(31)		5%	WB	5.7	5.9	9.0	12.5	15.7	19.3	20.0	20.3	17.5	13.9	9.9	6.7	(31)
(32)			MCDWB	6.9	8.6	13.5	19.5	21.7	26.0	27.0	26.2	21.8	16.9	12.5	8.3	(32)
(33)		10%	WB	4.4	4.6	7.9	11.5	14.5	18.2	19.1	19.5	16.4	13.0	8.8	5.4	(33)
(34)			MCDWB	5.6	6.7	11.8	17.7	19.9	24.6	25.8	25.0	20.0	15.6	10.6	6.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.5	7.0	9.7	11.0	10.2	10.4	10.8	9.6	8.5	6.0	5.6	(35)	
(36)			MCDBR	7.8	11.5	14.6	15.6	14.5	15.1	15.4	14.6	12.6	11.3	9.6	7.9	(36)
(37)			MCWBR	6.0	7.6	8.0	7.9	6.8	6.6	6.0	6.3	6.6	6.9	6.2	5.8	(37)
(38)		5% WB	MCDWB	7.4	10.6	13.2	14.8	12.9	13.7	13.8	13.1	11.8	10.5	9.0	7.3	(38)
(39)			MCWBR	5.8	7.2	7.5	7.7	6.2	6.3	5.8	6.3	6.5	6.8	6.1	5.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.292	0.317	0.354	0.392	0.405	0.411	0.413	0.406	0.378	0.348	0.316	0.288	(40)	
(41)		taud	2.430	2.361	2.337	2.266	2.274	2.296	2.286	2.323	2.378	2.452	2.484	2.443	(41)	
(42)		Ebn at Noon	794	843	862	858	859	854	846	836	826	799	758	752	(42)	
(43)		Edh at Noon	66	88	106	125	129	127	127	117	101	80	63	58	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.11	1.93	3.14	4.31	5.00	5.73	5.50	4.80	3.59	2.24	1.23	0.91	(44)	
(45)		RadStd	0.12	0.27	0.42	0.61	0.51	0.52	0.50	0.49	0.37	0.24	0.15	0.14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (110 neighbors)	N/A	N/A	N/A	N/A	+0.43	+0.37	N/A	N/A	+54	+14

Nomenclature: See separate page