

HOHENPEISSENBERG, Germany

WMO: 109620

Lat: 47.8008N

Lon: 11.0108E

Elev: 3233

StdP: 13.06

Time Zone: 1.00 (EUC)

Period: 82-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.4	11.6	2.1	6.9	10.7	7.4	9.0	18.5	43.1	40.0	36.7	36.7	7.3	70	0.644

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.5	77.9	62.7	74.6	61.2	72.0	60.2	64.1	74.5	62.7	72.4	61.2	70.1	7.0	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.3	88.2	68.7	58.9	83.6	67.1	57.5	79.5	65.3	31.1	74.5	30.0	72.7	28.9	70.3	69.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.4	26.8	22.9	DB	5.0	83.5	7.2	3.6	-0.1	86.1	-4.3	88.2	-8.3	90.2	-13.5	92.8	(4)
(5)			WB	4.6	67.5	7.2	1.3	-0.6	68.4	-4.8	69.2	-8.8	70.0	-14.0	70.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	45.0	30.4	29.7	36.2	41.4	50.4	55.9	61.3	60.5	55.1	47.3	37.6	33.0	(6)
(7)		DBStd	13.89	9.81	10.41	8.71	7.98	7.72	7.51	6.77	6.74	7.07	8.05	8.83	9.02	(7)
(8)		HDD50	3104	608	569	436	276	94	27	3	6	29	147	379	530	(8)
(9)		HDD65	7388	1073	987	894	707	452	284	153	169	305	549	823	992	(9)
(10)		CDD50	1277	0	2	7	18	108	204	353	331	181	64	6	3	(10)
(11)		CDD65	86	0	0	0	0	0	11	38	29	7	1	0	0	(11)
(12)		CDH74	337	0	0	0	0	1	35	173	116	12	0	0	0	(12)
(13)		CDH80	40	0	0	0	0	0	5	29	6	0	0	0	0	(13)
(14)	Wind	WSAvg	9.6	12.0	10.3	11.0	9.7	8.8	9.1	8.0	8.2	8.9	8.8	10.0	11.1	(14)
(15)	Precipitation	PrecAvg	47.0	2.5	2.2	2.7	3.1	5.7	6.1	6.0	6.4	4.1	2.9	2.5	2.8	(15)
(16)		PrecMax	60.2	5.6	6.5	5.9	8.2	13.8	10.1	13.7	10.9	8.7	5.9	5.3	5.0	(16)
(17)		PrecMin	38.0	0.1	0.5	1.2	0.7	1.7	2.7	1.1	1.8	1.3	0.2	0.0	0.2	(17)
(18)		PrecStd	6.1	1.3	1.2	1.1	1.7	2.5	2.0	2.6	2.4	1.7	1.3	1.2	1.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.6	54.8	62.1	65.5	71.6	78.0	82.9	80.7	75.5	69.5	58.9	59.9	(19)
(20)			MCWB	40.5	43.4	47.9	50.1	57.4	63.4	63.4	63.4	60.3	55.2	46.3	44.4	(20)
(21)		2%	DB	48.4	50.2	56.1	61.1	67.6	73.9	78.7	77.5	71.6	65.4	55.0	53.0	(21)
(22)			MCWB	39.1	40.8	44.8	48.1	54.3	60.5	62.8	63.0	58.9	53.2	44.2	40.9	(22)
(23)		5%	DB	45.0	46.8	51.9	57.4	64.4	70.6	74.9	74.1	68.5	62.4	52.5	48.7	(23)
(24)			MCWB	37.3	38.7	42.1	46.2	53.1	59.4	61.6	61.2	57.8	51.7	43.1	39.6	(24)
(25)		10%	DB	42.5	43.2	47.8	54.1	61.5	67.6	71.9	71.2	65.5	58.9	49.6	45.0	(25)
(26)			MCWB	36.3	36.3	40.1	44.4	52.0	57.8	60.7	60.4	56.4	50.6	42.3	38.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.2	44.8	48.5	51.5	59.7	64.5	66.2	66.0	62.8	57.5	48.9	46.1	(27)
(28)			MCDWB	47.5	53.1	60.7	62.0	69.2	73.9	77.2	77.4	71.0	66.1	53.8	55.3	(28)
(29)		2%	WB	41.1	42.3	45.5	49.3	56.2	62.2	64.3	64.0	60.5	55.3	46.7	43.4	(29)
(30)			MCDWB	46.3	48.2	54.6	59.0	64.2	71.1	75.1	74.4	68.3	62.4	51.9	50.2	(30)
(31)		5%	WB	38.9	39.7	43.2	47.2	54.4	60.5	62.9	62.4	58.8	53.1	44.9	41.6	(31)
(32)			MCDWB	43.0	45.2	50.3	55.5	61.9	69.1	72.8	72.3	66.2	59.6	50.0	46.9	(32)
(33)		10%	WB	37.1	37.4	41.3	45.4	52.8	58.5	61.4	60.9	57.2	51.2	43.1	39.3	(33)
(34)			MCDWB	41.2	41.8	46.7	52.6	60.2	66.5	70.4	69.7	64.1	57.3	48.3	43.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.1	9.0	10.5	12.4	13.2	13.5	13.0	11.6	9.9	8.8	8.7	(35)	
(36)			MCDBR	11.7	12.1	14.3	17.5	16.8	16.7	16.8	17.0	14.6	12.7	12.5	12.7	(36)
(37)			MCWBR	6.6	7.2	8.4	9.7	9.4	9.1	8.8	9.2	8.5	8.3	7.2	7.0	(37)
(38)		5% WB	MCDWB	11.0	11.8	13.1	16.1	14.9	15.8	15.4	15.3	13.2	11.9	11.5	11.8	(38)
(39)			MCWBR	7.3	8.0	8.2	9.3	9.1	9.0	8.7	9.1	8.2	8.1	8.0	7.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.264	0.285	0.317	0.352	0.363	0.369	0.370	0.364	0.340	0.311	0.285	0.261	(40)	
(41)		taud	2.475	2.427	2.420	2.368	2.375	2.385	2.372	2.406	2.456	2.530	2.544	2.499	(41)	
(42)		Ebn at Noon	266	281	287	286	285	283	281	278	276	269	255	253	(42)	
(43)		Edh at Noon	20	26	31	36	37	37	37	34	30	23	19	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	384	672	1015	1355	1541	1727	1691	1494	1096	732	410	315	(44)	
(45)		RadStd	48	87	117	178	178	168	161	158	134	83	58	43	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (95 neighbors)		N/A	N/A	N/A	N/A	+0.76	+0.72	N/A	N/A	+106	+32

Nomenclature: See separate page