

WOLFSEGG, Austria

WMO: 110010

Lat: 48.106N

Lon: 13.671E

Elev: 2020

StdP: 13.65

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.1	16.3	8.3	9.0	14.9	12.1	11.0	17.9	32.3	42.2	27.9	38.6	6.7	80	0.518

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.8	82.5	67.3	79.1	66.0	76.5	64.6	68.5	79.7	67.0	77.4	65.4	74.9	5.0	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.4	97.8	74.4	62.9	92.4	72.3	61.6	88.3	71.0	33.9	80.0	32.6	77.8	31.4	75.2	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.8	20.0	16.8	DB	10.0	86.8	5.2	2.8	6.2	88.8	3.2	90.5	0.3	92.0	-3.5	94.1	(4)
(5)			WB	8.8	71.6	4.6	2.2	5.5	73.2	2.9	74.5	0.3	75.8	-3.0	77.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.9	29.5	33.1	39.8	48.6	55.5	61.9	65.1	64.6	56.7	48.3	38.5	33.0		
	DBStd	14.52	8.51	8.85	8.44	7.97	7.30	7.55	6.68	6.42	6.38	7.56	7.36	7.69		
	HDD50	2612	634	476	329	120	30	5	0	0	13	124	352	529		
	HDD65	6458	1099	894	782	494	306	147	83	88	259	518	795	993		
	CDD50	1861	0	2	12	76	200	361	468	451	213	71	7	0		
	CDD65	233	0	0	0	1	10	53	86	74	9	0	0	0		
	CDH74	1198	0	0	0	3	36	289	465	384	21	0	0	0		
	CDH80	216	0	0	0	0	1	48	84	81	2	0	0	0		
(14) Wind	WSAvg	7.3	9.3	9.4	9.1	7.5	6.6	5.7	5.9	5.8	6.0	6.8	7.3	7.9		
(15) Precipitation	PrecAvg	40.4	2.5	2.3	3.0	2.5	4.1	5.0	5.0	4.7	3.5	2.8	2.5	2.6		
	PrecMax	51.1	5.0	5.1	5.5	6.3	7.9	11.7	10.5	12.0	7.3	5.4	6.1	4.8		
	PrecMin	28.9	0.4	0.4	0.3	0.2	1.2	2.0	1.1	1.3	1.0	0.6	0.0	0.4		
	PrecStd	4.9	1.4	1.2	1.6	1.4	1.7	2.0	2.0	1.9	1.5	1.2	1.3	1.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.2	56.4	62.3	72.1	78.1	84.7	86.3	87.3	76.5	68.8	60.8	53.1		
		MCWB	44.6	45.4	50.4	57.3	64.1	69.0	68.7	67.6	64.6	58.3	51.9	45.7		
	2%	DB	48.1	51.3	58.6	67.4	74.3	80.8	82.2	81.8	72.7	64.7	56.0	49.3		
		MCWB	43.2	44.6	48.4	55.0	61.8	67.2	66.9	66.8	63.3	56.7	49.3	43.6		
	5%	DB	44.8	48.0	55.1	63.9	70.9	77.2	78.8	77.9	69.4	61.1	52.3	46.5		
		MCWB	40.5	42.4	46.6	52.7	59.8	64.8	65.8	65.7	61.3	55.0	47.8	42.0		
	10%	DB	41.3	45.0	51.6	60.6	67.4	74.0	76.1	75.0	66.4	58.4	48.8	43.7		
		MCWB	38.1	40.4	44.7	51.0	57.6	63.2	64.5	64.3	59.6	53.5	45.6	40.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.5	48.1	51.8	58.5	66.0	71.1	70.6	70.2	66.3	60.2	53.0	46.9		
		MCDB	50.2	53.4	60.2	69.6	75.7	81.7	82.0	82.1	74.1	66.3	58.9	50.7		
	2%	WB	43.5	45.1	49.2	55.8	62.8	68.2	68.2	68.0	64.1	57.8	50.2	44.8		
		MCDB	47.4	50.1	56.6	66.2	72.6	79.3	79.4	79.0	71.9	62.6	54.5	48.4		
	5%	WB	41.1	42.9	47.4	53.5	60.4	65.9	66.8	66.3	62.1	55.8	48.1	42.6		
		MCDB	44.5	47.5	53.7	62.7	69.4	75.9	77.4	76.3	68.3	60.0	51.9	45.9		
	10%	WB	38.5	40.6	45.4	51.4	58.4	63.9	65.2	64.8	60.3	54.1	45.7	40.2		
		MCDB	41.3	44.5	50.7	59.4	66.5	72.5	74.5	73.8	65.6	58.0	48.7	43.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.6	7.9	10.4	12.6	12.9	12.6	12.8	12.4	10.6	9.2	6.9	7.0		
		MCDBR	10.2	11.7	15.1	16.6	17.3	17.0	16.4	16.6	14.1	12.4	11.9	11.4		
	5% WB	MCWBR	7.0	7.7	9.3	9.1	9.6	8.9	7.7	7.9	7.8	7.9	8.0	8.1		
		MCWBR	9.8	11.0	13.9	16.0	16.4	16.0	15.7	15.6	13.2	11.1	10.6	11.0		
(40) Clear-Sky Solar Irradiance	taub		0.288	0.312	0.350	0.381	0.390	0.394	0.400	0.393	0.368	0.339	0.313	0.287		
		taud	2.423	2.366	2.334	2.297	2.306	2.328	2.308	2.345	2.393	2.462	2.487	2.461		
	Ebn at Noon		252	268	274	275	277	276	272	269	265	256	240	238		
		Edh at Noon	21	28	33	38	39	39	39	36	31	25	20	18		
(44) All-Sky Solar Radiation	RadAvg		351	645	972	1343	1551	1708	1680	1485	1068	701	371	276		
	RadStd		51	84	117	167	184	159	161	163	141	75	50	37		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (99 neighbors)		+0.86	N/A	N/A	N/A	+0.72	+0.65	N/A	N/A	+122	+54

Nomenclature: See separate page