

ROHRBACH, Austria

WMO: 110080

Lat: 48.570N

Lon: 13.994E

Elev: 602

StdP: 94.29

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.9	-9.6	-14.6	1.1	-11.0	-12.2	1.4	-8.3	7.1	3.1	6.2	2.3	1.2	20	0.489

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	29.3	19.7	27.4	19.1	25.7	18.1	20.6	27.4	19.6	26.0	18.7	24.5	2.2	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.2	14.1	23.4	17.3	13.3	22.2	16.6	12.7	21.4	61.9	27.5	58.5	26.1	55.6	24.5	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.5	4.9	4.3	-14.6	32.1	3.3	1.3	-17.0	33.0	-18.9	33.8	-20.7	34.6	-23.1	35.5
			-14.9	22.3	3.0	1.0	-17.1	23.1	-18.9	23.7	-20.5	24.2	-22.7	25.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.5	-1.9	-0.3	3.6	9.1	13.2	16.7	18.1	18.0	13.5	8.7	3.3	-0.3		
	DBStd	8.12	4.23	4.20	4.13	4.31	3.90	3.88	3.47	3.44	3.42	3.73	3.80	3.76		
	HDD10.0	1537	368	289	199	67	14	2	0	0	7	69	203	319		
	HDD18.3	3694	627	522	457	278	164	75	48	48	150	298	451	578		
	CDD10.0	1001	0	0	1	39	114	204	252	249	111	29	2	0		
	CDD18.3	117	0	0	0	1	5	27	41	39	4	0	0	0		
	CDH23.3	1006	0	0	0	6	55	242	343	329	31	0	0	0		
	CDH26.7	232	0	0	0	0	6	56	84	83	3	0	0	0		
(14) Wind	WSAvg	1.8	1.9	1.9	1.9	2.0	1.9	1.8	1.7	1.6	1.6	1.7	1.5	1.6		
(15) Precipitation	PrecAvg	1031	84	75	85	58	93	102	120	106	78	74	74	83		
	PrecMax	1538	197	177	218	109	169	201	251	383	182	184	179	196		
	PrecMin	758	10	13	18	4	15	48	30	25	25	16	0	28		
	PrecStd	164	52	43	56	26	42	39	53	65	39	47	41	43		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.5	11.6	17.1	23.9	27.5	30.6	31.5	31.6	26.2	21.4	15.4	9.6		
		MCWB	7.1	6.4	9.9	14.2	18.4	20.4	20.7	19.7	17.9	14.6	10.8	7.4		
	2%	DB	7.1	8.9	14.8	21.1	24.9	28.4	28.9	29.0	23.9	18.6	12.8	7.6		
		MCWB	5.4	5.9	9.0	13.1	16.8	19.7	19.8	19.3	17.1	13.5	9.6	6.2		
	5%	DB	5.3	7.2	12.3	18.9	22.8	26.2	27.0	26.8	21.6	16.3	10.7	6.2		
		MCWB	4.0	4.7	7.6	11.9	15.6	18.3	19.1	18.8	15.8	12.6	8.5	4.9		
	10%	DB	3.6	5.3	10.0	16.8	20.6	24.1	25.1	24.9	19.7	14.4	8.8	4.6		
		MCWB	2.6	3.3	6.7	10.9	14.4	17.3	18.1	18.0	15.1	11.7	7.2	3.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.7	7.6	10.7	15.0	19.2	21.5	22.1	21.5	18.9	15.5	11.4	8.0		
		MCDB	9.2	10.1	16.1	22.7	25.6	28.9	29.1	28.5	24.4	19.5	14.3	9.1		
	2%	WB	5.5	6.2	9.4	13.6	17.5	20.0	20.6	20.2	17.5	14.2	10.0	6.6		
		MCDB	6.8	8.5	13.6	20.2	23.6	26.9	27.3	27.0	22.8	17.4	12.4	7.6		
	5%	WB	4.1	4.8	8.2	12.4	16.2	18.9	19.6	19.3	16.4	13.0	8.7	5.0		
		MCDB	5.2	7.0	11.6	18.2	21.9	25.0	25.8	25.5	20.8	15.6	10.5	6.1		
	10%	WB	2.7	3.5	7.0	11.2	14.9	17.9	18.7	18.3	15.4	12.0	7.2	3.6		
		MCDB	3.6	5.2	9.6	16.3	19.8	23.1	24.0	24.1	18.9	14.3	8.7	4.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.7	5.9	7.5	9.2	9.0	9.2	9.2	9.3	8.3	7.5	5.4	4.6		
		MCDBR	6.1	9.3	12.4	12.9	13.2	12.9	12.7	13.0	11.6	10.8	9.2	6.7		
	5% WB	MCWBR	4.7	6.3	7.3	6.7	6.2	5.6	5.4	5.5	5.7	6.5	6.2	5.4		
		MCWBR	5.8	8.7	11.2	12.2	12.0	11.8	11.6	12.0	10.6	9.8	8.4	6.5		
(40) Clear-Sky Solar Irradiance	taub		0.288	0.312	0.352	0.386	0.392	0.394	0.403	0.396	0.370	0.341	0.315	0.288		
		taud	2.394	2.358	2.320	2.277	2.296	2.319	2.294	2.328	2.374	2.440	2.466	2.447		
	Ebn at Noon		782	841	859	862	870	868	853	842	830	797	744	738		
		Edh at Noon	66	86	106	123	125	123	125	116	100	80	63	56		
(44) All-Sky Solar Radiation	RadAvg		0.99	1.90	2.96	4.32	5.01	5.50	5.30	4.69	3.34	2.08	1.05	0.77		
	RadStd		0.16	0.26	0.38	0.54	0.59	0.48	0.51	0.48	0.44	0.24	0.12	0.09		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (97 neighbors)		+0.50	N/A	N/A	N/A	+0.40	+0.36	N/A	N/A	+66	+28

Nomenclature: See separate page