

KREMSMUNSTER, Austria

WMO: 110120

Lat: **48.0550N**Lon: **14.1311E**Elev: **1278**StdP: **14.03**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.0	16.3	8.6	9.0	13.3	13.3	11.3	18.5	27.0	40.4	24.5	40.2	5.9	230	0.533

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.0	86.8	69.3	83.3	67.9	80.4	66.6	71.3	83.4	69.5	81.3	67.8	79.0	6.2	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.3	105.2	77.7	65.2	97.8	75.4	63.7	92.4	73.6	35.9	83.4	34.3	81.3	32.9	79.3	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.0	19.1	16.7	8.4	92.8	5.9	3.0	4.1	94.9	0.7	96.7	-2.7	98.4	-6.9	100.5		
(5)			DB	7.5	74.2	5.6	1.6	3.5	75.4	0.3	76.3	-2.9	77.3	-6.9	78.4	(5)
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.9	30.6	34.1	41.8	51.1	58.5	64.7	67.8	67.3	59.0	49.9	40.2	33.2		
	DBStd	14.91	8.34	8.23	7.59	7.78	6.65	6.76	5.98	6.18	5.94	6.68	6.90	7.47		
	HDD50	2322	603	446	269	81	8	1	0	0	4	86	302	522		
	HDD65	5857	1067	864	720	420	219	87	41	46	196	467	743	987		
	CDD50	2300	1	1	14	113	273	443	553	536	273	84	9	0		
	CDD65	362	0	0	0	2	19	79	129	118	15	0	0	0		
	CDH74	2707	0	0	0	27	158	599	968	861	92	2	0	0		
	CDH80	743	0	0	0	2	20	152	292	266	11	0	0	0		
(14) Wind	WSAvg	7.6	8.4	8.3	8.8	7.9	7.7	7.0	7.3	6.8	6.9	7.0	7.1	7.6		
(15) Precipitation	PrecAvg	37.6	2.3	2.3	2.5	3.0	3.9	4.5	5.0	4.7	2.9	2.3	2.8	2.4		
	PrecMax	52.9	4.4	5.9	5.4	7.2	8.5	6.9	9.2	14.1	4.5	7.2	6.0	5.1		
	PrecMin	28.2	0.2	0.2	0.6	1.0	1.5	2.0	1.7	1.2	1.1	0.1	1.0	0.4		
	PrecStd	6.6	1.3	1.4	1.1	1.7	1.8	1.5	1.9	2.6	0.9	1.7	1.3	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.5	57.0	66.2	77.6	82.7	88.5	91.6	92.2	81.1	71.6	62.2	53.7		
		MCWB	47.7	47.4	53.4	60.1	65.5	70.8	69.4	69.5	67.1	60.4	52.9	47.4		
	2%	DB	49.7	52.0	61.1	72.3	78.5	84.6	86.7	86.4	76.5	66.0	56.7	49.4		
		MCWB	44.9	45.5	50.8	57.6	63.7	69.0	69.0	69.0	64.8	58.3	51.1	45.3		
	5%	DB	45.4	48.3	56.8	68.2	74.7	80.9	82.9	82.4	72.5	62.4	52.8	45.9		
		MCWB	41.7	43.1	48.5	56.0	61.6	66.9	67.6	68.1	63.2	56.6	49.4	42.4		
	10%	DB	41.8	44.9	52.9	64.2	70.8	77.2	79.5	78.8	68.9	59.4	49.5	42.8		
		MCWB	39.0	40.8	46.4	53.7	59.5	65.1	66.4	66.9	61.3	55.0	46.5	40.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.2	48.9	55.4	61.7	67.3	73.4	73.6	74.3	68.9	62.1	54.4	48.8		
		MCDB	53.4	55.5	61.6	73.8	79.2	85.3	84.7	83.5	78.5	68.9	59.4	52.5		
	2%	WB	45.2	45.8	51.7	58.9	64.7	70.5	70.5	71.3	65.8	59.3	51.9	45.9		
		MCDB	49.7	51.6	59.7	70.6	75.9	82.8	82.7	83.4	74.6	64.5	56.1	49.2		
	5%	WB	42.3	43.6	49.4	56.5	62.4	68.4	68.9	69.3	63.8	57.1	49.6	43.2		
		MCDB	45.6	48.3	56.1	66.8	72.9	79.6	80.5	81.2	71.2	61.7	53.5	46.1		
	10%	WB	39.5	41.1	47.1	54.2	60.3	66.2	67.2	67.5	61.8	55.2	46.9	40.6		
		MCDB	42.1	44.8	52.6	62.5	69.6	75.8	77.7	78.8	67.9	59.3	49.5	43.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.6	10.2	13.6	16.7	16.4	16.3	17.0	17.0	15.0	12.3	8.2	7.3		
		MCDBR	11.6	16.1	21.4	24.6	23.7	23.0	23.6	23.9	21.3	17.0	13.7	12.4		
		MCWBR	8.7	11.0	12.8	13.1	11.6	10.6	9.6	10.3	11.2	10.5	9.5	9.4		
		MCDBR	11.5	15.1	20.0	22.5	22.2	22.3	21.8	22.6	19.8	16.4	13.0	12.4		
	5% WB	MCWBR	8.8	10.5	12.6	12.8	11.3	11.0	10.0	11.0	11.1	10.3	9.2	9.6		
(40) Clear-Sky Solar Irradiance	taub		0.295	0.321	0.361	0.395	0.404	0.409	0.415	0.408	0.380	0.349	0.322	0.294		
	taud		2.409	2.352	2.310	2.266	2.279	2.303	2.287	2.323	2.374	2.445	2.472	2.453		
	Ebn at Noon		248	265	270	271	272	271	267	264	261	252	236	234		
	Edh at Noon		21	28	34	40	41	40	40	37	32	25	20	18		
(44) All-Sky Solar Radiation	RadAvg		349	634	964	1340	1548	1697	1668	1483	1066	699	372	279		
	RadStd		48	82	116	160	181	150	159	161	139	74	48	36		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	+1.17	N/A	N/A	+1.49	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (102 neighbors)	+0.92	N/A	N/A	N/A	+0.72	+0.61	N/A	-252	+130	+58

Nomenclature: See separate page