

AMSTETTEN, Austria

WMO: 110180

Lat: 48.109N

Lon: 14.895E

Elev: 867

StdP: 14.24

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.4	17.1	7.0	8.1	12.3	12.7	10.8	18.8	18.9	40.8	17.0	39.3	4.1	280	0.476

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.1	88.1	69.9	84.5	68.6	81.4	67.1	71.5	84.3	69.8	81.5	68.3	78.9	5.0	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.4	104.2	76.2	65.9	98.7	74.6	64.6	94.1	73.2	35.8	84.4	34.3	81.7	33.1	79.2	78.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.7	13.7	12.0	DB	6.6	94.1	7.4	2.6	1.3	96.0	-3.1	97.5	-7.2	99.0	-12.6	100.9	(4)
(5)			WB	6.1	75.4	7.1	1.6	1.0	76.5	-3.1	77.5	-7.1	78.4	-12.2	79.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	50.3	31.0	34.6	41.8	51.1	58.9	65.5	68.0	67.4	58.9	50.1	41.1	33.5	(6)
(7)		DBStd	14.73	7.92	7.60	7.25	7.09	6.56	6.61	5.87	5.75	5.93	6.62	6.80	7.42	(7)
(8)		HDD50	2238	589	433	264	71	7	1	0	0	4	82	275	512	(8)
(9)		HDD65	5754	1054	852	719	418	208	74	36	41	198	461	716	977	(9)
(10)		CDD50	2329	1	0	10	105	284	465	559	539	270	86	10	0	(10)
(11)		CDD65	371	0	0	0	1	20	89	131	116	14	0	0	0	(11)
(12)		CDH74	3349	0	0	0	40	220	781	1170	1013	122	3	0	0	(12)
(13)		CDH80	995	0	0	0	4	34	224	381	335	17	0	0	0	(13)
(14)	Wind	WSAvg	5.1	6.2	5.8	5.9	5.3	5.0	4.4	4.5	4.1	4.2	4.9	5.7	5.9	(14)
(15)	Precipitation	PrecAvg	40.9	2.5	2.4	3.2	2.6	4.2	4.5	5.0	4.5	3.7	2.7	2.7	2.6	(15)
(16)		PrecMax	52.2	5.0	6.1	5.7	6.1	9.4	11.1	9.9	13.8	8.7	5.9	4.6	4.6	(16)
(17)		PrecMin	29.1	0.2	0.6	1.1	0.3	0.9	1.6	2.0	1.2	1.6	0.3	0.2	0.8	(17)
(18)		PrecStd	5.6	1.3	1.4	1.3	1.3	2.0	1.9	2.2	2.5	1.7	1.5	1.1	1.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.3	56.3	67.2	78.9	83.7	89.9	92.9	93.5	82.1	72.2	63.3	53.1	(19)
(20)			MCWB	47.9	47.8	53.4	61.0	65.9	71.0	71.1	69.3	67.6	60.7	54.5	48.0	(20)
(21)		2%	DB	48.7	52.3	61.8	73.0	79.8	85.8	87.9	87.6	77.6	66.6	57.8	48.0	(21)
(22)			MCWB	44.7	46.1	50.9	57.8	65.0	69.5	70.0	69.4	65.4	58.4	52.1	44.4	(22)
(23)		5%	DB	44.8	48.3	57.5	69.0	76.0	82.0	84.1	83.4	73.6	63.2	53.8	44.9	(23)
(24)			MCWB	41.5	43.3	48.6	55.6	62.8	67.0	68.4	68.6	63.7	57.1	50.2	42.4	(24)
(25)		10%	DB	41.3	44.9	53.2	65.0	72.2	78.4	80.6	79.7	69.6	59.9	50.2	42.2	(25)
(26)			MCWB	39.1	41.2	46.6	53.7	60.6	65.6	67.1	67.0	61.5	55.7	47.6	40.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.9	49.5	54.6	62.0	68.4	73.5	73.8	73.5	69.0	62.6	55.5	48.4	(27)
(28)			MCDWB	53.6	55.0	64.9	76.1	80.2	85.3	86.6	86.6	78.7	68.4	62.0	51.7	(28)
(29)		2%	WB	44.9	46.4	51.6	58.7	65.9	70.7	71.4	71.1	66.5	59.7	52.9	45.3	(29)
(30)			MCDWB	48.4	51.6	59.9	70.9	77.2	83.1	84.1	83.4	75.7	64.6	57.1	47.7	(30)
(31)		5%	WB	42.0	43.8	49.6	56.5	63.8	68.6	69.7	69.3	64.5	58.0	50.1	42.5	(31)
(32)			MCDWB	44.5	47.8	56.0	67.2	74.2	79.3	81.4	80.5	71.8	62.1	53.4	44.7	(32)
(33)		10%	WB	39.2	41.4	47.5	54.5	61.7	66.7	68.2	67.8	62.5	56.0	47.7	40.4	(33)
(34)			MCDWB	41.1	44.7	52.6	63.6	70.5	76.0	78.4	78.1	68.1	59.8	50.1	42.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.4	11.5	15.4	19.1	18.2	18.5	19.1	19.4	16.5	13.7	9.0	7.9	(35)
(36)			MCDBR	12.7	18.7	25.0	28.0	25.8	25.6	26.2	26.9	23.4	19.5	15.6	12.8	(36)
(37)			MCWBR	9.2	12.4	14.2	13.8	12.0	10.6	10.1	10.9	11.9	11.7	10.0	9.7	(37)
(38)		5% WB	MCDWB	12.5	17.8	23.0	25.8	24.2	23.7	23.8	24.6	21.4	17.6	14.4	12.2	(38)
(39)			MCWBR	9.4	12.2	13.6	13.2	11.6	10.6	9.8	10.9	11.4	11.1	9.8	9.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.306	0.335	0.379	0.420	0.426	0.430	0.437	0.431	0.401	0.366	0.336	0.306	(40)	
(41)		taud	2.371	2.308	2.248	2.190	2.221	2.248	2.234	2.266	2.315	2.390	2.420	2.416	(41)	
(42)		Ebn at Noon	241	258	263	263	266	265	261	257	253	244	228	227	(42)	
(43)		Edh at Noon	22	29	36	43	43	42	42	39	34	27	21	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	341	620	952	1343	1554	1698	1661	1483	1064	690	365	275	(44)	
(45)		RadStd	46	79	115	156	179	144	158	158	137	73	44	34	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (100 neighbors)		+0.94	N/A	N/A	N/A	+0.76	+0.70	-207	-261	+139	+59

Nomenclature: See separate page