

ALLENTSTEIG, Austria

WMO: 110190

Lat: 48.6911N

Lon: 15.3672E

Elev: 1991

StdP: 13.67

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.5	13.4	4.0	7.3	9.6	9.2	9.5	15.2	19.8	37.0	18.2	34.3	5.5	310	0.538

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.8	83.7	67.0	80.1	65.5	76.9	63.8	68.3	80.0	66.6	77.6	65.1	74.7	6.3	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.3	97.2	73.2	62.7	91.9	71.1	61.3	87.4	69.7	33.7	80.4	32.3	77.8	31.1	74.9	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.4	15.1	13.3	4.3	89.4	5.8	3.7	0.2	92.1	-3.2	94.3	-6.4	96.3	-10.6	99.0		
(5)			4.2	71.5	5.8	1.9	0.0	72.9	-3.4	74.0	-6.7	75.1	-10.9	76.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.6	27.9	31.2	37.5	47.0	54.7	61.1	64.5	64.1	55.3	46.8	38.0	30.6
	DBStd	14.79	8.63	8.76	7.97	7.84	6.63	6.73	6.01	6.11	6.38	7.00	7.11	8.09
	HDD50	2914	685	528	391	143	30	3	0	1	21	146	364	602
	HDD65	6879	1150	948	852	540	323	153	84	91	297	564	810	1067
	CDD50	1689	0	1	4	53	176	336	451	436	180	48	4	0
	CDD65	176	0	0	0	0	4	36	70	61	5	0	0	0
	CDH74	1409	0	0	0	5	33	288	540	507	36	0	0	0
	CDH80	320	0	0	0	0	2	54	128	133	3	0	0	0
Wind	WSAvg	6.4	7.2	7.2	7.2	6.8	6.4	5.8	5.7	5.5	5.6	6.1	6.7	6.7
Precipitation	PrecAvg	25.2	1.3	1.1	1.6	1.7	3.0	3.4	3.3	3.2	2.2	1.7	1.5	1.3
	PrecMax	35.4	2.6	2.3	3.9	3.3	6.2	8.0	6.2	10.5	6.3	4.1	2.6	2.5
	PrecMin	18.1	0.2	0.2	0.3	0.1	0.6	1.3	1.1	0.7	0.6	0.3	0.0	0.3
	PrecStd	3.9	0.6	0.6	0.9	0.9	1.2	1.4	1.3	1.9	1.2	0.9	0.6	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.8	55.8	62.4	73.3	77.8	85.2	88.2	88.9	78.4	68.9	58.8	51.2
		MCWB	45.7	45.4	49.9	57.8	62.6	67.6	67.8	67.1	63.3	57.5	52.1	45.8
	2%	DB	47.0	49.8	57.4	67.8	73.7	80.7	83.4	83.7	73.4	63.2	54.0	47.0
		MCWB	42.2	43.4	47.4	55.2	61.2	66.8	67.1	66.3	61.8	55.8	49.2	43.3
	5%	DB	43.1	46.1	52.8	63.5	70.4	77.1	79.9	79.4	69.5	59.8	50.6	44.1
		MCWB	40.0	41.3	45.0	52.4	59.8	64.0	65.3	65.2	60.0	54.0	47.5	41.0
	10%	DB	39.6	42.7	48.7	60.0	67.1	73.6	76.3	75.8	66.0	56.6	47.5	41.1
		MCWB	37.2	38.9	42.9	50.5	57.5	62.6	63.9	63.4	58.4	52.7	45.2	38.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.3	46.8	50.6	59.0	65.1	70.9	70.2	70.1	64.8	58.9	52.8	46.3
		MCDB	51.0	52.8	60.0	69.9	74.6	81.9	82.8	83.3	75.2	64.7	57.4	49.5
	2%	WB	42.7	43.9	48.1	55.8	62.6	68.0	68.2	67.7	62.7	56.8	50.1	44.0
		MCDB	46.1	48.7	56.2	66.5	72.1	78.3	80.4	80.1	71.3	61.5	52.8	46.8
	5%	WB	40.0	41.7	46.0	53.4	60.6	65.8	66.5	66.0	61.1	55.1	47.8	41.2
		MCDB	42.9	46.1	51.6	61.8	68.9	74.9	77.3	77.5	68.2	58.8	50.2	43.7
	10%	WB	37.4	39.0	43.7	51.2	58.5	63.7	65.0	64.3	59.2	53.2	45.4	38.8
		MCDB	39.6	42.5	48.1	58.7	65.5	71.7	74.2	73.9	64.8	56.3	47.3	40.9
Mean Daily Temperature Range	5% DB	MDBR	7.8	10.1	12.6	15.9	15.9	16.5	16.8	16.9	14.2	11.6	8.0	8.0
		MCDBR	12.5	15.1	19.9	22.0	21.5	22.3	22.9	23.0	19.8	16.5	13.0	12.8
		MCWBR	9.4	10.3	11.6	11.4	11.0	10.3	9.1	9.4	9.6	9.8	8.8	9.9
	5% WB	MCDBR	11.7	14.4	18.0	20.1	20.0	20.4	20.4	21.3	17.8	14.8	12.0	12.4
MCWBR		9.2	10.3	11.2	10.9	10.7	10.3	8.8	9.2	9.4	9.3	8.7	10.1	
Clear-Sky Solar Irradiance	taub	0.290	0.313	0.351	0.390	0.392	0.396	0.404	0.400	0.373	0.346	0.320	0.290	
	taud	2.398	2.374	2.326	2.261	2.291	2.310	2.286	2.313	2.360	2.420	2.447	2.446	
	Ebn at Noon	247	266	272	272	276	275	270	266	262	250	233	232	
	Edh at Noon	21	27	33	40	40	40	40	37	32	26	20	18	
All-Sky Solar Radiation	RadAvg	311	592	925	1362	1584	1728	1665	1484	1057	651	328	244	
	RadStd	51	78	123	170	184	151	163	149	138	78	36	27	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (90 neighbors)		+0.94	N/A	N/A	N/A	+0.70	+0.58	-212	-272	+130	+58

Nomenclature: See separate page