

ALLENTSTEIG, Austria

WMO: 110190

Lat: 48.6911N

Lon: 15.3672E

Elev: 607

StdP: 94.24

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.0	-10.3	-15.6	1.0	-12.4	-12.7	1.4	-9.3	8.9	2.8	8.2	1.3	2.5	310	0.538

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.3	28.7	19.4	26.7	18.6	24.9	17.6	20.2	26.7	19.2	25.3	18.4	23.7	2.8	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.0	13.9	22.9	17.1	13.1	21.7	16.3	12.5	21.0	60.6	26.9	57.4	25.4	54.4	23.8	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 7.8	6.8	6.0		-15.4	31.9	3.2	2.1	-17.7	33.4	-19.6	34.6	-21.3	35.7	-23.7	37.2	
(5)			DB	-15.5	22.0	3.2	1.1	-17.8	22.7	-19.7	23.3	-21.5	23.9	-23.8	24.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.1	-2.3	-0.5	3.1	8.3	12.6	16.2	18.1	17.8	12.9	8.2	3.3	-0.8
	DBStd	8.22	4.79	4.87	4.43	4.35	3.68	3.74	3.34	3.39	3.54	3.89	3.95	4.50
	HDD10.0	1619	381	293	217	79	17	2	0	1	12	81	202	334
	HDD18.3	3822	639	527	473	300	179	85	47	51	165	313	450	593
	CDD10.0	938	0	1	2	29	98	187	251	242	100	27	2	0
	CDD18.3	98	0	0	0	0	2	20	39	34	3	0	0	0
	CDH23.3	783	0	0	0	3	18	160	300	282	20	0	0	0
	CDH26.7	178	0	0	0	0	1	30	71	74	2	0	0	0
(14) Wind	WSAvg	2.9	3.2	3.2	3.2	3.0	2.9	2.6	2.6	2.5	2.5	2.7	3.0	3.0
(15) Precipitation	PrecAvg	639	32	27	41	43	75	87	83	82	55	43	38	32
	PrecMax	899	66	59	98	85	158	202	157	267	160	104	67	64
	PrecMin	459	5	5	7	2	14	34	27	19	14	7	1	7
	PrecStd	100	16	16	24	24	31	35	32	49	30	24	16	15
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.0	13.2	16.9	22.9	25.4	29.6	31.2	31.6	25.8	20.5	14.9	10.7
		MCWB	7.6	7.4	10.0	14.3	17.0	19.8	19.9	19.5	17.4	14.2	11.2	7.7
	2%	DB	8.4	9.9	14.1	19.9	23.2	27.0	28.6	28.7	23.0	17.3	12.2	8.3
		MCWB	5.7	6.3	8.6	12.9	16.2	19.3	19.5	19.1	16.5	13.2	9.6	6.3
	5%	DB	6.2	7.8	11.6	17.5	21.3	25.0	26.6	26.3	20.9	15.4	10.3	6.7
		MCWB	4.4	5.2	7.2	11.3	15.4	17.8	18.5	18.5	15.6	12.2	8.6	5.0
	10%	DB	4.2	5.9	9.3	15.5	19.5	23.1	24.6	24.3	18.9	13.7	8.6	5.0
		MCWB	2.9	3.8	6.1	10.3	14.2	17.0	17.7	17.4	14.7	11.5	7.3	3.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.0	8.2	10.4	15.0	18.4	21.6	21.2	21.2	18.2	15.0	11.5	8.0
		MCDB	10.5	11.6	15.6	21.1	23.7	27.7	28.2	28.5	24.0	18.2	14.1	9.7
	2%	WB	5.9	6.6	8.9	13.2	17.0	20.0	20.1	19.8	17.1	13.8	10.1	6.6
		MCDB	7.9	9.3	13.5	19.1	22.3	25.7	26.9	26.7	21.9	16.4	11.6	8.2
	5%	WB	4.5	5.4	7.8	11.9	15.9	18.8	19.2	18.9	16.2	12.8	8.8	5.1
		MCDB	6.0	7.8	10.9	16.5	20.5	23.8	25.2	25.3	20.1	14.9	10.1	6.5
	10%	WB	3.0	3.9	6.5	10.7	14.7	17.6	18.3	17.9	15.1	11.8	7.4	3.8
		MCDB	4.2	5.8	9.0	14.9	18.6	22.1	23.5	23.3	18.2	13.5	8.5	5.0
(35) Mean Daily Temperature Range	5% DB	MDBR	4.3	5.6	7.0	8.8	8.8	9.1	9.3	9.4	7.9	6.4	4.4	4.4
		MCDBR	6.9	8.4	11.0	12.2	12.0	12.4	12.7	12.8	11.0	9.2	7.2	7.1
		MCWBR	5.2	5.7	6.5	6.3	6.1	5.7	5.1	5.2	5.4	5.4	4.9	5.5
	5% WB	MCDBR	6.5	8.0	10.0	11.2	11.1	11.3	11.4	11.8	9.9	8.2	6.6	6.9
		MCWBR	5.1	5.7	6.2	6.1	6.0	5.7	4.9	5.1	5.2	5.1	4.8	5.6
(40) Clear-Sky Solar Irradiance	taub		0.290	0.313	0.351	0.390	0.392	0.396	0.404	0.400	0.373	0.346	0.320	0.290
	taud		2.398	2.374	2.326	2.261	2.291	2.310	2.286	2.313	2.360	2.420	2.447	2.446
	Ebn at Noon		778	840	859	857	869	866	852	838	825	789	734	732
	Edh at Noon		66	85	105	125	126	125	126	117	101	81	64	56
(44) All-Sky Solar Radiation	RadAvg		0.98	1.86	2.92	4.29	4.99	5.45	5.25	4.68	3.33	2.05	1.03	0.77
	RadStd		0.16	0.25	0.39	0.54	0.58	0.47	0.52	0.47	0.43	0.24	0.11	0.08

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (90 neighbors)		+0.52	N/A	N/A	N/A	+0.39	+0.32	-118	-151	+72	+32

Nomenclature: See separate page