

STIFT ZWETTL, Austria

WMO: 110200

Lat: 48.618N

Lon: 15.204E

Elev: 505

StdP: 95.40

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.5	-11.7	-17.6	0.8	-15.2	-13.9	1.2	-10.7	4.6	3.6	4.2	3.2	0.7	230	0.504

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.8	29.1	19.6	27.1	18.8	25.2	17.8	20.6	26.9	19.6	25.4	18.7	23.9	1.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	14.3	23.2	17.6	13.4	21.9	16.7	12.6	21.0	61.8	27.1	58.2	25.3	54.9	24.1	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3.9	3.3	2.8	-18.6	32.6	5.0	1.7	-22.2	33.8	-25.1	34.8	-27.9	35.8	-31.5	37.0
			-18.8	22.5	4.5	1.3	-22.0	23.5	-24.6	24.3	-27.2	25.0	-30.4	26.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.8	-2.4	-0.6	2.8	7.8	12.2	15.8	17.5	17.0	12.3	7.9	3.3	-0.9
	DBStd	7.91	4.77	4.71	4.11	3.75	3.33	3.45	3.02	3.10	3.17	3.61	3.63	4.47
	HDD10.0	1647	384	297	225	85	17	2	0	1	13	85	202	337
	HDD18.3	3922	642	530	483	317	192	89	52	63	182	324	451	596
	CDD10.0	829	0	0	1	18	83	176	233	216	82	19	1	0
	CDD18.3	64	0	0	0	0	1	14	27	21	1	0	0	0
	CDH23.3	868	0	0	0	6	36	204	319	281	22	0	0	0
	CDH26.7	216	0	0	0	1	3	47	86	78	1	0	0	0
(14) Wind	WSAvg	1.0	1.2	1.2	1.2	1.1	1.1	1.0	1.0	0.9	0.9	0.9	1.0	1.1
(15) Precipitation	PrecAvg	770	42	37	54	51	86	98	101	96	65	50	47	44
	PrecMax	1091	92	80	103	92	176	209	193	349	176	119	75	86
	PrecMin	567	10	11	15	6	23	42	32	32	15	10	4	12
	PrecStd	113	20	21	26	26	35	35	35	60	33	27	19	16
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.8	13.1	17.5	23.9	26.4	30.5	31.9	31.9	26.0	20.4	15.1	10.6
		MCWB	7.4	7.6	9.8	14.0	17.1	20.1	20.3	20.2	17.6	14.2	11.0	7.9
	2%	DB	8.0	10.2	14.4	20.9	24.2	27.8	29.0	28.7	23.3	17.6	12.2	8.5
		MCWB	5.5	6.4	8.4	12.8	16.3	19.2	19.7	19.3	16.7	13.4	9.5	6.2
	5%	DB	5.9	8.0	11.7	18.2	22.2	25.7	26.7	26.5	20.8	15.7	10.3	6.4
		MCWB	4.0	5.3	7.2	11.3	15.2	18.0	18.8	18.7	15.4	12.3	8.3	4.7
	10%	DB	4.0	5.8	9.4	15.9	20.0	23.6	24.7	24.2	18.6	13.8	8.6	4.7
		MCWB	2.5	3.5	6.1	10.1	13.9	17.0	18.0	17.5	14.5	11.5	7.2	3.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.8	8.2	10.2	14.8	18.7	21.9	22.0	21.8	18.6	15.2	11.4	8.1
		MCDB	10.3	11.8	16.1	22.7	24.7	27.7	28.1	28.1	23.9	18.7	13.8	10.1
	2%	WB	5.7	6.7	8.9	13.2	17.1	20.1	20.7	20.4	17.2	13.9	9.9	6.4
		MCDB	7.7	9.8	13.4	19.7	22.7	25.8	26.9	26.7	22.0	16.5	11.7	8.2
	5%	WB	4.2	5.2	7.7	11.9	15.8	18.9	19.6	19.3	16.1	12.8	8.6	4.7
		MCDB	5.9	7.9	11.2	17.0	21.1	24.2	25.2	25.1	19.9	15.3	10.0	6.2
	10%	WB	2.6	3.7	6.4	10.6	14.5	17.7	18.6	18.2	15.0	11.7	7.3	3.5
		MCDB	3.9	5.7	9.1	15.2	18.9	22.4	23.6	23.1	18.1	13.7	8.5	4.6
(35) Mean Daily Temperature Range	5% DB	MDBR	5.8	7.5	9.1	11.7	11.7	11.8	12.1	10.3	8.8	5.9	5.5	
		MCDBR	8.0	11.1	14.4	17.1	16.4	16.4	16.4	16.8	14.7	12.6	9.6	8.4
	5% WB	MCWBR	6.0	7.5	9.0	9.4	8.7	8.1	7.8	8.0	8.6	8.4	7.1	6.7
		MCWBR	7.8	10.5	13.2	15.4	15.2	14.6	14.7	15.1	13.2	11.4	8.4	8.0
(40) Clear-Sky Solar Irradiance	taub		0.294	0.317	0.357	0.396	0.399	0.403	0.411	0.407	0.380	0.350	0.323	0.294
		taud	2.389	2.360	2.311	2.251	2.281	2.302	2.278	2.307	2.353	2.416	2.444	2.442
	Ebn at Noon		773	834	852	851	862	859	845	831	819	784	731	727
		Edh at Noon	67	86	107	126	127	126	127	118	102	82	64	57
(44) All-Sky Solar Radiation	RadAvg		0.99	1.87	2.92	4.30	4.99	5.45	5.25	4.68	3.34	2.06	1.04	0.77
	RadStd		0.16	0.25	0.38	0.53	0.58	0.48	0.51	0.47	0.43	0.24	0.11	0.08

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (95 neighbors)	+0.51	N/A	N/A	N/A	+0.39	+0.33	N/A	-146	+72	+32

Nomenclature: See separate page