

RETZ, Austria

WMO: 110220

Lat: 48.7611N

Lon: 15.9417E

Elev: 320

StdP: 97.54

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.7	-8.4	-14.6	1.1	-9.4	-12.2	1.4	-7.0	12.9	7.1	11.8	6.0	3.4	50	0.536

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	30.9	20.8	29.0	20.1	27.3	19.1	21.8	28.7	20.8	27.3	19.8	25.9	3.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.4	14.7	25.5	18.5	13.8	23.9	17.6	13.1	22.9	65.1	28.7	61.3	27.4	58.1	26.0	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.6	9.1	7.9	-12.5	33.8	3.0	2.0	-14.7	35.2	-16.4	36.4	-18.1	37.5	-20.3	39.0		
(5)			-13.1	23.2	2.8	1.2	-15.2	24.0	-16.8	24.7	-18.4	25.4	-20.5	26.2	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	-0.8	1.4	5.4	11.1	15.2	18.7	20.6	20.5	15.5	10.2	5.0	0.5	(6)
(7)		DBStd	8.55	4.59	4.75	4.51	4.36	3.69	3.71	3.49	3.50	3.58	3.77	4.00	4.15	(7)
(8)		HDD10.0	1268	334	243	152	39	4	0	0	0	2	45	156	294	(8)
(9)		HDD18.3	3178	592	475	401	219	111	41	17	18	100	253	399	553	(9)
(10)		CDD10.0	1383	1	1	9	71	163	262	329	324	166	51	6	0	(10)
(11)		CDD18.3	253	0	0	0	2	12	52	89	84	14	1	0	0	(11)
(12)		CDH23.3	1829	0	0	0	10	73	368	686	617	73	2	0	0	(12)
(13)		CDH26.7	506	0	0	0	1	8	92	210	186	11	0	0	0	(13)
(14)	Wind	WSAvg	3.7	3.8	4.0	4.2	4.0	3.5	3.8	3.4	3.6	3.4	3.4	3.4	(14)	
(15)	Precipitation	PrecAvg	526	25	20	34	35	60	71	70	66	49	35	33	28	(15)
(16)		PrecMax	751	55	55	90	77	106	140	172	155	119	80	63	50	(16)
(17)		PrecMin	385	4	3	6	1	12	23	18	21	10	6	4	7	(17)
(18)		PrecStd	86	13	14	20	19	21	30	33	34	29	20	14	11	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.6	14.4	18.7	24.7	27.7	31.7	33.3	33.9	28.2	22.4	16.8	11.0	(19)
(20)			MCWB	8.9	8.9	11.4	15.7	18.5	21.0	21.7	20.6	19.3	15.8	12.7	8.3	(20)
(21)		2%	DB	9.6	11.8	16.2	21.9	25.4	29.2	31.0	30.8	25.5	19.2	14.1	8.8	(21)
(22)			MCWB	6.7	7.9	10.1	14.4	17.7	20.7	21.2	20.5	18.0	14.5	11.0	6.5	(22)
(23)		5%	DB	7.2	9.7	13.9	19.8	23.6	27.2	29.1	28.6	23.2	17.3	12.0	7.2	(23)
(24)			MCWB	5.0	6.5	8.8	13.1	16.7	19.3	20.0	19.7	16.8	13.6	10.0	5.3	(24)
(25)		10%	DB	5.3	7.5	11.8	17.9	21.7	25.4	27.1	26.7	21.3	15.6	10.3	5.6	(25)
(26)			MCWB	3.6	5.0	7.7	11.9	15.5	18.4	19.2	18.7	15.8	12.8	8.6	4.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	9.6	12.0	16.5	19.9	23.1	23.2	23.0	19.7	16.6	13.0	8.7	(27)
(28)			MCDWB	12.6	13.4	17.4	23.5	25.5	29.2	30.5	31.5	26.5	20.9	16.0	10.7	(28)
(29)		2%	WB	6.9	8.2	10.5	14.7	18.4	21.5	21.8	21.3	18.5	15.2	11.7	6.9	(29)
(30)			MCDWB	9.2	11.2	15.1	21.0	24.1	27.5	29.0	28.5	24.1	18.1	13.7	8.4	(30)
(31)		5%	WB	5.2	6.8	9.3	13.5	17.3	20.2	20.7	20.3	17.5	14.2	10.2	5.5	(31)
(32)			MCDWB	7.0	9.5	13.2	19.0	22.5	25.7	27.3	27.3	22.0	16.5	11.8	6.9	(32)
(33)		10%	WB	3.7	5.2	8.1	12.4	16.2	19.1	19.7	19.4	16.5	13.2	8.8	4.4	(33)
(34)			MCDWB	5.1	7.4	11.4	17.2	21.0	24.1	25.7	25.6	20.4	15.4	10.1	5.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.3	5.5	7.1	8.4	8.5	8.8	9.2	9.1	7.7	6.3	4.4	4.0	(35)
(36)			MCDBR	6.7	8.2	10.5	10.7	11.0	11.4	11.9	11.8	10.6	8.7	6.9	6.3	(36)
(37)			MCWBR	4.9	5.3	5.9	5.4	5.3	5.1	4.5	4.6	4.7	4.9	4.5	4.8	(37)
(38)		5% WB	MCDWR	6.6	8.1	9.8	10.2	10.5	10.6	11.1	11.1	9.7	7.8	6.3	5.9	(38)
(39)			MCWBR	5.0	5.5	5.8	5.4	5.3	5.2	4.6	4.8	4.7	4.7	4.3	4.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.307	0.330	0.370	0.413	0.414	0.417	0.425	0.422	0.394	0.365	0.339	0.306	(40)	
(41)		taud	2.374	2.347	2.282	2.196	2.234	2.259	2.239	2.262	2.311	2.365	2.391	2.409	(41)	
(42)		Ebn at Noon	751	816	836	833	848	846	832	815	801	762	701	703	(42)	
(43)		Edh at Noon	68	88	110	133	133	131	132	123	107	86	67	58	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.94	1.80	2.89	4.34	5.08	5.54	5.32	4.75	3.38	2.04	1.02	0.74	(44)	
(45)		RadStd	0.14	0.24	0.40	0.50	0.58	0.46	0.53	0.46	0.44	0.26	0.11	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.84	N/A	N/A	+1.24	N/A	N/A	-155	-225	+148	+61
(47) Regional (88 neighbors)		+0.54	N/A	N/A	+0.78	+0.40	+0.34	-122	-160	+78	+34

Nomenclature: See separate page