

JAUERLING, Austria

WMO: 110240

Lat: 48.334N

Lon: 15.339E

Elev: 3151

StdP: 13.10

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.7	12.2	1.5	6.7	14.3	6.8	8.8	16.1	34.1	33.4	30.9	32.1	8.1	310	0.655

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.6	79.0	64.8	75.6	63.5	72.8	62.0	66.4	75.9	64.6	73.6	63.0	71.3	8.1	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.8	96.3	71.8	61.1	90.5	69.4	59.6	85.6	67.9	32.9	76.0	31.4	73.9	30.2	71.4	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.9	23.5	20.9	DB	6.0	83.4	5.7	4.0	1.9	86.3	-1.4	88.6	-4.6	90.8	-8.8	93.7	(4)
(5)			WB	4.5	69.9	5.4	2.1	0.6	71.4	-2.6	72.6	-5.6	73.9	-9.6	75.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.6	26.8	29.6	35.1	44.2	51.8	58.2	61.2	61.4	52.7	45.5	36.8	30.3	(6)	
	DBStd	14.59	8.79	9.33	8.84	8.61	7.49	7.56	7.02	6.92	7.17	8.41	8.44	8.69	(7)	
	HDD50	3310	718	570	466	210	70	15	3	3	52	191	401	611	(8)	
	HDD65	7576	1183	990	927	625	412	227	158	155	373	605	845	1076	(9)	
	CDD50	1324	0	0	4	35	125	261	352	357	133	51	6	0	(10)	
	CDD65	115	0	0	0	0	3	23	41	44	4	0	0	0	(11)	
	CDH74	464	0	0	0	0	5	86	168	198	7	0	0	0	(12)	
	CDH80	68	0	0	0	0	0	10	21	36	1	0	0	0	(13)	
(14) Wind	WSAvg	10.6	12.0	12.0	11.5	10.0	9.9	9.0	9.7	9.1	9.7	10.9	11.2	11.6	(14)	
(15) Precipitation	PrecAvg	26.2	1.3	1.1	1.7	1.7	3.0	3.5	3.5	3.3	2.3	1.8	1.5	1.3	(15)	
	PrecMax	35.3	2.8	2.6	3.9	3.9	6.3	8.9	7.0	11.0	6.1	3.7	2.8	2.6	(16)	
	PrecMin	17.9	0.1	0.1	0.3	0.0	0.7	1.7	1.2	1.0	0.8	0.3	0.0	0.3	(17)	
	PrecStd	4.2	0.7	0.7	0.9	1.0	1.4	1.5	1.5	2.0	1.1	1.0	0.6	0.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.8	52.6	59.4	68.9	73.5	81.0	82.8	84.3	73.9	67.2	58.9	52.5	(19)	
		MCWB	41.4	41.8	47.2	55.0	59.6	65.6	65.8	64.8	62.1	55.8	48.4	42.4	(20)	
	2%	DB	46.3	48.4	54.8	63.7	69.8	76.3	78.3	79.2	69.4	63.0	54.9	47.9	(21)	
		MCWB	39.4	39.5	44.6	52.3	58.8	64.4	65.0	64.4	60.3	53.6	46.6	40.9	(22)	
	5%	DB	42.8	45.3	50.8	59.6	66.7	72.8	75.2	75.4	65.9	59.8	51.8	44.7	(23)	
		MCWB	37.9	38.5	42.8	50.0	57.1	62.4	63.4	63.1	58.2	52.2	45.2	39.3	(24)	
	10%	DB	39.3	42.3	47.0	56.4	63.4	69.9	72.2	72.0	63.0	56.8	48.8	41.9	(25)	
		MCWB	35.6	36.9	40.8	48.0	55.1	60.5	62.1	61.7	56.6	51.2	43.9	37.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.5	43.6	48.0	55.7	62.7	68.3	69.0	68.5	63.6	57.9	50.3	44.1	(27)	
		MCDB	47.8	49.1	57.0	66.3	70.9	77.0	77.9	78.3	70.7	63.5	56.0	49.0	(28)	
	2%	WB	40.6	41.2	45.5	53.0	59.9	65.5	66.2	66.0	61.0	55.0	48.2	42.0	(29)	
		MCDB	44.4	46.5	53.0	62.0	67.7	74.2	75.9	75.9	68.0	60.7	53.2	46.1	(30)	
	5%	WB	38.4	39.3	43.6	50.9	57.8	63.3	64.5	64.1	59.1	53.4	46.3	40.3	(31)	
		MCDB	42.3	43.8	49.3	58.7	65.3	71.5	73.5	73.4	65.0	57.9	50.5	44.0	(32)	
	10%	WB	35.9	37.4	41.6	48.5	55.7	61.2	62.8	62.4	57.1	51.7	44.2	38.0	(33)	
		MCDB	39.2	41.9	46.3	55.3	62.5	68.6	70.9	70.8	62.1	56.2	48.0	41.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.4	8.2	9.6	12.0	12.0	12.1	12.1	11.6	9.7	9.1	7.7	7.6	(35)	
		MCDBR	11.3	11.6	14.0	15.1	15.6	15.1	16.0	15.4	13.2	12.6	11.8	12.1	(36)	
	5% WB	MCWBR	7.6	7.4	8.6	9.1	9.5	9.2	8.5	8.5	8.3	7.6	7.0	7.9	(37)	
		MCWBR	10.4	10.6	12.9	14.1	14.7	13.8	14.2	13.9	12.4	11.3	10.4	11.1	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.272	0.293	0.327	0.361	0.364	0.369	0.375	0.371	0.348	0.322	0.299	0.273	(40)	
		taud	2.440	2.418	2.392	2.345	2.363	2.371	2.349	2.376	2.422	2.485	2.509	2.485	(41)	
	Ebn at Noon		258	276	282	282	285	283	279	275	272	262	246	244	(42)	
		Edh at Noon	20	26	31	36	37	37	37	35	30	24	19	17	(43)	
(44) All-Sky Solar Radiation	RadAvg		326	607	941	1358	1570	1715	1666	1486	1062	672	348	260	(44)	
	RadStd		49	79	118	163	182	149	160	153	137	75	39	30	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (98 neighbors)		+0.94	N/A	N/A	N/A	+0.72	+0.63	-207	-263	+130	+59

Nomenclature: See separate page