

WIEN SCHWECHAT, Austria

WMO: 110360

Lat: 48.1175N

Lon: 16.5814E

Elev: 600

StdP: 14.38

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.0	17.9	7.1	8.1	15.3	12.1	10.4	20.7	32.7	43.2	29.7	41.1	8.4	340	0.577

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.7	89.3	69.8	85.9	68.7	82.6	67.1	71.4	84.8	69.9	82.5	68.5	80.0	10.3	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.9	101.1	76.7	65.5	96.3	75.5	64.2	91.8	74.5	35.5	85.0	34.2	82.9	33.0	80.5	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.0	23.9	21.4	8.0	94.0	5.4	3.7	4.1	96.7	0.9	98.9	-2.2	100.9	-6.1	103.6		
(5)			7.2	74.5	5.3	1.6	3.4	75.7	0.3	76.7	-2.7	77.6	-6.6	78.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.6	32.4	35.8	42.8	52.1	60.0	66.7	70.2	69.4	60.7	51.4	42.4	34.0	(6)
(7)		DBStd	15.08	8.43	8.64	7.61	7.13	6.21	6.25	5.60	5.66	5.95	7.01	7.35	7.58	(7)
(8)		HDD50	2067	548	402	242	60	3	0	0	0	2	69	243	498	(8)
(9)		HDD65	5391	1011	819	688	387	178	54	17	21	153	424	677	962	(9)
(10)		CDD50	2642	2	3	19	124	313	501	627	600	324	112	16	1	(10)
(11)		CDD65	491	0	0	0	2	23	105	179	156	25	1	0	0	(11)
(12)		CDH74	4215	0	0	0	27	205	887	1574	1335	181	6	0	0	(12)
(13)		CDH80	1303	0	0	0	2	24	249	545	454	29	0	0	0	(13)
(14)	Wind	WSAvg	9.9	10.8	11.1	11.1	10.4	9.8	9.1	9.3	8.4	9.1	9.1	10.3	10.2	(14)
(15)	Precipitation	PrecAvg	22.6	1.1	1.0	1.5	1.5	2.4	2.8	2.9	2.5	2.3	1.7	1.6	1.3	(15)
(16)		PrecMax	30.5	2.4	2.2	3.2	3.5	5.6	6.3	7.5	5.9	6.4	3.7	3.1	2.5	(16)
(17)		PrecMin	15.5	0.1	0.0	0.3	0.0	0.6	0.9	0.3	0.3	0.6	0.1	0.1	0.4	(17)
(18)		PrecStd	3.7	0.6	0.7	0.9	0.9	1.2	1.3	1.6	1.5	1.6	0.9	0.6	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.1	60.6	68.0	77.4	82.7	90.3	93.5	93.6	83.8	73.5	64.9	55.4	(19)
(20)			MCWB	48.6	48.4	53.2	60.4	65.6	70.6	70.8	69.5	66.2	61.3	55.7	49.0	(20)
(21)		2%	DB	52.0	55.8	63.1	72.9	79.1	86.1	89.4	89.2	78.9	68.9	60.3	51.4	(21)
(22)			MCWB	45.6	47.3	50.9	58.1	64.3	69.7	69.8	69.5	64.8	59.7	53.6	45.4	(22)
(23)		5%	DB	48.0	52.0	59.0	68.7	75.6	82.5	85.9	84.9	75.2	65.3	56.2	46.9	(23)
(24)			MCWB	43.0	45.0	49.0	55.8	62.4	67.4	68.7	68.1	63.1	57.8	51.3	42.6	(24)
(25)		10%	DB	44.2	48.2	55.2	64.9	72.3	79.1	82.5	81.3	71.6	62.0	52.5	43.8	(25)
(26)			MCWB	40.2	43.0	47.0	53.7	60.4	66.0	67.4	66.7	61.4	56.2	48.3	40.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.6	50.3	54.6	61.5	68.0	73.5	73.6	72.9	67.9	63.0	56.9	49.4	(27)
(28)			MDCB	55.9	58.0	65.2	74.9	79.9	85.5	89.0	86.7	79.4	70.4	62.7	54.7	(28)
(29)		2%	WB	45.9	47.6	51.9	58.9	65.6	70.8	71.4	70.8	66.1	60.8	54.3	46.1	(29)
(30)			MDCB	51.0	54.7	60.7	70.1	76.3	83.0	85.0	84.2	76.1	67.3	59.4	50.4	(30)
(31)		5%	WB	43.0	45.5	49.9	56.8	63.5	69.0	69.9	69.3	64.3	58.8	51.5	42.9	(31)
(32)			MDCB	46.7	51.2	57.7	67.0	73.6	80.3	82.7	81.8	72.5	63.9	56.0	46.1	(32)
(33)		10%	WB	40.2	43.0	47.8	54.9	61.5	67.0	68.4	67.8	62.6	56.7	48.9	40.7	(33)
(34)			MDCB	43.6	47.6	54.3	63.7	70.7	77.3	80.1	79.0	70.6	61.2	52.1	43.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.3	11.8	15.2	17.9	17.6	18.2	18.7	18.7	16.0	14.1	9.9	8.7	(35)
(36)			MCDBR	14.2	17.7	23.0	24.0	23.3	23.4	25.0	24.7	22.1	18.7	14.9	14.2	(36)
(37)			MCWBR	9.9	11.1	13.1	12.2	11.0	9.9	9.3	9.1	10.1	10.5	9.6	10.3	(37)
(38)		5% WB	MCDBR	13.6	16.6	21.1	22.0	21.5	21.9	22.4	22.1	19.6	17.1	14.0	13.2	(38)
(39)			MCWBR	10.1	11.0	12.7	11.6	10.8	10.1	9.1	9.2	9.6	10.3	9.5	10.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.319	0.343	0.381	0.425	0.423	0.427	0.435	0.434	0.407	0.377	0.350	0.318	(40)	
(41)		taud	2.378	2.343	2.264	2.170	2.221	2.247	2.228	2.245	2.289	2.346	2.376	2.403	(41)	
(42)		Ebn at Noon	236	256	262	261	267	266	262	256	251	239	220	221	(42)	
(43)		Edh at Noon	22	29	36	43	43	42	43	40	35	28	22	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	312	571	946	1427	1684	1837	1772	1580	1130	686	354	244	(44)	
(45)		RadStd	36	76	123	141	178	135	161	151	137	78	34	28	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.86	N/A	N/A	N/A	+0.81	+0.72	N/A	-227	+171	+92
(47) Regional (85 neighbors)		+1.03	N/A	N/A	+1.51	+0.83	+0.70	-225	-301	+158	+79

Nomenclature: See separate page