

RIED IM INNKEIS, Austria

WMO: 110530

Lat: 48.217N

Lon: 13.475E

Elev: 429

StdP: 96.27

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.0	-9.1	-14.5	1.1	-11.5	-11.5	1.5	-8.0	5.4	6.0	4.7	4.1	1.0	90	0.440

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	30.7	20.8	28.8	20.0	27.2	19.3	21.5	28.8	20.6	27.3	19.8	25.9	1.1	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	14.5	24.9	18.2	13.8	23.6	17.5	13.2	22.8	64.6	28.9	61.1	27.5	58.3	26.0	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.3	3.5	3.1	DB	-14.0	33.2	3.7	1.4	-16.7	34.1	-18.8	34.9	-20.9	35.7	-23.5	36.7	(4)
(5)			WB	-14.8	23.3	3.8	0.9	-17.5	24.0	-19.7	24.5	-21.9	25.0	-24.6	25.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	-0.8	1.0	5.0	10.1	13.9	18.0	19.6	19.0	14.3	9.8	4.4	0.9	(6)	
	DBStd	8.07	4.55	4.62	4.23	3.89	3.68	3.68	3.25	3.17	3.33	3.46	3.59	3.97	(7)	
	HDD10.0	1306	336	254	158	46	8	1	0	0	4	47	169	283	(8)	
	HDD18.3	3340	594	487	412	248	144	49	26	31	128	264	417	541	(9)	
	CDD10.0	1177	1	1	4	48	129	242	298	278	132	42	3	0	(10)	
	CDD18.3	169	0	0	0	1	6	41	65	51	6	0	0	0	(11)	
	CDH23.3	1643	0	0	0	12	88	406	613	468	56	1	0	0	(12)	
	CDH26.7	458	0	0	0	2	13	106	191	140	7	0	0	0	(13)	
(14) Wind	WSAvg	1.3	1.6	1.7	1.7	1.4	1.1	1.1	1.1	1.0	1.0	1.0	1.4	1.6	(14)	
(15) Precipitation	PrecAvg	1046	64	56	78	65	105	126	130	118	95	71	69	69	(15)	
	PrecMax	1279	138	142	145	170	197	277	282	282	195	134	164	124	(16)	
	PrecMin	740	12	10	17	4	26	46	25	33	35	18	3	16	(17)	
	PrecStd	122	36	32	39	38	44	51	55	50	39	32	33	33	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.2	14.1	19.0	24.9	28.4	31.9	33.2	33.0	27.2	22.2	16.1	12.1	(19)	
		MCWB	8.4	8.3	11.5	15.6	18.9	21.8	21.3	21.1	19.3	15.4	11.8	8.8	(20)	
	2%	DB	9.6	11.3	16.4	22.3	25.9	29.5	30.8	30.2	24.9	19.3	13.5	9.7	(21)	
		MCWB	7.1	7.4	10.4	13.7	17.9	20.4	20.7	20.6	18.5	14.6	10.4	7.6	(22)	
	5%	DB	7.2	9.3	14.1	20.0	23.6	27.6	28.7	27.9	22.6	17.3	11.5	8.0	(23)	
		MCWB	5.4	6.4	9.0	12.8	16.3	19.3	20.0	19.9	17.0	13.4	9.5	6.0	(24)	
	10%	DB	5.3	7.3	11.9	17.9	21.3	25.8	26.9	25.9	20.4	15.6	9.7	6.3	(25)	
		MCWB	3.9	5.0	8.0	11.6	14.8	18.3	19.5	18.9	15.8	12.8	8.1	4.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	9.2	12.2	16.2	20.1	22.8	22.8	22.3	19.9	16.3	12.4	9.3	(27)	
		MCDB	11.3	12.9	18.4	23.8	27.0	30.1	30.9	30.6	25.7	20.3	15.1	11.3	(28)	
	2%	WB	7.2	7.8	10.7	14.3	18.2	21.2	21.3	21.2	18.7	15.0	10.7	7.8	(29)	
		MCDB	9.2	10.7	15.4	21.1	24.9	27.7	28.8	28.6	24.3	18.2	12.9	9.7	(30)	
	5%	WB	5.6	6.4	9.5	13.1	16.9	20.0	20.5	20.2	17.6	14.0	9.6	6.2	(31)	
		MCDB	7.2	9.1	13.4	19.1	22.8	26.4	27.3	26.6	21.8	16.6	11.4	7.5	(32)	
	10%	WB	3.9	5.1	8.3	12.0	15.6	19.0	19.7	19.4	16.5	13.0	8.2	4.9	(33)	
		MCDB	5.3	7.1	11.5	16.8	20.3	24.3	25.7	24.9	19.6	15.3	9.6	6.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.1	6.7	8.7	10.2	9.7	9.9	10.1	10.0	8.8	7.8	5.3	5.0	(35)	
		MCDBR	7.5	10.2	13.8	15.0	14.5	13.8	14.2	14.1	12.4	11.3	8.8	8.0	(36)	
	5% WB	MCWBR	5.6	6.8	8.2	7.7	7.1	5.9	5.7	6.0	6.3	7.0	6.2	6.0	(37)	
		MCWBR	7.3	9.7	12.8	14.0	13.4	12.4	12.6	13.0	11.3	10.3	8.0	7.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.297	0.322	0.361	0.394	0.402	0.406	0.412	0.406	0.380	0.350	0.323	0.296	(40)	
		taud	2.407	2.349	2.309	2.265	2.279	2.304	2.283	2.319	2.364	2.435	2.462	2.446	(41)	
	Ebn at Noon		776	830	850	855	861	858	845	834	821	790	739	732	(42)	
		Edh at Noon	67	88	108	125	128	126	126	117	102	81	64	57	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.08	2.02	3.06	4.26	4.93	5.44	5.32	4.69	3.37	2.18	1.15	0.84	(44)	
	RadStd		0.17	0.27	0.37	0.54	0.59	0.50	0.51	0.51	0.45	0.24	0.15	0.11	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (96 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.48	N/A	N/A	N/A	+0.38	+0.38	N/A	N/A	+68	+27

Nomenclature: See separate page