

LILIENFELD TARSCHBERG, Austria

WMO: 110780

Lat: 48.028N

Lon: 15.588E

Elev: 696

StdP: 93.24

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.7	-9.5	-15.0	1.1	-10.1	-12.4	1.4	-8.1	10.7	2.0	10.0	1.6	2.5	220	0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	28.2	19.6	26.3	18.9	24.6	18.0	20.4	26.4	19.4	25.1	18.5	23.9	2.2	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.2	14.2	24.2	17.1	13.3	22.8	16.3	12.6	21.6	61.9	26.6	58.2	25.1	55.1	24.0	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.9	7.7	6.6	DB	-13.4	31.0	3.2	1.6	-15.6	32.2	-17.5	33.1	-19.3	34.0	-21.6	35.2	(4)
(5)			WB	-13.7	22.7	3.0	1.1	-15.9	23.4	-17.6	24.1	-19.3	24.7	-21.5	25.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.6	-1.5	0.2	3.4	8.6	12.7	16.1	17.9	17.9	13.2	9.1	4.1	0.3	(6)	
	DBStd	8.11	4.91	5.15	4.65	4.81	4.09	4.09	3.62	3.69	3.84	4.33	4.59	4.72	(7)	
	HDD10.0	1512	356	275	207	81	20	4	0	1	13	70	184	302	(8)	
	HDD18.3	3683	614	508	462	294	180	89	52	53	158	287	427	560	(9)	
	CDD10.0	984	0	1	3	38	103	188	246	247	110	42	7	0	(10)	
	CDD18.3	113	0	0	0	1	4	23	39	41	4	1	0	0	(11)	
	CDH23.3	664	0	0	0	2	14	135	242	253	16	1	0	0	(12)	
	CDH26.7	128	0	0	0	0	0	23	50	54	1	0	0	0	(13)	
(14) Wind	WSAvg	2.9	3.5	3.4	3.3	3.1	2.7	2.6	2.6	2.5	2.5	2.7	3.1	3.3	(14)	
(15) Precipitation	PrecAvg	856	43	42	60	59	93	109	111	98	79	57	55	49	(15)	
	PrecMax	1131	110	102	133	121	240	295	307	262	232	136	100	100	(16)	
	PrecMin	574	2	8	10	4	27	39	37	25	14	4	0	12	(17)	
	PrecStd	138	24	25	31	29	50	55	61	55	47	37	25	21	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.8	13.5	16.7	22.7	25.0	29.1	30.4	30.6	25.2	20.9	17.0	12.7	(19)	
		MCWB	6.8	7.0	9.2	13.7	17.5	20.0	20.3	19.4	17.6	14.1	11.2	7.4	(20)	
	2%	DB	9.5	10.7	14.2	20.1	23.1	26.8	28.0	28.1	22.9	18.8	14.9	10.2	(21)	
		MCWB	5.8	5.9	8.4	12.6	16.5	19.6	19.7	19.4	17.0	13.4	10.0	6.4	(22)	
	5%	DB	7.4	9.0	12.2	17.8	21.3	24.7	26.0	26.1	20.9	16.8	13.1	8.6	(23)	
		MCWB	4.6	5.1	7.3	11.4	15.5	18.3	18.8	18.7	15.7	12.5	9.0	5.4	(24)	
	10%	DB	5.4	7.2	10.2	15.7	19.3	22.9	24.1	24.2	19.1	15.1	10.9	6.9	(25)	
		MCWB	3.2	4.1	6.4	10.2	14.2	17.2	18.0	17.9	14.9	11.7	7.9	4.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.7	8.0	10.1	14.6	18.9	21.6	21.9	21.6	18.9	15.4	11.8	8.2	(27)	
		MCDB	10.1	11.9	15.2	21.8	23.7	27.1	28.1	27.7	23.6	19.2	15.7	10.7	(28)	
	2%	WB	6.1	6.5	8.8	13.0	17.2	19.9	20.4	20.0	17.4	14.1	10.4	7.1	(29)	
		MCDB	9.0	9.9	13.2	19.0	22.0	25.6	26.5	26.3	21.8	17.4	14.3	9.7	(30)	
	5%	WB	4.8	5.4	7.7	11.7	15.8	18.6	19.3	19.0	16.2	13.1	9.3	5.9	(31)	
		MCDB	7.2	8.6	11.3	17.0	20.4	24.1	25.0	25.1	20.0	15.7	12.6	8.4	(32)	
	10%	WB	3.3	4.2	6.7	10.6	14.5	17.5	18.3	18.1	15.2	12.1	8.0	4.4	(33)	
		MCDB	5.2	7.1	9.9	15.1	18.9	22.3	23.5	23.6	18.6	14.7	10.5	6.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.4	5.0	5.9	7.3	7.3	7.6	7.7	7.8	6.4	5.9	4.7	4.6	(35)	
		MCDBR	6.4	7.6	9.2	10.0	10.1	10.3	10.7	10.7	9.1	8.2	7.6	7.5	(36)	
	5% WB	MCWBR	4.2	4.7	5.5	5.6	6.2	5.8	5.4	5.0	5.0	5.0	4.5	5.0	(37)	
		MCWBR	6.0	6.9	8.5	9.2	9.5	9.9	9.9	10.0	8.5	7.2	6.9	7.1	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.287	0.311	0.349	0.387	0.390	0.396	0.401	0.398	0.372	0.343	0.316	0.287	(40)	
		taud	2.418	2.373	2.328	2.277	2.307	2.320	2.304	2.329	2.379	2.446	2.474	2.459	(41)	
	Ebn at Noon		795	849	865	862	873	867	856	842	831	801	751	751	(42)	
		Edh at Noon	66	86	106	123	124	124	124	116	100	80	63	57	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.08	1.95	3.01	4.24	4.92	5.37	5.26	4.70	3.38	2.19	1.17	0.87	(44)	
	RadStd		0.14	0.25	0.36	0.48	0.56	0.44	0.49	0.50	0.43	0.23	0.14	0.11	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (100 neighbors)		+0.53	N/A	N/A	N/A	+0.43	+0.39	-116	-146	+79	+37

Nomenclature: See separate page