

FELDKIRCH, Austria

WMO: 111050

Lat: 47.271N

Lon: 9.610E

Elev: 1430

StdP: 13.95

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 14.7	(c) 18.4	(d) 11.4	(e) 10.4	(f) 16.5	(g) 14.9	(h) 12.4	(i) 20.7	(j) 12.3	(k) 44.3	(l) 10.2	(m) 41.3	(n) 2.1	(o) 20	(p) 0.435

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 16.0	(c) 86.1	(d) 69.8	(e) 82.7	(f) 68.3	(g) 79.6	(h) 67.1	(i) 71.3	(j) 83.5	(k) 69.5	(l) 80.5	(m) 68.0	(n) 78.0	(o) 4.0	(p) 0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.8	104.1	78.5	65.4	98.9	76.2	64.1	94.3	73.9	36.0	83.7	34.4	80.8	33.1	78.2	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.2	8.6	7.2	11.2	91.0	5.0	3.7	7.6	93.7	4.6	95.8	1.8	97.9	-1.8	100.6
			11.0	74.2	4.9	1.7	7.5	75.5	4.6	76.5	1.9	77.5	-1.7	78.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.4	32.4	35.9	43.0	50.4	58.2	64.7	67.0	66.2	58.4	51.7	41.3	34.8	
	DBStd	14.07	7.77	8.16	7.53	7.50	6.93	7.18	6.26	5.76	5.87	6.69	7.50	7.50	
	HDD50	2092	546	398	235	85	11	1	0	0	5	61	275	475	
	HDD65	5647	1010	816	681	438	231	93	51	55	212	412	711	937	
	CDD50	2243	1	2	19	98	264	441	528	503	256	114	14	3	
	CDD65	323	0	0	0	1	19	83	114	93	12	1	0	0	
	CDH74	2446	0	0	0	14	170	692	848	645	68	9	0	0	
	CDH80	612	0	0	0	1	26	193	233	155	4	0	0	0	
Wind	WSAvg	2.9	2.7	2.9	3.3	3.6	3.2	3.0	3.0	2.7	2.4	2.5	2.6	2.7	
Precipitation	PrecAvg	55.1	2.7	3.0	3.5	4.0	5.4	6.7	6.6	6.7	4.9	3.8	4.1	3.6	
	PrecMax	70.8	5.9	8.3	7.0	7.4	12.6	12.4	12.2	11.5	7.9	8.2	9.4	7.6	
	PrecMin	42.0	0.3	0.8	1.2	1.3	0.7	2.6	2.6	1.9	2.2	0.4	0.3	0.4	
	PrecStd	6.1	1.6	1.6	1.5	1.7	2.6	2.4	2.6	2.4	1.5	1.7	2.0	1.7	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.6	60.6	67.5	75.8	83.6	90.4	90.6	89.2	79.8	74.8	67.6	62.5	
		MCWB	46.7	48.1	53.1	58.1	65.4	69.9	72.2	71.3	66.7	58.3	52.3	48.2	
	2%	DB	49.0	55.2	63.0	72.0	78.8	85.2	86.0	84.3	76.0	68.9	61.9	51.8	
		MCWB	43.2	45.0	51.0	56.8	63.5	68.5	70.1	70.6	65.2	58.8	51.0	45.2	
	5%	DB	45.7	51.1	59.3	68.2	74.8	81.4	82.1	80.7	72.3	65.2	55.9	47.4	
		MCWB	41.6	43.7	49.2	55.6	61.3	67.5	68.7	68.7	63.3	57.1	49.4	43.6	
	10%	DB	42.3	47.2	55.4	64.0	71.1	77.8	78.7	77.4	68.8	62.0	51.2	44.4	
		MCWB	39.5	41.8	47.5	53.3	59.5	65.7	67.2	67.1	61.5	56.0	47.5	41.5	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.2	49.5	54.6	60.6	67.5	72.5	73.2	73.3	68.5	62.1	54.4	49.2
			MCDB	52.7	57.8	64.7	73.1	80.0	85.7	87.1	85.9	76.9	68.3	62.6	58.1
2%		WB	44.2	46.3	52.1	57.8	64.5	70.0	71.2	71.2	66.1	60.0	51.9	46.4	
		MCDB	48.0	53.1	61.2	69.6	76.0	82.0	83.8	82.5	73.7	65.7	59.1	51.7	
5%		WB	41.8	44.3	50.0	55.9	62.3	68.1	69.4	69.3	64.1	58.1	49.8	44.1	
		MCDB	45.0	50.1	57.6	66.7	72.6	79.5	80.7	79.2	70.8	63.5	55.5	47.1	
10%		WB	39.6	42.0	48.0	53.9	60.2	66.2	67.6	67.6	62.1	56.5	47.7	41.6	
		MCDB	42.2	46.9	54.6	62.9	69.4	76.7	77.4	76.5	67.8	61.3	51.3	44.1	
Mean Daily Temperature Range		5% DB	MDBR	9.9	13.1	15.9	16.9	16.5	16.1	16.0	15.6	15.1	14.3	11.2	9.8
			MCDBR	14.3	20.4	22.8	22.9	22.8	22.1	21.5	21.3	19.6	19.4	18.5	14.2
	MCWBR		9.3	12.4	13.4	12.2	11.6	10.7	10.4	11.3	11.0	11.1	10.6	8.9	
	5% WB	MCDBR	12.7	18.5	20.7	21.4	20.4	20.1	19.8	19.9	18.2	17.3	15.9	13.3	
		MCWBR	8.7	11.8	12.5	12.0	11.1	10.4	10.0	11.0	10.8	10.7	9.7	8.7	
Clear-Sky Solar Irradiance	taub	0.285	0.312	0.356	0.402	0.418	0.425	0.427	0.417	0.383	0.350	0.315	0.282		
	taud	2.367	2.290	2.246	2.208	2.229	2.258	2.255	2.298	2.371	2.443	2.462	2.404		
	Ebn at Noon	255	269	272	270	269	267	265	262	261	253	242	242		
	Edh at Noon	22	30	37	42	43	42	42	38	32	26	21	19		
All-Sky Solar Radiation	RadAvg	400	677	1057	1381	1564	1800	1754	1532	1157	741	424	330		
	RadStd	45	88	141	201	160	167	159	154	120	82	55	48		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (113 neighbors)	N/A	N/A	N/A	+1.19	+0.79	+0.67	N/A	N/A	+101	+25

Nomenclature: See separate page