

GALZIG, Austria

WMO: 111100

Lat: 47.1297N

Lon: 10.2303E

Elev: 6857

StdP: 11.40

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 1.7	(c) 5.1	(d) -8.3	(e) 4.5	(f) 18.8	(g) -3.7	(h) 5.8	(i) 18.1	(j) 42.3	(k) 20.5	(l) 38.7	(m) 20.4	(n) 12.6	(o) 80	(p) 0.832

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.7	66.8	54.0	63.9	52.9	61.4	51.8	56.3	63.1	54.6	61.3	53.1	59.5	10.6	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
53.5	78.8	58.6	51.8	74.0	57.2	50.3	69.9	55.8	27.0	63.9	25.8	61.5	24.8	59.7	69.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
32.3	27.9	24.4	-0.9	71.3	5.2	2.5	-4.7	73.1	-7.7	74.6	-10.7	76.0	-14.5	77.9
			-1.6	59.0	5.0	1.8	-5.3	60.3	-8.2	61.3	-11.0	62.3	-14.7	63.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	35.8	21.2	22.1	26.3	32.7	39.1	47.4	49.9	50.8	43.7	38.6	30.6	25.8		
	DBStd	13.21	8.32	9.30	8.74	7.89	8.20	8.33	7.29	7.14	7.38	8.92	9.35	8.73		
	HDD50	5496	891	781	733	520	348	145	95	80	209	360	582	752		
	HDD65	10671	1356	1201	1198	970	802	529	468	442	638	818	1032	1217		
	CDD50	300	0	0	0	0	10	66	92	104	21	7	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	11.3	13.7	13.1	13.2	11.2	11.1	10.0	10.5	9.6	9.8	10.1	11.0	12.4		
	PrecAvg	58.7	3.9	3.4	4.1	3.5	5.2	6.8	7.6	7.5	5.0	3.9	4.1	4.1		
(15) Precipitation	PrecMax	72.7	10.3	9.1	8.5	7.9	11.1	12.0	12.6	14.2	9.4	9.0	9.5	10.4		
	PrecMin	47.2	0.2	0.7	1.1	0.6	1.6	3.4	3.5	2.4	1.7	0.4	0.0	0.3		
	PrecStd	5.2	2.6	1.8	2.1	1.7	2.1	2.0	2.2	2.5	1.8	1.9	2.2	2.3		
	PrecStd	5.2	2.6	1.8	2.1	1.7	2.1	2.0	2.2	2.5	1.8	1.9	2.2	2.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.7	45.4	46.5	52.5	62.2	69.6	70.0	70.0	62.1	59.7	52.3	45.1		
		MCWB	33.0	31.6	34.8	41.3	47.5	53.9	55.2	55.1	50.8	47.4	40.6	32.5		
	2%	DB	39.7	41.1	42.9	49.2	57.8	65.5	66.1	66.6	58.9	55.3	48.0	41.7		
		MCWB	31.0	30.5	32.8	39.5	46.1	52.3	54.4	54.5	49.7	45.5	37.8	30.7		
	5%	DB	35.9	37.0	40.2	46.2	54.4	62.2	62.9	63.6	56.4	52.1	44.8	39.2		
		MCWB	28.6	29.3	32.1	38.1	44.8	51.8	53.0	53.3	48.6	42.9	36.2	30.2		
	10%	DB	32.5	33.7	37.8	43.6	51.0	59.1	60.2	61.0	53.7	49.7	42.2	37.0		
		MCWB	27.2	27.8	31.3	36.6	43.3	50.2	51.9	52.4	47.4	41.7	35.1	29.3		
	0.4%	WB	35.9	34.8	36.7	43.3	50.7	57.1	58.1	58.3	53.5	49.6	42.5	35.3		
		MCDB	39.8	39.1	42.5	49.7	57.8	64.4	64.9	64.1	59.4	56.0	49.5	40.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	32.5	32.1	34.9	40.9	47.9	54.3	56.1	56.4	51.5	46.5	39.5	33.6		
		MCDB	36.7	37.4	40.0	47.1	54.7	61.5	63.0	63.1	56.4	52.6	45.0	37.8		
	5%	WB	30.4	30.2	33.3	39.0	45.8	52.8	54.4	54.7	49.7	44.6	37.6	32.2		
		MCDB	33.8	36.0	38.3	44.9	52.4	59.8	60.9	61.6	54.4	50.2	42.8	36.3		
	10%	WB	28.3	28.3	31.8	37.0	43.9	51.3	52.8	53.1	48.0	42.9	35.9	30.6		
		MCDB	32.4	33.4	36.5	42.7	50.4	58.0	58.6	59.6	52.5	48.2	41.0	34.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.1	8.8	9.1	9.5	10.2	10.9	10.7	10.7	9.8	10.0	8.2	8.4		
		MCDBR	10.8	11.0	11.5	11.5	14.5	14.2	14.2	13.4	12.7	12.7	10.1	10.1		
		MCWBR	6.4	6.3	6.5	5.7	7.4	7.7	7.5	7.3	7.7	7.5	6.3	5.9		
		MCDBR	10.1	10.5	10.1	11.0	13.3	13.2	13.2	12.8	11.4	11.7	8.8	9.8		
	5% WB	MCWBR	7.9	7.2	6.1	6.2	7.3	8.2	8.0	7.9	7.4	7.6	6.2	7.1		
		MCWBR	7.9	7.2	6.1	6.2	7.3	8.2	8.0	7.9	7.4	7.6	6.2	7.1		
(40) Clear-Sky Solar Irradiance	taub		0.214	0.232	0.262	0.295	0.308	0.315	0.314	0.309	0.286	0.265	0.239	0.214		
	taud		2.423	2.380	2.371	2.415	2.465	2.478	2.472	2.507	2.564	2.601	2.568	2.465		
	Ebn at Noon		292	306	309	305	303	300	299	297	297	291	280	280		
	Edh at Noon		20	27	32	34	34	34	33	31	26	22	18	17		
(44) All-Sky Solar Radiation	RadAvg		446	739	1103	1385	1539	1751	1739	1528	1156	776	456	368		
	RadStd		51	90	134	192	168	161	154	154	127	91	68	50		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (104 neighbors)		+0.59	N/A	N/A	+1.17	+0.79	+0.70	N/A	N/A	+101	+25

Nomenclature: See separate page