

GALZIG, Austria

WMO: 111100

Lat: 47.1297N

Lon: 10.2303E

Elev: 2090

StdP: 78.61

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -16.8	(c) -15.0	(d) -22.4	(e) 0.6	(f) -7.3	(g) -19.9	(h) 0.8	(i) -7.7	(j) 18.9	(k) -6.4	(l) 17.3	(m) -6.5	(n) 5.6	(o) 80	(p) 0.832

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 6.0	(c) 19.3	(d) 12.2	(e) 17.7	(f) 11.6	(g) 16.3	(h) 11.0	(i) 13.5	(j) 17.3	(k) 12.5	(l) 16.3	(m) 11.7	(n) 15.3	(o) 4.7	(p) 280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 11.9	(b) 11.3	(c) 14.8	(d) 11.0	(e) 10.6	(f) 14.0	(g) 10.2	(h) 10.0	(i) 13.2	(j) 45.0	(k) 17.7	(l) 42.1	(m) 16.4	(n) 39.7	(o) 15.4	(p) 20.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.4	12.5	10.9	-18.3	21.9	2.9	1.4	-20.4	22.9	-22.1	23.7	-23.7	24.5	-25.8	25.5
			-18.7	15.0	2.8	1.0	-20.7	15.7	-22.3	16.3	-23.9	16.8	-25.9	17.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.1	-6.0	-5.5	-3.1	0.4	4.0	8.5	10.0	10.4	6.5	3.7	-0.8	-3.5		
	DBStd	7.34	4.62	5.17	4.86	4.38	4.56	4.63	4.05	3.97	4.10	4.95	5.19	4.85		
	HDD10.0	3053	495	434	407	289	193	81	53	44	116	200	323	418		
	HDD18.3	5928	753	667	666	539	446	294	260	246	354	454	573	676		
	CDD10.0	167	0	0	0	0	6	37	51	58	12	4	0	0		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	5.1	6.1	5.9	5.9	5.0	5.0	4.5	4.7	4.3	4.4	4.5	4.9	5.5		
(15) Precipitation	PrecAvg	1491	98	87	104	90	132	172	192	191	128	100	103	103		
	PrecMax	1847	261	231	215	201	283	306	319	360	240	229	241	264		
	PrecMin	1200	6	19	28	14	40	87	89	61	43	10	0	8		
	PrecStd	133	66	45	54	42	53	52	57	63	45	47	55	59		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.9	7.4	8.1	11.4	16.8	20.9	21.1	21.1	16.7	15.4	11.3	7.3		
		MCWB	0.5	-0.2	1.6	5.2	8.6	12.1	12.9	12.9	10.4	8.5	4.8	0.3		
	2%	DB	4.3	5.0	6.0	9.5	14.3	18.6	19.0	19.2	14.9	12.9	8.9	5.4		
		MCWB	-0.6	-0.8	0.5	4.2	7.9	11.3	12.4	12.5	9.8	7.5	3.2	-0.7		
	5%	DB	2.2	2.8	4.6	7.9	12.4	16.8	17.2	17.5	13.5	11.2	7.1	4.0		
		MCWB	-1.9	-1.5	0.0	3.4	7.1	11.0	11.6	11.8	9.2	6.0	2.3	-1.0		
	10%	DB	0.3	1.0	3.2	6.4	10.5	15.0	15.7	16.1	12.1	9.8	5.7	2.8		
		MCWB	-2.7	-2.4	-0.4	2.5	6.3	10.1	11.1	11.3	8.6	5.4	1.7	-1.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.2	1.5	2.6	6.3	10.4	14.0	14.5	14.6	11.9	9.8	5.8	1.8		
		MCDB	4.3	3.9	5.8	9.8	14.3	18.0	18.3	17.8	15.2	13.3	9.7	4.6		
	2%	WB	0.3	0.1	1.6	5.0	8.8	12.4	13.4	13.5	10.9	8.1	4.2	0.9		
		MCDB	2.6	3.0	4.5	8.4	12.6	16.4	17.2	17.3	13.5	11.5	7.2	3.2		
	5%	WB	-0.9	-1.0	0.7	3.9	7.7	11.5	12.5	12.6	9.8	7.0	3.1	0.1		
		MCDB	1.0	2.2	3.5	7.2	11.3	15.4	16.0	16.4	12.5	10.1	6.0	2.4		
	10%	WB	-2.1	-2.1	-0.1	2.8	6.6	10.7	11.6	11.7	8.9	6.0	2.2	-0.8		
		MCDB	0.2	0.8	2.5	6.0	10.2	14.5	14.8	15.4	11.4	9.0	5.0	1.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.5	4.9	5.1	5.3	5.7	6.0	6.0	6.0	5.4	5.5	4.5	4.6		
		MCDBR	6.0	6.1	6.4	6.4	8.0	7.9	7.9	7.5	7.0	7.1	5.6	5.6		
	5% WB	MCWBR	3.6	3.5	3.6	3.2	4.1	4.3	4.2	4.1	4.3	4.2	3.5	3.3		
		MCWBR	5.6	5.8	5.6	6.1	7.4	7.3	7.3	7.1	6.3	6.5	4.9	5.5		
(40) Clear-Sky Solar Irradiance	taub	taub	0.214	0.232	0.262	0.295	0.308	0.315	0.314	0.309	0.286	0.265	0.239	0.214		
		taud	2.423	2.380	2.371	2.415	2.465	2.478	2.472	2.507	2.564	2.601	2.568	2.465		
	Ebn at Noon	Ebn at Noon	921	964	973	963	956	947	943	937	937	916	884	883		
		Edh at Noon	64	84	101	107	106	106	105	97	83	68	56	55		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.41	2.33	3.48	4.37	4.85	5.52	5.48	4.82	3.64	2.45	1.44	1.16		
	RadStd	RadStd	0.16	0.28	0.42	0.60	0.53	0.51	0.48	0.49	0.40	0.29	0.21	0.16		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (104 neighbors)		+0.33	N/A	N/A	+0.65	+0.44	+0.39	N/A	N/A	+56	+14

Nomenclature: See separate page