

PATSCHERKOFEL, Austria

WMO: 111260

Lat: 47.2089N

Lon: 11.4622E

Elev: 7388

StdP: 11.17

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-0.8	3.2	-12.8	3.6	10.8	-7.1	4.9	14.6	69.4	25.0	63.3	23.2	8.7	320	0.929

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.6	63.7	52.8	61.2	51.7	59.0	50.8	54.8	60.4	53.3	58.9	51.9	57.3	10.3	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
52.6	77.8	57.2	50.8	72.8	55.6	49.4	68.9	54.3	26.2	60.5	25.1	59.1	24.2	57.5	68.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 58.1	49.2	41.3	-5.6	68.1	8.2	4.4	-11.5	71.3	-16.4	73.9	-21.0	76.4	-27.0	79.6		
(5)			-4.9	57.9	5.5	3.5	-8.9	60.4	-12.1	62.5	-15.1	64.4	-19.1	67.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	33.8	19.8	19.1	23.9	30.8	37.4	45.5	48.4	48.9	42.2	36.7	28.7	23.2	(6)
(7)		DBStd	13.25	8.12	9.23	8.50	7.80	7.81	7.96	7.29	6.77	7.22	8.26	9.12	8.64	(7)
(8)		HDD50	6106	935	866	808	577	395	177	114	103	244	416	640	831	(8)
(9)		HDD65	11389	1400	1286	1273	1027	855	586	516	498	683	879	1090	1296	(9)
(10)		CDD50	192	0	0	0	0	5	41	63	70	11	2	0	0	(10)
(11)		CDD65	1	0	0	0	0	0	0	1	0	0	0	0	0	(11)
(12)		CDH74	3	0	0	0	0	0	0	3	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	14.5	16.3	16.0	14.3	16.5	13.3	11.2	10.7	11.3	11.5	17.1	19.1	16.9	(14)
(15)	Precipitation	PrecAvg	38.9	1.7	1.6	2.1	2.5	3.7	5.1	5.4	5.4	3.5	3.2	2.9	1.9	(15)
(16)		PrecMax	51.1	3.7	5.3	5.7	4.8	6.6	8.0	8.9	8.9	5.8	6.4	7.6	5.2	(16)
(17)		PrecMin	31.0	0.2	0.4	0.6	0.4	0.6	2.7	2.7	1.8	1.3	0.1	0.1	0.0	(17)
(18)		PrecStd	5.0	0.9	1.1	1.1	1.1	1.5	1.3	1.5	1.6	1.2	1.6	1.7	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.2	42.1	44.1	50.4	59.0	66.7	68.4	66.5	60.1	55.8	48.0	42.5	(19)
(20)			MCWB	32.4	30.1	32.6	40.2	46.9	51.8	58.8	52.5	49.9	43.2	38.0	30.8	(20)
(21)		2%	DB	36.9	37.8	40.6	46.7	55.2	62.3	63.5	63.5	56.8	52.4	45.5	39.6	(21)
(22)			MCWB	30.2	28.4	32.2	39.0	46.4	51.6	53.7	52.3	48.0	41.5	35.9	29.3	(22)
(23)		5%	DB	33.9	34.6	37.8	43.8	51.6	59.4	60.6	60.9	54.2	49.7	42.8	37.1	(23)
(24)			MCWB	28.1	27.4	30.6	37.8	44.6	50.9	52.4	51.4	47.0	41.1	34.4	27.9	(24)
(25)		10%	DB	30.8	30.8	35.1	41.0	48.2	56.5	58.0	58.5	51.8	46.9	40.0	34.4	(25)
(26)			MCWB	26.6	26.2	29.7	36.3	42.8	49.6	51.2	50.7	45.8	40.2	33.1	27.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	34.7	32.3	36.6	42.2	49.7	55.5	59.3	56.2	52.6	47.3	41.5	33.8	(27)
(28)			MCD B	37.3	37.3	40.4	47.2	54.1	61.2	66.1	62.2	56.0	50.3	46.0	37.0	(28)
(29)		2%	WB	31.7	30.3	33.7	40.3	47.2	53.7	55.4	54.0	50.2	44.9	38.3	32.0	(29)
(30)			MCD B	35.0	34.3	37.9	44.9	52.8	59.3	60.9	60.0	54.5	48.7	42.6	34.9	(30)
(31)		5%	WB	29.4	28.5	31.9	38.7	45.1	52.0	53.6	52.7	48.2	42.9	36.1	30.5	(31)
(32)			MCD B	32.8	33.4	35.9	42.8	50.6	57.5	59.1	58.6	52.6	47.0	39.6	33.8	(32)
(33)		10%	WB	27.4	26.4	30.4	36.7	43.3	50.3	51.9	51.3	46.7	41.3	34.6	29.0	(33)
(34)			MCD B	30.3	30.4	34.0	40.7	47.8	55.6	57.0	57.2	50.8	45.7	37.8	32.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.5	7.6	8.0	8.0	8.8	9.8	10.4	9.6	8.3	7.9	7.1	7.6	(35)
(36)			MCDBR	10.6	9.3	9.9	10.0	12.1	13.1	12.7	11.5	10.7	9.9	8.3	9.4	(36)
(37)			MCWBR	7.1	5.5	6.1	5.6	6.5	6.9	6.7	6.0	6.3	6.2	5.1	5.6	(37)
(38)		5% WB	MCD BR	9.7	9.2	8.9	9.1	11.1	12.2	12.1	11.0	9.3	8.7	7.4	8.3	(38)
(39)			MCWBR	8.0	7.0	6.1	5.6	6.6	7.1	7.1	6.7	6.0	5.9	5.5	6.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.216	0.234	0.264	0.296	0.308	0.315	0.314	0.309	0.285	0.266	0.241	0.216	(40)	
(41)		taud	2.457	2.414	2.418	2.452	2.474	2.484	2.478	2.510	2.570	2.605	2.588	2.507	(41)	
(42)		Ebn at Noon	292	305	308	305	303	300	299	297	298	290	280	280	(42)	
(43)		Edh at Noon	20	26	30	33	33	33	33	31	26	22	17	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	448	745	1097	1376	1529	1724	1720	1518	1142	782	459	370	(44)	
(45)		RadStd	52	90	125	184	173	164	155	158	132	92	70	50	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (89 neighbors)	+0.67	N/A	N/A	+1.13	+0.77	+0.76	N/A	N/A	+108	+22

Nomenclature: See separate page