

KUFSTEIN, Austria

WMO: 111300

Lat: 47.575N

Lon: 12.163E

Elev: 1613

StdP: 13.86

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.4	15.8	7.9	8.7	11.9	12.3	10.9	16.4	11.8	33.7	10.1	31.9	2.6	200	0.480

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.9	86.4	68.8	83.1	67.1	80.0	65.7	69.9	83.7	68.3	80.7	66.7	77.7	5.5	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.1	98.6	75.6	63.7	93.8	73.4	62.5	89.8	71.5	34.8	83.7	33.4	81.1	32.1	78.0	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.1	9.3	8.0	DB	6.8	92.5	5.2	3.2	3.1	94.8	0.1	96.7	-2.8	98.5	-6.6	100.8	(4)
(5)			WB	6.3	72.8	5.1	1.9	2.6	74.2	-0.4	75.4	-3.2	76.4	-7.0	77.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.2	30.3	33.8	41.5	49.7	57.6	63.5	66.3	65.9	58.0	50.6	40.2	32.4
	DBStd	14.47	6.97	7.51	7.35	7.51	6.85	7.11	6.09	5.97	6.14	6.59	7.31	6.80
	HDD50	2386	609	454	274	97	15	2	0	1	8	75	304	547
	HDD65	6040	1074	874	729	461	245	113	58	61	222	447	745	1011
	CDD50	2102	0	0	10	86	250	405	506	495	247	93	9	1
	CDD65	283	0	0	0	1	15	66	99	91	11	0	0	0
	CDH74	2439	0	0	0	23	190	602	821	720	80	3	0	0
	CDH80	666	0	0	0	2	36	172	248	201	7	0	0	0
Wind	WSAvg	3.6	3.5	3.6	3.8	4.0	3.9	3.8	3.7	3.6	3.4	3.5	3.4	3.4
Precipitation	PrecAvg	57.2	3.6	3.3	4.3	3.7	5.6	7.2	7.0	7.1	5.1	3.5	3.5	3.3
	PrecMax	69.4	8.7	9.4	10.6	7.0	10.6	11.1	12.9	12.0	10.3	6.5	7.6	6.5
	PrecMin	45.2	0.5	0.5	1.8	0.0	0.7	3.8	1.4	3.6	2.7	0.9	0.0	0.6
	PrecStd	6.2	2.0	2.0	2.0	1.9	2.3	2.0	2.6	2.2	2.0	1.6	2.0	1.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.2	57.3	67.3	76.9	84.4	89.4	91.1	90.2	80.3	72.2	66.1	54.7
		MCWB	43.5	46.2	52.2	59.0	64.5	69.2	71.2	69.7	65.9	60.1	52.7	46.0
	2%	DB	44.0	50.7	62.1	72.5	79.4	84.9	86.2	85.2	76.2	67.6	57.7	45.8
		MCWB	39.9	42.7	49.9	56.6	62.9	67.6	69.2	69.0	64.0	57.9	49.9	42.6
	5%	DB	41.0	46.3	57.7	68.2	74.9	81.2	82.5	81.7	72.3	63.8	52.8	42.8
		MCWB	38.3	40.4	47.6	54.2	60.3	65.9	67.6	67.3	62.1	56.1	47.9	40.7
	10%	DB	38.5	42.7	53.0	64.0	70.8	77.1	78.6	77.9	68.7	60.1	49.3	40.1
		MCWB	36.4	38.8	45.3	52.2	58.4	64.1	65.6	65.7	60.4	54.4	46.0	38.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.1	46.7	53.2	60.0	66.8	71.1	72.6	71.7	67.2	61.2	53.3	46.3
		MCDB	47.9	55.0	64.8	74.9	81.9	85.4	87.8	86.7	77.2	68.9	62.9	52.7
	2%	WB	40.4	43.5	50.5	57.3	63.6	68.9	69.9	69.6	64.8	58.9	50.6	43.0
		MCDB	43.0	49.5	60.1	70.5	76.4	82.1	83.5	83.2	74.0	65.1	56.4	45.2
	5%	WB	38.5	41.1	48.3	54.9	61.3	66.8	68.1	67.9	63.0	56.9	48.4	40.9
		MCDB	40.9	45.5	56.1	66.4	72.4	78.8	80.4	79.9	71.0	62.2	52.4	42.8
	10%	WB	36.7	39.0	46.1	52.7	59.4	64.8	66.4	66.3	61.2	55.1	46.2	38.4
		MCDB	38.4	42.5	52.0	62.5	69.0	74.8	76.6	76.7	67.4	59.7	49.3	39.9
Mean Daily Temperature Range	5% DB	MDBR	9.6	12.3	16.2	18.5	18.3	17.8	17.9	17.8	15.8	14.8	10.7	8.7
		MCDBR	11.8	19.2	25.7	27.5	26.8	26.3	25.4	24.8	22.3	20.5	17.5	12.1
		MCWBR	8.3	11.7	14.2	13.6	11.9	10.7	10.3	10.3	11.3	11.6	10.5	8.5
	5% WB	MCDBR	10.6	17.4	23.5	25.5	23.9	23.2	23.2	23.3	20.5	18.7	16.3	11.4
		MCWBR	7.7	11.1	13.4	13.1	11.2	10.0	9.9	10.2	10.6	10.8	9.9	8.2
Clear-Sky Solar Irradiance	taub		0.298	0.327	0.372	0.413	0.427	0.433	0.433	0.426	0.391	0.358	0.325	0.296
	taud		2.377	2.279	2.218	2.182	2.204	2.238	2.240	2.277	2.346	2.411	2.436	2.424
	Ebn at Noon		248	262	266	266	266	265	263	259	258	249	235	235
	Edh at Noon		22	30	38	43	44	43	42	39	33	27	21	19
All-Sky Solar Radiation	RadAvg		403	700	1017	1318	1497	1662	1669	1484	1086	754	423	327
	RadStd		50	88	118	168	177	174	164	173	142	81	66	50

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.01	N/A	N/A	+1.19	+0.72	N/A	-275	-353	+180	+104
(47)	Regional (88 neighbors)	+0.72	N/A	N/A	N/A	+0.63	+0.67	N/A	N/A	+106	+36

Nomenclature: See separate page