

KUFSTEIN, Austria

WMO: 111300

Lat: 47.575N

Lon: 12.163E

Elev: 492

StdP: 95.56

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.4	-9.0	-13.4	1.2	-11.2	-10.9	1.6	-8.6	5.3	1.0	4.5	0.0	1.2	200	0.480

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	30.2	20.4	28.4	19.5	26.7	18.7	21.0	28.7	20.1	27.1	19.3	25.4	2.5	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.4	14.1	24.2	17.6	13.4	23.0	17.0	12.8	21.9	63.1	28.7	59.9	27.3	56.9	25.6	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.5	4.2	3.6	-14.0	33.6	2.9	1.8	-16.1	34.9	-17.7	35.9	-19.4	36.9	-21.4	38.2		
(5)			-14.3	22.7	2.8	1.1	-16.3	23.5	-18.0	24.1	-19.6	24.7	-21.7	25.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	-0.9	1.0	5.3	9.8	14.2	17.5	19.1	18.9	14.4	10.3	4.5	0.2		
	DBStd	8.04	3.87	4.17	4.08	4.17	3.81	3.95	3.38	3.32	3.41	3.66	4.06	3.78		
	HDD10.0	1326	338	252	152	54	8	1	0	1	4	42	169	304		
	HDD18.3	3356	597	486	405	256	136	63	32	34	123	248	414	562		
	CDD10.0	1168	0	0	6	48	139	225	281	275	137	52	5	1		
	CDD18.3	157	0	0	0	1	8	37	55	51	6	0	0	0		
	CDH23.3	1355	0	0	0	13	106	334	456	400	44	2	0	0		
	CDH26.7	370	0	0	0	1	20	96	138	112	4	0	0	0		
(14) Wind	WSAvg	1.6	1.6	1.6	1.7	1.8	1.7	1.7	1.7	1.6	1.5	1.6	1.5	1.5		
(15) Precipitation	PrecAvg	1453	91	84	109	93	141	182	179	180	129	90	89	85		
	PrecMax	1763	222	240	270	177	269	283	327	306	261	165	193	165		
	PrecMin	1148	12	12	45	0	17	96	35	91	69	22	0	14		
	PrecStd	157	52	51	52	47	58	51	67	56	50	40	50	41		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.5	14.1	19.6	24.9	29.1	31.9	32.8	32.4	26.8	22.4	18.9	12.6		
		MCWB	6.4	7.9	11.2	15.0	18.0	20.7	21.8	21.0	18.8	15.6	11.5	7.8		
	2%	DB	6.7	10.4	16.7	22.5	26.3	29.4	30.1	29.6	24.6	19.8	14.3	7.7		
		MCWB	4.4	5.9	9.9	13.6	17.2	19.8	20.7	20.6	17.8	14.4	9.9	5.9		
	5%	DB	5.0	8.0	14.3	20.1	23.8	27.3	28.0	27.6	22.4	17.7	11.5	6.0		
		MCWB	3.5	4.7	8.7	12.4	15.7	18.8	19.8	19.6	16.7	13.4	8.8	4.8		
	10%	DB	3.6	5.9	11.7	17.8	21.6	25.0	25.9	25.5	20.4	15.6	9.6	4.5		
		MCWB	2.5	3.8	7.4	11.2	14.7	17.8	18.7	18.7	15.8	12.4	7.8	3.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.7	8.2	11.8	15.6	19.3	21.7	22.6	22.1	19.5	16.2	11.8	7.9		
		MCDB	8.8	12.8	18.2	23.8	27.7	29.7	31.0	30.4	25.1	20.5	17.2	11.5		
	2%	WB	4.6	6.4	10.3	14.0	17.6	20.5	21.0	20.9	18.2	14.9	10.3	6.1		
		MCDB	6.1	9.7	15.6	21.4	24.7	27.8	28.6	28.4	23.3	18.4	13.6	7.4		
	5%	WB	3.6	5.0	9.1	12.7	16.3	19.3	20.1	20.0	17.2	13.8	9.1	4.9		
		MCDB	4.9	7.5	13.4	19.1	22.4	26.0	26.9	26.6	21.6	16.8	11.3	6.0		
	10%	WB	2.6	3.9	7.8	11.5	15.2	18.2	19.1	19.0	16.2	12.8	7.9	3.6		
		MCDB	3.5	5.8	11.1	16.9	20.5	23.8	24.8	24.8	19.7	15.4	9.6	4.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	6.8	9.0	10.3	10.2	9.9	9.9	9.9	8.8	8.2	6.0	4.8		
		MCDBR	6.6	10.6	14.3	15.3	14.9	14.6	14.1	13.8	12.4	11.4	9.7	6.7		
	5% WB	MCWBR	4.6	6.5	7.9	7.6	6.6	5.9	5.7	5.7	6.3	6.4	5.8	4.7		
		MCWBR	5.9	9.7	13.1	14.2	13.3	12.9	12.9	13.0	11.4	10.4	9.1	6.3		
(40) Clear-Sky Solar Irradiance	taub		0.298	0.327	0.372	0.413	0.427	0.433	0.433	0.426	0.391	0.358	0.325	0.296		
		taud	2.377	2.279	2.218	2.182	2.204	2.238	2.240	2.277	2.346	2.411	2.436	2.424		
	Ebn at Noon		781	826	838	837	839	834	828	817	812	784	742	740		
		Edh at Noon	70	95	119	136	138	135	133	123	104	84	67	60		
(44) All-Sky Solar Radiation	RadAvg		1.27	2.21	3.21	4.16	4.72	5.24	5.26	4.68	3.42	2.38	1.33	1.03		
	RadStd		0.16	0.28	0.37	0.53	0.56	0.55	0.52	0.55	0.45	0.26	0.21	0.16		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.56	N/A	N/A	+0.66	+0.40	N/A	-153	-196	+100	+58
(47) Regional (88 neighbors)		+0.40	N/A	N/A	N/A	+0.35	+0.37	N/A	N/A	+59	+20

Nomenclature: See separate page