

KRIMML, Austria

WMO: 111360

Lat: 47.229N

Lon: 12.182E

Elev: 3316

StdP: 13.02

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.1	11.7	4.2	7.7	9.6	7.6	9.2	13.1	9.0	40.7	6.6	36.9	1.7	310	0.528

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.5	81.4	63.2	78.1	62.0	74.8	60.9	65.5	76.5	63.8	74.2	62.4	71.9	3.7	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.9	93.8	69.0	60.3	88.4	67.4	58.9	83.9	65.5	32.3	76.5	30.9	74.7	29.7	72.2	72.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	6.8	5.2	DB	4.0	88.2	5.2	2.4	0.2	90.0	-2.8	91.4	-5.8	92.8	-9.6	94.5	(4)
(5)			WB	3.1	69.0	5.0	2.1	-0.5	70.5	-3.4	71.7	-6.2	72.9	-9.9	74.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	45.0	25.8	29.9	37.6	45.4	52.8	58.9	61.5	61.3	54.0	46.5	36.1	28.9	(6)
(7)		DBStd	14.28	7.01	7.68	7.29	7.17	6.85	7.18	6.36	6.04	6.14	6.88	7.79	7.08	(7)
(8)		HDD50	3189	749	563	384	169	51	13	2	2	32	147	422	655	(8)
(9)		HDD65	7402	1214	983	849	589	381	204	143	145	332	574	868	1120	(9)
(10)		CDD50	1352	0	0	1	31	137	280	358	352	151	38	4	0	(10)
(11)		CDD65	86	0	0	0	0	2	21	33	29	1	0	0	0	(11)
(12)		CDH74	849	0	0	0	1	43	239	308	242	16	0	0	0	(12)
(13)		CDH80	151	0	0	0	0	3	44	59	44	1	0	0	0	(13)
(14)	Wind	WSAvg	2.1	1.7	2.0	2.2	2.6	2.4	2.2	2.1	1.8	2.0	1.9	1.8	(14)	
(15)	Precipitation	PrecAvg	42.8	1.8	1.7	2.3	2.8	4.0	5.7	6.3	5.9	3.9	3.4	2.9	2.0	(15)
(16)		PrecMax	51.0	3.9	4.5	6.1	5.7	6.1	8.1	8.7	9.2	6.0	6.7	6.6	4.5	(16)
(17)		PrecMin	37.0	0.2	0.3	0.7	0.2	0.9	3.0	2.4	3.4	1.8	0.2	0.0	0.2	(17)
(18)		PrecStd	3.8	0.9	1.0	1.1	1.3	1.5	1.3	1.5	1.5	1.1	1.7	1.5	1.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.2	51.9	61.9	70.5	79.1	85.3	85.5	84.8	76.5	68.4	61.3	53.8	(19)
(20)			MCWB	40.5	41.1	46.6	53.6	59.5	62.8	65.0	65.0	60.9	54.3	48.4	42.4	(20)
(21)		2%	DB	40.5	47.2	57.9	66.3	74.0	80.4	81.0	80.4	71.7	64.2	56.8	44.8	(21)
(22)			MCWB	36.4	38.8	44.9	50.4	57.0	61.6	63.8	63.8	58.5	52.9	46.0	39.2	(22)
(23)		5%	DB	36.4	43.4	53.6	62.8	69.6	76.5	77.3	76.4	68.1	60.1	50.2	39.3	(23)
(24)			MCWB	34.4	36.8	42.6	48.7	54.9	60.3	62.5	62.5	57.0	51.2	44.6	37.0	(24)
(25)		10%	DB	34.1	39.4	49.2	59.0	65.9	72.3	73.5	72.5	64.5	56.3	45.8	36.2	(25)
(26)			MCWB	32.7	35.0	40.4	47.1	53.2	59.3	61.5	61.2	55.3	49.9	42.9	34.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.7	42.3	47.9	54.4	61.1	66.4	67.5	67.8	62.9	56.3	50.6	43.3	(27)
(28)			MCD B	47.6	49.5	59.4	69.3	74.9	77.0	78.4	80.0	71.2	63.4	59.0	50.4	(28)
(29)		2%	WB	36.9	39.5	45.5	51.7	58.4	63.8	65.6	65.4	60.4	54.1	47.0	40.3	(29)
(30)			MCD B	40.0	45.9	55.8	63.9	70.4	75.7	76.9	76.1	68.5	60.6	53.1	45.0	(30)
(31)		5%	WB	34.7	37.4	43.4	49.6	56.3	62.0	63.9	63.6	58.3	52.5	45.2	37.1	(31)
(32)			MCD B	36.3	42.2	51.7	60.5	66.9	72.9	74.1	73.2	65.3	58.3	50.4	38.9	(32)
(33)		10%	WB	33.0	35.4	41.4	47.7	54.2	60.3	62.4	62.0	56.5	50.9	42.9	34.8	(33)
(34)			MCD B	34.1	38.9	48.1	57.3	63.5	69.8	71.5	70.7	62.4	55.6	46.2	36.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.9	13.2	17.3	18.5	18.8	18.7	18.5	18.1	16.7	15.4	10.9	9.2	(35)
(36)			MCDBR	12.0	18.2	25.0	25.6	26.4	27.0	25.8	25.0	23.0	20.4	17.5	13.1	(36)
(37)			MCWBR	8.5	11.3	13.2	11.8	11.3	11.0	10.7	10.8	11.3	10.8	9.8	9.0	(37)
(38)		5% WB	MCD BR	11.2	16.4	23.1	23.4	24.2	23.8	22.9	22.8	20.0	18.1	15.0	12.1	(38)
(39)			MCWBR	8.3	10.3	12.4	11.0	11.0	10.9	10.5	11.1	10.7	10.1	9.1	8.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.256	0.280	0.320	0.358	0.372	0.381	0.379	0.373	0.341	0.315	0.286	0.257	(40)	
(41)		taud	2.400	2.332	2.312	2.319	2.341	2.357	2.358	2.393	2.462	2.511	2.517	2.457	(41)	
(42)		Ebn at Noon	269	283	286	284	283	280	279	276	276	268	256	257	(42)	
(43)		Edh at Noon	21	29	34	38	38	38	37	35	30	24	19	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	431	724	1054	1330	1512	1686	1706	1510	1118	771	442	355	(44)	
(45)		RadStd	51	91	124	172	179	165	156	168	140	86	73	52	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (88 neighbors)		+0.74	N/A	N/A	N/A	+0.68	+0.68	N/A	N/A	+112	+34

Nomenclature: See separate page