

KRIMML, Austria

WMO: 111360

Lat: 47.229N

Lon: 12.182E

Elev: 1011

StdP: 89.76

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.3	-11.3	-15.4	1.1	-12.4	-13.6	1.3	-10.5	4.0	4.9	3.0	2.7	0.7	310	0.528

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	27.5	17.3	25.6	16.7	23.8	16.0	18.6	24.7	17.7	23.4	16.9	22.1	1.7	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.6	13.4	20.5	15.7	12.6	19.7	14.9	12.0	18.6	57.2	24.7	54.0	23.7	51.3	22.4	22.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.1	3.0	2.3	-15.6	31.2	2.9	1.3	-17.6	32.2	-19.4	33.0	-21.0	33.8	-23.1	34.7		
(5)			-16.1	20.6	2.8	1.2	-18.1	21.4	-19.7	22.1	-21.2	22.7	-23.3	23.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.2	-3.4	-1.2	3.1	7.4	11.5	14.9	16.4	16.3	12.2	8.1	2.3	-1.7		
	DBStd	7.93	3.89	4.27	4.05	3.98	3.81	3.99	3.53	3.36	3.41	3.82	4.33	3.93		
	HDD10.0	1772	416	313	213	94	28	7	1	1	18	82	234	364		
	HDD18.3	4112	674	546	472	327	212	113	79	81	184	319	482	622		
	CDD10.0	751	0	0	1	17	76	156	199	196	84	21	2	0		
	CDD18.3	48	0	0	0	0	1	12	18	16	1	0	0	0		
	CDH23.3	472	0	0	0	1	24	133	171	134	9	0	0	0		
	CDH26.7	84	0	0	0	0	2	24	33	24	1	0	0	0		
(14) Wind	WSAvg	0.9	0.8	0.9	1.0	1.2	1.1	1.0	1.0	0.9	0.8	0.9	0.9	0.8		
(15) Precipitation	PrecAvg	1087	46	42	58	71	102	144	161	150	99	87	74	51		
	PrecMax	1295	98	114	154	144	155	205	222	234	152	170	167	115		
	PrecMin	941	5	7	18	6	23	75	61	87	46	4	0	4		
	PrecStd	96	24	26	28	34	37	34	37	38	27	42	37	26		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.0	11.0	16.6	21.4	26.2	29.6	29.7	29.3	24.7	20.2	16.3	12.1		
		MCWB	4.7	5.1	8.1	12.0	15.3	17.1	18.3	18.4	16.0	12.4	9.1	5.8		
	2%	DB	4.7	8.4	14.4	19.0	23.3	26.9	27.2	26.9	22.0	17.9	13.8	7.1		
		MCWB	2.4	3.8	7.2	10.2	13.9	16.4	17.7	17.7	14.7	11.6	7.8	4.0		
	5%	DB	2.5	6.4	12.0	17.1	20.9	24.7	25.2	24.6	20.1	15.6	10.1	4.1		
		MCWB	1.3	2.7	5.9	9.3	12.7	15.7	16.9	17.0	13.9	10.7	7.0	2.8		
	10%	DB	1.2	4.1	9.5	15.0	18.8	22.4	23.1	22.5	18.1	13.5	7.7	2.3		
		MCWB	0.4	1.7	4.7	8.4	11.8	15.2	16.4	16.2	13.0	10.0	6.0	1.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.4	5.7	8.9	12.4	16.2	19.1	19.7	19.9	17.2	13.5	10.3	6.3		
		MCDB	8.6	9.7	15.2	20.7	23.8	25.0	25.8	26.6	21.8	17.4	15.0	10.2		
	2%	WB	2.7	4.1	7.5	11.0	14.6	17.7	18.7	18.5	15.8	12.3	8.3	4.6		
		MCDB	4.5	7.7	13.2	17.7	21.3	24.3	24.9	24.5	20.3	15.9	11.7	7.2		
	5%	WB	1.5	3.0	6.3	9.8	13.5	16.7	17.7	17.5	14.6	11.4	7.3	2.8		
		MCDB	2.4	5.6	11.0	15.8	19.4	22.7	23.4	22.9	18.5	14.6	10.2	3.8		
	10%	WB	0.5	1.9	5.2	8.7	12.3	15.7	16.9	16.7	13.6	10.5	6.1	1.5		
		MCDB	1.1	3.8	9.0	14.0	17.5	21.0	22.0	21.5	16.9	13.1	7.9	2.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.5	7.3	9.6	10.3	10.4	10.4	10.3	10.1	9.3	8.6	6.1	5.1		
		MCDBR	6.7	10.1	13.9	14.2	14.7	15.0	14.3	13.9	12.8	11.3	9.7	7.3		
	5% WB	MCWBR	4.7	6.3	7.3	6.6	6.3	6.1	6.0	6.0	6.3	6.0	5.5	5.0		
		MCWBR	6.2	9.1	12.8	13.0	13.5	13.2	12.7	12.7	11.1	10.0	8.4	6.7		
(40) Clear-Sky Solar Irradiance	taub	taub	0.256	0.280	0.320	0.358	0.372	0.381	0.379	0.373	0.341	0.315	0.286	0.257		
		taud	2.400	2.332	2.312	2.319	2.341	2.357	2.358	2.393	2.462	2.511	2.517	2.457		
	Ebn at Noon	Ebn at Noon	849	892	901	895	892	883	879	870	871	845	808	809		
		Edh at Noon	67	90	108	119	121	119	118	109	93	76	61	57		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.36	2.28	3.32	4.19	4.76	5.32	5.38	4.76	3.53	2.43	1.39	1.12		
	RadStd	RadStd	0.16	0.29	0.39	0.54	0.56	0.52	0.49	0.53	0.44	0.27	0.23	0.17		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (88 neighbors)		+0.41	N/A	N/A	N/A	+0.38	+0.38	N/A	N/A	+62	+19	

Nomenclature: See separate page