

BISCHOFSHOFEN, Austria

WMO: 111410

Lat: 47.407N

Lon: 13.221E

Elev: 1797

StdP: 13.77

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 9.8	(c) 13.4	(d) 6.7	(e) 8.3	(f) 10.8	(g) 10.4	(h) 10.0	(i) 14.4	(j) 11.4	(k) 30.3	(l) 9.8	(m) 30.1	(n) 2.5	(o) 160	(p) 0.509

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 18.7	(c) 85.6	(d) 66.8	(e) 82.1	(f) 65.5	(g) 78.8	(h) 64.1	(i) 68.3	(j) 81.7	(k) 66.8	(l) 78.8	(m) 65.4	(n) 75.9	(o) 6.6	(p) 10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 64.2	(b) 96.1	(c) 71.7	(d) 62.8	(e) 91.3	(f) 70.4	(g) 61.5	(h) 87.3	(i) 68.9	(j) 33.6	(k) 81.9	(l) 32.3	(m) 78.8	(n) 31.2	(o) 76.2	(p) 78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 13.2	(b) 11.1	(c) 9.2	(e) 5.7	(f) 92.6	(g) 5.7	(h) 2.8	(i) 1.6	(j) 94.5	(k) -1.8	(l) 96.2	(m) -5.0	(n) 97.7	(o) -9.2	(p) 99.7		
(a) 13.2	(b) 11.1	(c) 9.2	(e) 5.0	(f) 72.0	(g) 5.4	(h) 1.9	(i) 1.1	(j) 73.4	(k) -2.0	(l) 74.5	(m) -5.0	(n) 75.6	(o) -8.9	(p) 77.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.1	27.8	32.3	40.7	49.5	56.7	62.4	65.3	64.8	57.4	49.7	38.7	30.4		
	DBStd	14.60	6.74	6.69	6.84	6.99	6.37	6.81	5.95	5.70	5.77	6.20	6.66	6.24		
	HDD50	2631	687	495	293	93	16	3	0	1	9	83	342	609		
	HDD65	6393	1152	915	753	466	265	126	70	74	233	476	789	1074		
	CDD50	1924	0	0	4	77	223	376	476	459	232	73	4	0		
	CDD65	211	0	0	0	0	7	50	81	67	6	0	0	0		
	CDH74	1980	0	0	0	20	147	520	684	549	59	1	0	0		
	CDH80	526	0	0	0	2	22	144	204	149	5	0	0	0		
	WSAvg	3.2	2.8	3.1	3.5	3.9	3.8	3.8	3.5	3.2	2.9	2.9	2.7	2.6		
	PrecAvg	52.8	2.8	2.7	3.7	3.3	5.0	6.5	7.3	6.7	4.9	3.6	3.3	3.0		
(15) Precipitation	PrecMax	61.1	6.4	7.2	7.8	5.7	7.2	9.4	11.1	9.7	7.8	5.9	6.5	8.5		
	PrecMin	43.3	0.4	0.8	1.5	0.9	1.1	4.4	3.6	4.1	2.3	0.8	0.5	0.9		
	PrecStd	4.1	1.5	1.6	1.7	1.3	1.7	1.4	2.0	1.4	1.5	1.5	1.3	1.5		
	PrecStd	4.1	1.5	1.6	1.7	1.3	1.7	1.4	2.0	1.4	1.5	1.5	1.3	1.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.1	53.0	66.2	76.6	83.2	88.8	90.1	88.6	79.7	71.3	64.1	46.7		
		MCWB	40.6	43.1	49.9	56.5	62.8	67.2	68.4	67.4	64.0	59.0	51.2	42.9		
	2%	DB	39.5	47.2	61.1	71.9	78.3	84.2	85.5	84.4	75.2	66.5	54.3	41.9		
		MCWB	37.2	40.1	48.1	54.5	60.6	65.8	67.4	66.9	62.0	56.6	48.2	40.0		
	5%	DB	37.3	43.2	56.3	67.6	74.2	80.3	81.5	80.3	71.4	62.8	50.2	39.4		
		MCWB	35.5	37.9	45.9	52.7	58.7	64.1	66.0	65.6	60.6	54.5	46.0	37.8		
	10%	DB	35.5	40.2	51.5	63.4	70.0	76.0	77.4	76.2	67.6	59.1	46.9	37.5		
		MCWB	34.3	36.7	43.8	50.7	56.7	62.7	64.4	64.1	58.9	53.0	44.2	36.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.0	44.3	51.4	58.0	64.7	69.6	70.9	70.0	65.7	60.1	52.1	43.4		
		MCDB	43.2	51.4	63.0	73.9	79.0	84.2	84.4	83.8	75.7	68.3	61.3	46.2		
	2%	WB	37.6	40.8	48.8	55.4	62.0	67.1	68.5	68.1	63.5	57.6	48.8	40.4		
		MCDB	39.2	45.9	58.9	69.6	75.0	80.6	82.2	80.6	72.7	64.3	53.8	41.8		
	5%	WB	35.9	38.7	46.6	53.4	60.0	65.3	66.9	66.4	61.7	55.7	46.6	38.0		
		MCDB	36.9	42.2	54.7	65.1	71.2	77.1	79.0	77.4	69.4	61.1	49.7	39.1		
	10%	WB	34.5	36.9	44.3	51.5	58.0	63.5	65.3	64.8	59.7	53.7	44.3	36.4		
		MCDB	35.4	39.5	50.7	61.6	67.6	73.6	75.1	74.7	65.9	58.1	46.9	37.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.0	13.6	17.7	20.3	19.8	18.8	18.7	18.7	17.0	16.9	11.2	9.4		
		MCDBR	9.4	19.1	27.2	29.9	28.9	28.3	27.2	27.1	23.9	22.4	17.1	10.7		
		MCWBR	7.2	12.2	14.6	13.6	12.2	11.4	10.6	11.0	11.7	12.7	10.8	8.1		
		MCDBR	8.5	16.7	25.1	27.4	25.8	25.4	24.6	24.4	21.6	20.4	16.2	9.8		
	5% WB	MCWBR	6.7	10.8	13.8	12.8	11.5	10.7	10.1	10.7	11.0	11.8	10.4	7.5		
(40) Clear-Sky Solar Irradiance	taub		0.290	0.322	0.371	0.415	0.430	0.437	0.437	0.428	0.390	0.357	0.323	0.291		
	taud		2.357	2.262	2.198	2.167	2.188	2.221	2.227	2.270	2.347	2.406	2.432	2.417		
	Ebn at Noon		251	264	266	265	265	263	261	259	258	250	237	238		
	Edh at Noon		23	31	38	44	45	43	43	39	33	27	21	19		
(44) All-Sky Solar Radiation	RadAvg		413	709	1020	1301	1485	1643	1672	1488	1088	762	429	336		
	RadStd		50	89	121	164	179	172	162	178	145	81	71	53		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (91 neighbors)	+0.79	N/A	N/A	N/A	+0.72	+0.61	N/A	N/A	+126	+59

Nomenclature: See separate page