

SALZBURG, Austria

WMO: 111500

Lat: 47.7894N

Lon: 13.0086E

Elev: 1460

StdP: 13.94

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.8	15.1	5.3	7.6	12.5	10.5	9.9	17.5	22.1	45.2	18.9	41.0	2.9	170	0.516

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.2	87.6	67.6	84.2	66.6	80.8	65.0	69.6	83.4	67.9	80.4	66.4	77.9	7.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.8	96.8	74.1	63.4	92.1	72.4	62.3	88.7	71.2	34.4	83.6	33.0	80.7	31.8	77.9	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.9	14.6	13.0	DB	4.1	92.6	6.1	2.9	-0.3	94.7	-3.9	96.4	-7.3	98.0	-11.7	100.1	(4)
(5)			WB	3.6	72.8	6.1	2.2	-0.8	74.4	-4.3	75.7	-7.8	76.9	-12.2	78.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	49.9	31.6	34.8	42.0	49.9	57.7	64.1	67.1	66.5	58.5	50.9	40.6	33.7	(6)
(7)		DBStd	14.54	8.54	9.02	7.86	7.70	6.95	7.04	6.16	6.15	6.26	7.13	7.57	7.63	(7)
(8)		HDD50	2258	572	428	266	96	13	1	0	0	6	78	292	506	(8)
(9)		HDD65	5853	1037	846	714	456	242	102	50	55	211	439	731	970	(9)
(10)		CDD50	2208	1	2	17	92	253	423	529	513	260	105	12	1	(10)
(11)		CDD65	325	0	0	0	2	17	74	114	102	15	1	0	0	(11)
(12)		CDH74	2985	0	0	0	32	217	704	1019	889	118	6	0	0	(12)
(13)		CDH80	874	0	0	0	3	37	203	337	282	12	0	0	0	(13)
(14)	Wind	WSAvg	5.8	5.9	5.9	6.5	6.3	6.1	5.9	6.0	5.6	5.3	5.3	5.3	5.8	(14)
(15)	Precipitation	PrecAvg	49.1	2.6	2.1	3.1	3.3	5.4	6.7	6.5	6.5	4.4	3.1	2.9	2.8	(15)
(16)		PrecMax	91.5	7.4	5.7	6.9	8.5	13.9	15.2	12.8	14.2	10.9	7.9	8.1	6.5	(16)
(17)		PrecMin	31.1	0.1	0.3	0.6	0.5	0.6	2.0	1.8	2.2	0.7	0.2	0.0	0.5	(17)
(18)		PrecStd	10.7	1.7	1.2	1.5	1.7	2.5	2.7	2.3	2.5	2.0	1.7	1.7	1.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.5	60.8	68.1	78.2	84.1	89.8	91.7	91.6	81.3	73.9	67.8	56.5	(19)
(20)			MCWB	46.3	47.8	50.7	58.8	64.3	69.3	69.0	69.0	65.4	59.6	52.2	45.6	(20)
(21)		2%	DB	48.7	55.1	63.1	73.1	79.9	85.7	87.6	86.5	77.3	69.8	60.6	49.6	(21)
(22)			MCWB	42.1	44.7	49.5	55.8	62.1	67.0	67.5	68.1	63.1	58.0	49.8	43.0	(22)
(23)		5%	DB	45.0	50.2	58.9	68.9	75.5	82.0	83.9	82.7	73.7	65.8	55.1	46.2	(23)
(24)			MCWB	40.5	42.1	47.5	53.7	59.9	65.0	66.4	66.5	61.8	56.1	47.8	42.0	(24)
(25)		10%	DB	42.4	46.1	54.1	64.5	71.5	78.0	80.2	78.9	70.0	61.8	51.2	43.1	(25)
(26)			MCWB	38.7	40.6	45.3	51.5	57.7	63.4	65.4	65.1	60.0	54.4	46.4	39.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.8	49.0	53.1	60.2	65.7	71.4	71.8	71.4	67.1	61.7	53.9	47.1	(27)
(28)			MCDWB	53.6	58.8	63.8	75.7	79.5	86.3	85.6	85.6	77.1	70.4	63.8	53.7	(28)
(29)		2%	WB	43.3	45.6	50.4	57.0	63.3	68.4	69.4	69.4	64.9	59.4	51.0	44.5	(29)
(30)			MCDWB	47.0	52.7	60.4	69.8	76.5	81.4	83.0	83.4	74.4	66.7	57.8	48.3	(30)
(31)		5%	WB	40.7	43.2	48.4	54.5	61.3	66.6	67.6	67.6	63.2	57.5	48.9	42.0	(31)
(32)			MCDWB	44.3	48.7	57.0	66.5	72.5	78.7	80.2	79.8	71.3	64.0	54.1	45.1	(32)
(33)		10%	WB	38.6	40.9	46.3	52.4	59.2	64.7	66.0	66.0	61.2	55.5	46.8	39.9	(33)
(34)			MCDWB	41.7	45.3	53.2	62.7	68.9	75.1	77.4	76.7	68.0	60.7	51.0	42.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.4	13.9	16.4	18.4	18.5	17.7	18.2	17.9	16.4	16.0	12.7	10.6	(35)
(36)			MCDBR	14.5	20.2	24.7	26.7	26.1	25.2	25.4	24.4	22.5	21.6	20.5	14.6	(36)
(37)			MCWBR	9.4	12.1	13.3	13.3	11.8	10.5	10.1	10.0	11.2	12.0	11.7	9.5	(37)
(38)		5% WB	MCDWB	13.6	18.2	22.0	24.0	23.3	22.5	22.5	22.7	20.4	19.5	18.2	13.0	(38)
(39)			MCWBR	9.3	11.4	12.6	12.9	11.3	10.2	9.9	10.2	10.7	11.6	11.2	9.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.296	0.324	0.366	0.401	0.413	0.418	0.421	0.414	0.384	0.352	0.322	0.294	(40)	
(41)		taud	2.399	2.319	2.271	2.237	2.251	2.280	2.272	2.308	2.363	2.433	2.459	2.441	(41)	
(42)		Ebn at Noon	248	263	268	269	270	269	266	263	260	251	236	235	(42)	
(43)		Edh at Noon	22	29	36	41	42	41	41	38	32	26	21	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	381	679	994	1318	1511	1668	1669	1481	1073	732	400	304	(44)	
(45)		RadStd	51	86	118	166	181	168	163	172	144	77	61	46	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	+0.65	N/A	N/A	N/A	N/A	(46)
(47)	Regional (86 neighbors)	+0.79	N/A	N/A	N/A	+0.65	+0.68	N/A	N/A	+112	+45	(47)

Nomenclature: See separate page