

SALZBURG, Austria

WMO: 111500

Lat: 47.7894N

Lon: 13.0086E

Elev: 445

StdP: 96.09

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.3	-9.4	-14.8	1.1	-10.8	-12.0	1.4	-8.1	9.9	7.3	8.5	5.0	1.3	170	0.516

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	30.9	19.8	29.0	19.2	27.1	18.3	20.9	28.6	19.9	26.9	19.1	25.5	3.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.2	13.8	23.4	17.4	13.2	22.4	16.8	12.7	21.8	62.1	28.6	59.0	27.1	56.1	25.5	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.6	6.5	5.8	DB	-15.5	33.7	3.4	1.6	-18.0	34.8	-19.9	35.8	-21.8	36.7	-24.3	37.9	(4)
(5)			WB	-15.8	22.7	3.4	1.2	-18.2	23.6	-20.2	24.3	-22.1	25.0	-24.6	25.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.9	-0.2	1.5	5.5	9.9	14.3	17.8	19.5	19.2	14.7	10.5	4.8	0.9	(6)
(7)		DBStd	8.08	4.74	5.01	4.37	4.28	3.86	3.91	3.42	3.42	3.48	3.96	4.20	4.24	(7)
(8)		HDD10.0	1254	318	238	148	53	7	1	0	0	3	43	162	281	(8)
(9)		HDD18.3	3252	576	470	397	253	134	57	28	31	117	244	406	539	(9)
(10)		CDD10.0	1227	1	1	9	51	141	235	294	285	144	58	7	1	(10)
(11)		CDD18.3	181	0	0	0	1	9	41	63	57	8	1	0	0	(11)
(12)		CDH23.3	1658	0	0	0	18	121	391	566	494	66	3	0	0	(12)
(13)		CDH26.7	486	0	0	0	2	21	113	187	157	7	0	0	0	(13)
(14)	Wind	WSAvg	2.6	2.6	2.6	2.9	2.8	2.7	2.7	2.5	2.4	2.4	2.4	2.6	(14)	
(15)	Precipitation	PrecAvg	1246	66	54	79	84	138	170	164	165	111	78	74	72	(15)
(16)		PrecMax	2323	187	146	176	215	352	386	324	360	277	200	207	164	(16)
(17)		PrecMin	790	2	7	15	12	14	50	46	57	17	6	0	13	(17)
(18)		PrecStd	271	42	31	37	44	63	69	59	63	51	43	42	38	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.0	16.0	20.0	25.7	29.0	32.1	33.2	33.1	27.4	23.3	19.9	13.6	(19)
(20)			MCWB	7.9	8.8	10.4	14.9	18.0	20.7	20.6	20.5	18.6	15.4	11.2	7.6	(20)
(21)		2%	DB	9.3	12.8	17.3	22.8	26.6	29.8	30.9	30.3	25.2	21.0	15.9	9.8	(21)
(22)			MCWB	5.6	7.0	9.7	13.2	16.7	19.4	19.7	20.1	17.3	14.4	9.9	6.1	(22)
(23)		5%	DB	7.2	10.1	14.9	20.5	24.2	27.8	28.8	28.2	23.1	18.8	12.8	7.9	(23)
(24)			MCWB	4.7	5.6	8.6	12.1	15.5	18.3	19.1	19.2	16.6	13.4	8.8	5.5	(24)
(25)		10%	DB	5.8	7.9	12.3	18.1	22.0	25.6	26.8	26.1	21.1	16.6	10.6	6.2	(25)
(26)			MCWB	3.7	4.8	7.4	10.8	14.3	17.5	18.6	18.4	15.5	12.5	8.0	4.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.8	9.4	11.7	15.7	18.7	21.9	22.1	21.9	19.5	16.5	12.2	8.4	(27)
(28)			MCD B	12.0	14.9	17.7	24.3	26.4	30.2	29.8	29.8	25.1	21.3	17.7	12.0	(28)
(29)		2%	WB	6.3	7.5	10.2	13.9	17.4	20.2	20.8	20.8	18.3	15.2	10.5	6.9	(29)
(30)			MCD B	8.3	11.5	15.8	21.0	24.7	27.4	28.4	28.6	23.6	19.3	14.3	9.1	(30)
(31)		5%	WB	4.8	6.2	9.1	12.5	16.3	19.2	19.8	19.8	17.3	14.1	9.4	5.5	(31)
(32)			MCD B	6.8	9.3	13.9	19.2	22.5	25.9	26.8	26.6	21.8	17.8	12.3	7.3	(32)
(33)		10%	WB	3.7	4.9	8.0	11.4	15.1	18.2	18.9	18.9	16.2	13.0	8.2	4.4	(33)
(34)			MCD B	5.4	7.4	11.8	17.0	20.5	23.9	25.2	24.8	20.0	15.9	10.6	6.0	(34)
(35)	Mean Daily Temperature Range	MDBR	6.3	7.7	9.1	10.2	10.3	9.9	10.1	10.0	9.1	8.9	7.0	5.9	(35)	
(36)		5% DB	MCD BR	8.1	11.2	13.7	14.8	14.5	14.0	14.1	13.6	12.5	12.0	11.4	8.1	(36)
(37)			MCWBR	5.2	6.7	7.4	7.4	6.6	5.8	5.6	5.6	6.2	6.6	6.5	5.3	(37)
(38)			5% WB	MCD BR	7.6	10.1	12.2	13.4	13.0	12.5	12.5	12.6	11.3	10.8	10.1	7.2
(39)		MCWBR		5.2	6.3	7.0	7.2	6.3	5.6	5.5	5.7	5.9	6.5	6.2	5.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.296	0.324	0.366	0.401	0.413	0.418	0.421	0.414	0.384	0.352	0.322	0.294	(40)	
(41)		taud	2.399	2.319	2.271	2.237	2.251	2.280	2.272	2.308	2.363	2.433	2.459	2.441	(41)	
(42)		Ebn at Noon	783	830	846	849	851	847	838	828	819	791	745	741	(42)	
(43)		Edh at Noon	68	91	113	128	132	129	128	119	102	82	65	59	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.20	2.14	3.13	4.16	4.76	5.26	5.26	4.67	3.38	2.31	1.26	0.96	(44)	
(45)		RadStd	0.16	0.27	0.37	0.52	0.57	0.53	0.52	0.54	0.45	0.24	0.19	0.14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		N/A	N/A	N/A	N/A	N/A	+0.36	N/A	N/A	N/A	N/A		
(47) Regional (86 neighbors)		+0.44	N/A	N/A	N/A	+0.36	+0.38	N/A	N/A	+62	+25		

Nomenclature: See separate page