

FEUERKOGEL, Austria

WMO: 111550

Lat: 47.817N

Lon: 13.718E

Elev: 5315

StdP: 12.08

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.7	9.0	-8.2	4.3	20.5	-2.6	5.8	23.1	48.8	30.6	43.6	33.5	8.4	310	0.741

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.0	71.3	59.2	68.5	57.9	66.0	56.6	61.4	68.4	59.6	66.4	57.9	64.3	6.8	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.8	90.2	65.3	56.8	83.8	63.3	55.0	78.6	61.7	30.2	68.4	28.7	66.6	27.5	64.5	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 37.9	31.7	26.8	2.0	76.4	5.3	3.1	-1.7	78.7	-4.8	80.5	-7.8	82.3	-11.6	84.5		
(5)			1.7	65.4	5.4	3.2	-2.2	67.6	-5.4	69.5	-8.5	71.3	-12.4	73.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	39.8	26.1	25.5	29.8	36.7	44.5	50.9	53.9	54.2	47.3	43.0	35.1	28.9
	DBStd	13.36	8.63	9.67	8.73	8.88	8.12	8.10	7.20	7.36	7.86	9.08	9.85	9.30
	HDD50	4333	740	686	626	407	210	86	43	41	142	249	450	653
	HDD65	9230	1205	1106	1091	850	637	424	349	342	530	682	896	1118
	CDD50	594	0	0	0	6	38	115	165	171	62	33	4	0
	CDD65	15	0	0	0	0	0	3	5	7	0	0	0	0
	CDH74	16	0	0	0	0	0	3	8	5	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	10.8	13.2	12.7	12.2	9.9	9.6	9.1	9.7	8.6	9.2	10.9	12.0	12.7
Precipitation	PrecAvg	55.7	3.6	3.2	4.3	3.3	5.4	6.5	6.9	6.3	5.2	3.7	3.6	3.7
	PrecMax	66.9	8.6	7.4	8.1	6.7	10.5	13.3	14.2	13.5	10.6	6.6	9.7	7.8
	PrecMin	42.3	0.4	1.0	1.6	0.6	1.3	2.6	2.3	2.6	1.7	0.9	0.0	1.0
	PrecStd	5.6	2.0	1.6	2.1	1.5	2.1	2.3	2.6	2.2	2.2	1.6	2.0	1.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.1	48.3	50.2	59.3	67.6	73.5	74.9	74.3	67.3	64.6	58.5	50.6
		MCWB	36.7	34.4	38.3	46.1	54.6	61.4	61.7	60.0	55.7	47.8	44.2	37.0
	2%	DB	44.0	44.6	47.0	54.9	63.1	69.4	71.1	70.9	63.4	60.7	53.8	46.8
		MCWB	34.6	33.7	37.5	44.5	52.4	58.8	59.6	58.8	53.4	46.7	42.5	35.6
	5%	DB	41.1	41.4	44.4	51.6	59.8	66.5	67.9	68.0	60.8	58.0	50.7	43.9
		MCWB	33.5	32.7	36.5	42.9	50.8	57.0	58.3	57.7	52.1	46.4	41.0	33.8
	10%	DB	38.3	38.1	42.0	48.6	56.4	63.3	65.1	65.2	58.3	55.2	48.0	41.4
		MCWB	31.8	31.5	35.2	41.2	48.9	55.3	57.1	56.5	51.0	45.3	39.5	32.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.7	37.5	41.4	48.3	57.5	63.4	64.6	63.1	58.0	51.8	46.5	39.6
		MCDB	42.9	42.2	46.6	56.0	63.7	70.5	71.7	70.5	63.1	58.0	54.6	45.2
	2%	WB	36.6	35.5	39.4	45.8	54.0	60.5	61.4	60.8	55.8	49.8	44.0	37.9
		MCDB	41.5	40.9	44.0	53.2	60.8	67.7	68.2	67.8	60.9	56.5	51.5	43.1
	5%	WB	34.7	34.0	37.8	43.8	51.6	58.2	59.7	59.1	54.0	48.3	42.1	36.5
		MCDB	39.8	39.6	42.6	50.4	58.0	64.6	66.4	66.0	59.1	54.7	48.6	41.5
	10%	WB	32.7	32.3	36.2	42.0	49.6	56.0	57.8	57.3	52.1	46.8	40.5	34.5
		MCDB	37.2	37.5	40.9	47.8	55.5	62.1	64.0	63.8	57.0	53.6	46.6	39.7
Mean Daily Temperature Range	5% DB	MDBR	8.2	8.3	8.1	8.5	9.3	9.7	9.9	9.0	8.3	9.0	8.5	8.2
		MCDBR	11.2	11.0	9.8	10.7	12.6	12.6	13.2	12.0	11.1	11.2	10.3	10.5
		MCWBR	6.6	6.2	6.6	7.4	9.3	10.1	9.8	9.5	9.0	7.3	5.9	5.9
	5% WB	MCDBR	10.3	10.0	9.2	10.3	11.2	11.7	12.1	11.0	9.7	10.1	10.0	10.0
		MCWBR	7.5	7.0	6.7	7.8	9.3	10.1	9.9	9.5	8.7	7.1	6.5	7.2
Clear-Sky Solar Irradiance	taub	0.243	0.265	0.296	0.321	0.331	0.335	0.339	0.333	0.312	0.289	0.268	0.244	
	taud	2.471	2.437	2.437	2.437	2.436	2.445	2.427	2.462	2.508	2.563	2.568	2.512	
	Ebn at Noon	276	290	295	296	296	294	291	289	286	278	264	263	
	Edh at Noon	19	25	30	33	35	35	35	32	28	22	18	16	
All-Sky Solar Radiation	RadAvg	375	668	987	1321	1518	1672	1667	1481	1072	726	396	300	
	RadStd	49	85	117	162	180	161	161	170	142	76	58	44	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (94 neighbors)		N/A	N/A	N/A	+1.62	N/A	N/A	N/A	N/A	N/A
		+0.90	N/A	N/A	+1.35	+0.76	+0.65	N/A	N/A	+133
										+58

Nomenclature: See separate page