

AIGEN IM ENNSTAL, Austria

WMO: 111570

Lat: 47.5328N

Lon: 14.1383E

Elev: 652

StdP: 93.74

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.4	-12.6	-17.1	0.9	-14.7	-14.3	1.2	-11.8	10.1	5.5	8.7	2.7	0.7	240	0.533

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	29.3	19.3	27.4	18.6	25.6	17.8	20.3	27.4	19.2	25.9	18.4	24.4	2.6	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.7	13.8	24.2	16.8	13.0	22.5	16.0	12.3	21.3	61.4	27.4	57.6	26.0	54.5	24.6	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.5	6.4	5.4	-18.8	32.6	3.5	1.5	-21.4	33.7	-23.4	34.6	-25.4	35.4	-28.0	36.5		
			-19.1	22.4	3.5	1.0	-21.6	23.1	-23.6	23.7	-25.5	24.3	-28.1	25.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.1	-2.9	-0.5	3.9	8.4	12.8	16.5	18.0	17.5	13.0	8.6	3.2	-1.9	(6)
	DBStd	8.23	4.73	4.38	3.86	3.63	3.48	3.68	3.08	3.01	3.16	3.51	4.13	4.43	(7)
	HDD10.0	1626	401	294	191	72	13	2	0	1	9	69	208	369	(8)
	HDD18.3	3822	658	527	447	299	173	76	44	52	160	302	455	627	(9)
	CDD10.0	929	0	0	1	22	101	197	247	232	100	26	3	0	(10)
	CDD18.3	83	0	0	0	0	2	22	33	25	1	0	0	0	(11)
	CDH23.3	967	0	0	0	6	67	257	331	281	27	0	0	0	(12)
	CDH26.7	245	0	0	0	1	12	69	91	71	2	0	0	0	(13)
(14) Wind	WSAvg	2.0	2.0	2.1	2.5	2.2	2.1	2.1	2.0	1.8	1.8	1.7	1.8	1.8	(14)
(15) Precipitation	PrecAvg	1345	86	74	103	78	123	157	179	152	126	94	87	86	(15)
	PrecMax	1592	214	179	221	139	214	268	337	272	246	182	217	214	(16)
	PrecMin	1073	9	25	38	23	35	88	77	65	54	37	10	31	(17)
	PrecStd	124	52	40	54	29	46	41	65	45	48	37	44	40	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.3	13.0	18.2	23.9	28.2	31.3	31.8	31.1	26.1	21.2	18.0	9.5	(19)
		MCWB	5.9	6.9	9.8	13.6	17.0	19.7	20.3	19.8	17.9	14.8	10.6	6.5	(20)
	2%	DB	6.4	9.7	15.8	21.1	25.1	28.7	29.1	28.7	23.6	18.6	13.8	7.1	(21)
		MCWB	3.9	5.3	8.8	12.1	16.0	18.6	19.6	19.5	17.0	13.6	9.8	4.6	(22)
	5%	DB	4.5	7.0	13.0	18.8	22.8	26.5	27.0	26.5	21.6	16.5	10.9	5.1	(23)
		MCWB	2.6	3.9	7.5	11.2	14.7	17.8	18.8	18.8	15.8	12.3	8.3	3.2	(24)
	10%	DB	3.0	5.0	10.3	16.3	20.4	24.1	24.8	24.3	19.5	14.6	8.9	3.4	(25)
		MCWB	1.4	2.6	6.3	9.9	13.9	16.9	17.9	17.9	14.7	11.4	7.0	2.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.1	7.3	10.5	14.3	18.2	20.9	21.8	21.5	18.7	15.6	11.6	7.1	(27)
		MCDB	9.5	12.0	16.5	22.3	25.7	28.7	29.4	28.5	24.7	20.1	16.4	9.0	(28)
	2%	WB	4.2	5.5	9.2	12.7	16.5	19.5	20.2	20.2	17.4	14.1	9.9	5.0	(29)
		MCDB	6.0	9.0	14.7	20.0	23.6	26.9	27.4	27.1	22.7	17.6	13.5	6.6	(30)
	5%	WB	2.7	4.0	7.9	11.5	15.4	18.4	19.2	19.1	16.2	12.9	8.6	3.4	(31)
		MCDB	4.2	6.6	12.5	17.6	21.5	25.2	25.8	25.4	20.5	15.8	10.8	4.7	(32)
	10%	WB	1.6	2.8	6.5	10.3	14.2	17.3	18.2	18.1	15.0	11.7	7.1	2.2	(33)
		MCDB	2.7	4.7	9.9	15.5	19.5	23.1	24.0	23.6	18.8	14.2	8.7	3.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	7.0	8.4	9.9	11.5	11.6	11.2	11.2	11.5	10.6	10.3	7.5	6.2	(35)
		MCDBR	7.6	11.5	15.7	17.7	17.0	16.5	16.0	16.1	15.0	13.6	11.0	7.5	(36)
	5% WB	MCWBR	5.6	7.6	9.3	9.5	8.6	7.4	7.6	8.0	8.7	8.7	7.4	5.6	(37)
		MCWBR	7.1	10.5	14.7	16.2	15.2	14.9	14.6	14.8	13.7	12.6	10.4	7.0	(38)
(40) Clear-Sky Solar Irradiance	taub		0.283	0.313	0.357	0.399	0.410	0.416	0.419	0.411	0.379	0.347	0.316	0.284	(40)
		taud	2.376	2.305	2.260	2.235	2.254	2.282	2.277	2.317	2.381	2.443	2.467	2.441	(41)
	Ebn at Noon		803	845	856	852	854	850	841	832	827	800	757	760	(42)
		Edh at Noon	69	93	114	129	131	129	128	118	101	81	65	59	(43)
(44) All-Sky Solar Radiation	RadAvg		1.22	2.12	3.12	4.11	4.73	5.19	5.21	4.65	3.38	2.34	1.31	1.00	(44)
	RadStd		0.14	0.26	0.35	0.46	0.55	0.46	0.49	0.55	0.44	0.23	0.19	0.15	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (103 neighbors)	+0.46	N/A	N/A	+1.05	+0.56	+0.41	N/A	N/A	N/A	N/A
		+0.51	N/A	N/A	+0.79	+0.46	+0.39	N/A	-139	+81	+43

Nomenclature: See separate page