

LUNZ, Austria

WMO: 111700

Lat: 47.854N

Lon: 15.068E

Elev: 2004

StdP: 13.66

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.0	7.4	-0.7	5.7	2.7	4.5	7.5	8.4	14.4	36.8	12.9	37.0	0.9	90	0.514

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.9	84.1	66.6	80.7	65.3	77.3	63.7	68.5	79.8	66.8	77.4	65.2	74.8	3.2	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.9	99.2	72.7	63.2	93.3	71.0	61.6	88.2	69.3	33.9	80.1	32.5	77.6	31.2	74.9	75.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.0	8.8	7.0	DB	-3.3	90.4	8.1	3.0	-9.1	92.6	-13.8	94.4	-18.3	96.1	-24.2	98.3	(4)
(5)			WB	-3.7	72.4	8.0	1.9	-9.4	73.8	-14.1	74.9	-18.6	76.0	-24.3	77.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.0	26.7	30.3	37.4	46.1	54.0	60.4	62.9	62.5	55.3	47.7	37.9	29.6		
	DBStd	14.56	9.32	8.63	7.06	7.01	6.25	6.31	5.53	5.24	6.01	6.46	7.70	8.14		
	HDD50	2997	724	551	391	154	31	5	0	0	20	121	369	631		
	HDD65	7043	1189	971	855	568	342	162	106	111	293	538	812	1096		
	CDD50	1533	0	0	1	35	156	318	400	388	179	48	8	0		
	CDD65	102	0	0	0	0	2	24	41	33	2	0	0	0		
	CDH74	1507	0	0	0	13	92	375	512	458	57	0	0	0		
	CDH80	360	0	0	0	0	10	90	134	121	5	0	0	0		
	WSAvg	2.1	2.4	2.3	2.5	2.4	2.1	1.9	1.9	1.7	1.7	2.1	2.2	2.3		
	PrecAvg	51.5	3.7	3.1	4.4	3.1	5.0	5.4	5.9	5.4	5.0	3.2	3.4	3.6		
	PrecMax	65.4	7.9	6.9	7.7	5.5	12.4	13.8	13.7	11.6	12.7	7.6	6.1	6.7		
(15) Precipitation	PrecMin	37.6	0.7	0.9	2.2	0.5	1.2	1.7	1.5	1.4	1.9	0.3	0.4	1.3		
	PrecStd	7.0	1.9	1.7	1.9	1.4	2.4	2.6	3.0	2.6	2.5	1.7	1.4	1.3		
	DB	53.1	54.8	63.6	75.8	81.3	87.1	88.8	88.4	79.7	70.5	65.4	54.8			
	MCWB	44.8	44.2	48.4	56.2	63.1	67.3	68.1	67.7	63.9	58.2	52.4	44.3			
	2% DB	46.2	50.1	57.8	70.0	76.7	82.5	83.6	83.3	74.7	65.6	60.2	46.7			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	MCWB	40.7	42.7	46.2	53.9	61.0	65.8	67.2	66.4	62.5	56.5	49.9	42.6			
	5% DB	41.1	45.3	53.2	65.4	72.6	78.4	79.8	79.3	70.7	61.7	54.0	42.0			
	MCWB	37.9	40.0	44.4	51.7	58.7	64.1	65.6	65.5	60.6	54.2	47.4	39.2			
	10% DB	37.6	41.4	48.7	60.8	68.1	74.3	75.7	74.9	66.6	57.8	48.5	38.8			
	MCWB	35.4	37.5	42.6	49.5	56.5	62.3	63.8	63.6	58.7	52.7	45.4	36.5			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	45.5	45.8	49.9	57.6	66.0	70.0	71.0	70.6	65.9	60.6	53.1	46.2			
	MCDB	51.4	52.4	60.7	73.0	75.5	81.7	83.1	82.0	75.2	67.7	61.9	52.2			
	2% WB	41.3	42.9	47.4	54.8	62.4	67.3	68.4	68.3	63.8	57.4	50.4	43.0			
	MCDB	44.8	49.1	55.7	67.7	73.9	78.4	80.2	79.3	72.5	63.5	58.0	46.6			
	5% WB	38.1	40.4	45.2	52.3	59.9	65.3	66.7	66.4	61.7	55.1	48.0	39.5			
(30) Mean Daily Temperature Range	MCDB	40.7	44.8	51.9	63.2	69.7	75.9	77.0	76.5	69.2	60.5	53.5	42.1			
	10% WB	35.5	37.8	43.0	50.2	57.6	63.4	64.9	64.5	59.5	53.0	45.4	36.9			
	MCDB	37.5	41.2	48.6	59.4	66.3	72.7	74.0	73.4	65.5	57.1	48.9	38.5			
	5% DB	11.5	14.1	16.9	20.2	19.9	20.1	19.9	20.7	17.7	16.8	12.0	9.7			
	MCDBR	14.2	20.6	26.5	31.0	30.4	29.5	29.4	29.9	26.2	24.0	20.1	15.0			
(36) Clear-Sky Solar Irradiance	MCWBR	9.9	13.4	15.5	15.9	15.3	14.4	14.3	14.7	15.1	15.1	12.5	10.9			
	5% WB	13.1	17.8	23.9	27.9	27.6	26.8	26.3	27.2	24.1	21.8	18.2	14.3			
	MCDBR	9.8	12.0	14.7	15.0	14.8	13.9	13.4	14.5	14.6	14.4	12.1	10.7			
	taub	0.294	0.324	0.367	0.408	0.414	0.419	0.424	0.418	0.389	0.355	0.325	0.294			
	taud	2.381	2.317	2.259	2.203	2.234	2.260	2.248	2.278	2.331	2.404	2.435	2.426			
(42) All-Sky Solar Radiation	Ebn at Noon	248	263	268	267	270	268	265	261	258	249	234	234			
	Edh at Noon	22	29	36	42	43	42	42	39	34	27	21	19			
	RadAvg	357	634	964	1327	1536	1678	1655	1479	1066	709	385	292			
(45)	RadStd	43	80	112	148	176	137	155	163	136	71	50	38			

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (102 neighbors)	+0.94	N/A	N/A	N/A	+0.77	+0.72	-198	-257	+142	+68	(47)

Nomenclature: See separate page