

FISHBACH, Austria

WMO: 111730

Lat: 47.444N

Lon: 15.644E

Elev: 3403

StdP: 12.98

Time Zone: 1.00 (EUC)

Period: 06-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.0	14.6	3.5	7.4	14.6	7.1	9.0	17.9	30.7	24.8	27.9	24.7	4.6	340	0.546

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.5	79.0	66.1	75.7	64.8	72.7	63.1	67.6	76.0	65.7	73.7	64.0	71.6	5.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.6	103.5	72.7	62.7	96.6	71.0	60.9	90.6	68.9	34.1	76.1	32.5	74.1	31.1	71.8	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.7	21.1	17.4	DB	8.2	83.3	4.4	2.4	5.0	85.1	2.4	86.5	-0.1	87.8	-3.3	89.5	(4)
(5)			WB	7.1	70.7	4.2	2.7	4.2	72.6	1.7	74.2	-0.6	75.7	-3.6	77.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.8	29.2	30.9	37.2	45.7	52.2	58.6	62.3	61.3	53.4	46.7	38.9	32.4
	DBStd	13.60	8.39	8.25	7.86	7.37	6.60	6.10	6.18	6.21	6.75	7.54	8.17	7.92
	HDD50	2893	645	535	398	163	55	6	1	2	41	159	341	547
	HDD65	7099	1110	955	861	578	400	206	125	150	349	569	784	1012
	CDD50	1363	0	0	2	35	122	264	382	352	144	55	7	0
	CDD65	96	0	0	0	0	2	15	42	35	2	0	0	0
	CDH74	456	0	0	0	0	7	67	187	189	6	0	0	0
	CDH80	48	0	0	0	0	0	4	17	27	0	0	0	0
Wind	WSAvg	5.6	5.5	5.5	6.6	6.3	7.0	5.7	5.6	5.3	5.5	5.0	4.8	5.0
Precipitation	PrecAvg	37.7	1.6	1.6	2.2	2.4	4.1	5.2	5.0	5.0	3.6	2.9	2.4	2.0
	PrecMax	48.2	3.1	4.1	5.8	5.0	8.4	7.7	10.4	8.3	6.7	6.8	4.9	4.3
	PrecMin	26.3	0.5	0.3	0.4	0.3	1.7	2.4	1.3	1.7	1.2	0.2	0.0	0.3
	PrecStd	5.1	0.8	1.0	1.1	1.0	1.5	1.4	2.1	1.7	1.2	1.6	1.1	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.2	52.6	59.4	69.0	72.9	79.7	82.2	83.0	72.9	68.6	60.3	52.3
		MCWB	43.0	41.8	47.3	55.6	61.2	65.5	67.7	68.4	63.2	57.4	49.2	41.5
	2%	DB	47.1	48.0	55.2	63.1	69.8	75.6	78.8	79.2	70.0	64.4	55.9	48.5
		MCWB	40.5	40.1	46.0	51.6	59.6	64.3	66.2	66.5	61.2	55.1	47.9	39.5
	5%	DB	43.9	44.8	51.7	60.1	66.2	72.5	75.8	75.1	66.7	60.5	52.7	45.3
		MCWB	38.7	38.8	43.7	50.1	57.2	62.5	65.0	64.7	59.4	53.5	46.1	38.8
	10%	DB	40.9	41.7	48.3	56.8	62.9	69.0	72.7	71.6	63.4	56.8	49.5	42.5
		MCWB	36.6	36.7	41.9	48.4	55.0	60.4	63.4	62.9	57.5	51.5	44.5	37.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.3	44.4	48.7	56.3	62.9	67.6	69.7	70.7	65.3	59.1	51.6	44.1
		MCDB	49.6	52.0	57.6	67.6	72.2	75.1	78.2	78.0	70.9	66.7	55.7	49.2
	2%	WB	41.4	41.1	46.5	52.7	60.4	65.5	67.7	67.5	61.8	56.2	49.4	41.9
		MCDB	46.1	46.3	53.6	62.0	68.3	73.6	76.1	76.7	68.2	62.8	53.8	46.1
	5%	WB	39.3	39.0	44.4	50.7	57.9	63.2	65.9	65.4	60.0	54.1	47.4	39.8
		MCDB	43.2	43.7	50.9	58.3	64.8	71.1	73.9	73.6	65.9	59.1	51.4	43.8
	10%	WB	37.0	36.9	42.4	49.0	55.8	61.1	64.3	63.4	57.9	52.2	45.4	37.7
		MCDB	40.1	41.1	47.5	55.6	61.8	68.1	71.6	71.0	62.7	56.4	48.8	41.9
Mean Daily Temperature Range	5% DB	MDBR	8.9	9.8	11.3	13.3	13.0	13.0	13.5	13.4	11.3	11.6	9.7	9.2
		MCDBR	11.9	13.5	16.6	18.1	17.5	17.5	17.0	17.9	15.2	15.9	14.1	13.5
		MCWBR	8.3	9.1	9.9	10.1	10.0	9.0	8.9	9.5	9.1	9.1	9.1	9.1
	5% WB	MCDBR	10.7	12.6	15.1	16.9	16.9	16.9	16.3	17.2	14.6	14.3	12.6	12.4
		MCWBR	8.1	8.9	9.5	9.8	10.4	9.8	9.1	10.0	9.1	8.8	8.6	8.9
Clear-Sky Solar Irradiance	taub	0.273	0.297	0.332	0.370	0.373	0.378	0.382	0.381	0.355	0.330	0.304	0.273	
	taud	2.448	2.409	2.374	2.318	2.347	2.356	2.343	2.360	2.413	2.471	2.503	2.492	
	Ebn at Noon	262	277	282	280	283	281	278	273	271	261	247	249	
	Edh at Noon	21	27	32	38	38	38	38	36	31	25	20	18	
All-Sky Solar Radiation	RadAvg	376	648	985	1326	1546	1690	1682	1501	1085	737	410	309	
	RadStd	40	81	111	137	170	128	148	169	136	70	56	43	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (101 neighbors)		+0.95	N/A	N/A	+1.57	+0.86	+0.74	-193	-254	+158	+94

Nomenclature: See separate page