

FISHBACH, Austria

WMO: 111730

Lat: 47.444N

Lon: 15.644E

Elev: 1037

StdP: 89.47

Time Zone: 1.00 (EUC)

Period: 06-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.7	-9.7	-15.9	1.1	-9.7	-13.8	1.3	-7.8	13.7	-4.0	12.5	-4.1	2.1	340	0.546

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.5	26.1	19.0	24.3	18.2	22.6	17.3	19.8	24.5	18.7	23.2	17.8	22.0	2.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	14.8	22.6	17.0	13.8	21.7	16.1	12.9	20.5	61.5	24.5	57.8	23.4	54.5	22.1	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.5	9.4	7.8	-13.2	28.5	2.5	1.3	-15.0	29.5	-16.4	30.3	-17.8	31.0	-19.6	32.0		
(5)			-13.8	21.5	2.3	1.5	-15.5	22.6	-16.8	23.4	-18.1	24.3	-19.8	25.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.7	-1.6	-0.6	2.9	7.6	11.2	14.8	16.8	16.3	11.9	8.1	3.8	0.2		
	DBStd	7.55	4.66	4.58	4.37	4.09	3.67	3.39	3.43	3.45	3.75	4.19	4.54	4.40		
	HDD10.0	1607	358	297	221	91	31	3	1	1	23	88	189	304		
	HDD18.3	3944	617	531	478	321	222	114	69	83	194	316	436	562		
	CDD10.0	757	0	0	1	19	68	147	212	196	80	31	4	0		
	CDD18.3	53	0	0	0	0	1	8	23	19	1	0	0	0		
	CDH23.3	253	0	0	0	0	4	37	104	105	3	0	0	0		
	CDH26.7	27	0	0	0	0	0	2	9	15	0	0	0	0		
(14) Wind	WSAvg	2.5	2.4	2.4	3.0	2.8	3.1	2.6	2.5	2.4	2.5	2.2	2.1	2.2		
(15) Precipitation	PrecAvg	957	40	41	56	61	103	131	128	126	92	73	62	50		
	PrecMax	1225	78	105	148	126	213	195	265	210	170	173	124	109		
	PrecMin	667	12	8	9	7	44	62	32	44	30	6	1	8		
	PrecStd	129	21	26	29	26	37	36	53	44	31	40	28	23		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	11.5	15.2	20.6	22.7	26.5	27.9	28.3	22.7	20.3	15.7	11.3		
		MCWB	6.1	5.4	8.5	13.1	16.2	18.6	19.8	20.2	17.3	14.1	9.6	5.3		
	2%	DB	8.4	8.9	12.9	17.3	21.0	24.2	26.0	26.2	21.1	18.0	13.3	9.2		
		MCWB	4.7	4.5	7.8	10.9	15.3	17.9	19.0	19.1	16.2	12.9	8.8	4.2		
	5%	DB	6.6	7.1	11.0	15.6	19.0	22.5	24.3	24.0	19.3	15.8	11.5	7.4		
		MCWB	3.7	3.8	6.5	10.1	14.0	16.9	18.3	18.1	15.2	11.9	7.8	3.8		
	10%	DB	4.9	5.4	9.0	13.8	17.1	20.5	22.6	22.0	17.4	13.8	9.7	5.8		
		MCWB	2.6	2.6	5.5	9.1	12.8	15.8	17.4	17.2	14.2	10.8	7.0	3.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.8	6.9	9.3	13.5	17.2	19.8	20.9	21.5	18.5	15.0	10.9	6.7		
		MCDB	9.8	11.1	14.2	19.8	22.3	24.0	25.7	25.5	21.6	19.3	13.2	9.6		
	2%	WB	5.2	5.1	8.0	11.5	15.8	18.6	19.9	19.7	16.6	13.5	9.7	5.5		
		MCDB	7.8	7.9	12.0	16.7	20.2	23.1	24.5	24.8	20.1	17.1	12.1	7.8		
	5%	WB	4.1	3.9	6.9	10.4	14.4	17.4	18.8	18.5	15.5	12.3	8.6	4.3		
		MCDB	6.2	6.5	10.5	14.6	18.2	21.7	23.3	23.1	18.8	15.1	10.8	6.6		
	10%	WB	2.8	2.7	5.8	9.5	13.2	16.2	17.9	17.5	14.4	11.2	7.4	3.2		
		MCDB	4.5	5.0	8.6	13.1	16.6	20.1	22.0	21.7	17.1	13.5	9.3	5.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	5.5	6.3	7.4	7.2	7.2	7.5	7.5	6.3	6.4	5.4	5.1		
		MCDBR	6.6	7.5	9.2	10.0	9.7	9.7	9.5	10.0	8.5	8.8	7.8	7.5		
		MCWBR	4.6	5.1	5.5	5.6	5.6	5.0	4.9	5.3	5.1	5.1	5.0	5.0		
	5% WB	MCDBR	5.9	7.0	8.4	9.4	9.4	9.1	9.5	8.1	7.9	7.0	6.9	6.9		
		MCWBR	4.5	5.0	5.3	5.4	5.8	5.4	5.0	5.6	5.1	4.9	4.8	4.9		
(40) Clear-Sky Solar Irradiance	taub		0.273	0.297	0.332	0.370	0.373	0.378	0.382	0.381	0.355	0.330	0.304	0.273		
	taud		2.448	2.409	2.374	2.318	2.347	2.356	2.343	2.360	2.413	2.471	2.503	2.492		
	Ebn at Noon		826	874	889	882	891	885	876	861	853	822	779	784		
	Edh at Noon		65	84	102	119	120	119	120	113	97	79	62	56		
(44) All-Sky Solar Radiation	RadAvg		1.18	2.04	3.10	4.18	4.87	5.33	5.30	4.73	3.42	2.32	1.29	0.97		
	RadStd		0.12	0.26	0.35	0.43	0.54	0.40	0.47	0.53	0.43	0.22	0.18	0.14		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (101 neighbors)		+0.53	N/A	N/A	+0.87	+0.48	+0.41	-107	-141	+88	+52

Nomenclature: See separate page