

RAX SEILBAHNBERGSTATION, Austria

WMO: 111800

Lat: **47.7175N**Lon: **15.7786E**Elev: **5111**StdP: **12.18**Time Zone: **1.00 (EUC)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.8	8.2	-5.3	5.0	19.4	0.4	6.8	18.6	39.4	15.1	36.4	16.5	16.1	300	0.761

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.1	71.5	59.7	68.5	58.6	65.9	57.0	61.6	68.8	59.8	66.6	58.1	64.5	6.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.8	89.6	65.2	56.9	83.7	63.8	55.2	78.6	61.9	30.2	69.2	28.8	66.7	27.5	64.8	66.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 34.3	29.9	26.2	DB	1.8	76.5	4.4	3.1	-1.4	78.7	-4.0	80.6	-6.5	82.3	-9.7	84.6	(4)
(5)			WB	1.8	64.4	4.6	1.6	-1.5	65.6	-4.2	66.5	-6.7	67.4	-10.0	68.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	39.3	24.4	25.4	29.0	36.6	44.6	51.2	54.5	46.5	41.8	34.0	28.3	(6)	
(7)		DBStd	13.59	9.08	9.57	8.78	8.13	7.92	7.73	7.30	6.88	7.52	9.05	9.35	9.33	(7)
(8)		HDD50	4474	792	688	651	405	207	77	39	30	153	277	483	672	(8)
(9)		HDD65	9389	1257	1108	1116	851	634	417	332	333	555	718	931	1137	(9)
(10)		CDD50	577	0	0	0	4	38	113	179	170	48	23	2	0	(10)
(11)		CDD65	16	0	0	0	0	0	2	6	8	0	0	0	0	(11)
(12)		CDH74	27	0	0	0	0	0	3	6	18	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	11.6	13.4	13.2	12.3	11.4	11.5	10.2	10.7	10.9	11.1	11.7	12.9	(14)	
(15)	Precipitation	PrecAvg	42.2	2.0	2.0	3.0	2.6	4.6	5.6	5.4	4.0	3.0	2.8	2.4	(15)	
(16)		PrecMax	51.0	4.5	4.6	7.6	5.9	8.0	9.3	10.7	7.2	9.3	6.3	5.6	4.8	(16)
(17)		PrecMin	30.4	0.3	0.3	1.1	0.2	1.7	2.4	1.1	1.4	1.7	0.5	0.0	0.4	(17)
(18)		PrecStd	5.4	1.3	1.1	1.6	1.3	1.7	1.8	2.5	1.5	1.7	1.4	1.2	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.0	49.6	50.4	58.4	66.9	73.0	74.6	76.2	66.7	63.8	56.8	52.4	(19)
(20)			MCWB	36.8	36.7	39.3	47.4	55.9	59.9	61.6	60.6	56.4	48.9	44.6	38.3	(20)
(21)		2%	DB	44.2	45.0	46.5	54.1	62.9	69.1	71.1	71.7	62.9	59.8	52.0	46.6	(21)
(22)			MCWB	35.5	35.2	38.0	44.7	53.2	59.2	60.4	59.0	54.5	48.3	42.4	35.7	(22)
(23)		5%	DB	40.6	41.6	43.6	50.9	59.7	65.9	68.2	68.1	59.8	56.7	48.7	43.4	(23)
(24)			MCWB	33.5	34.1	36.9	43.5	51.7	57.2	58.8	58.2	53.2	47.1	41.0	34.3	(24)
(25)		10%	DB	37.1	38.3	41.0	47.6	56.1	62.4	65.3	65.1	57.2	53.8	46.2	40.3	(25)
(26)			MCWB	32.4	33.0	35.6	41.6	49.8	55.4	57.3	56.7	51.7	46.3	39.9	33.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.6	41.0	41.4	48.6	57.4	63.2	63.8	63.2	58.5	53.1	47.2	40.5	(27)
(28)			MCD B	45.0	43.8	46.8	55.4	64.8	69.6	70.9	71.0	63.8	58.5	52.0	46.7	(28)
(29)		2%	WB	37.1	37.2	39.3	46.3	54.5	60.2	61.8	61.1	56.3	51.0	44.5	38.4	(29)
(30)			MCD B	42.0	41.7	44.1	52.3	61.2	66.9	68.8	68.7	61.0	56.4	48.4	43.6	(30)
(31)		5%	WB	35.2	35.3	37.8	44.2	52.2	58.1	59.9	59.2	54.4	49.1	42.7	36.8	(31)
(32)			MCD B	39.2	39.7	42.1	49.7	58.3	64.4	66.7	66.5	58.7	54.1	47.1	41.0	(32)
(33)		10%	WB	32.9	33.4	36.2	42.2	50.2	56.1	58.1	57.5	52.4	47.3	40.9	34.8	(33)
(34)			MCD B	36.3	37.3	40.2	46.8	55.5	61.8	64.2	64.2	56.2	52.0	45.3	39.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.1	8.3	8.2	9.1	10.0	10.3	10.1	8.9	9.0	7.9	8.1	(35)	
(36)			MCD BR	11.7	12.2	10.7	12.6	14.1	14.1	13.5	13.8	12.1	11.5	10.2	11.3	(36)
(37)			MCWBR	7.8	7.7	7.6	8.1	9.2	10.0	8.7	9.2	9.9	9.1	6.9	6.6	(37)
(38)		5% WB	MCD BR	10.7	10.7	10.0	11.4	13.2	13.0	12.5	12.8	11.4	10.3	9.4	10.8	(38)
(39)			MCWBR	8.4	8.2	7.6	7.6	9.2	10.0	8.9	9.6	9.7	8.5	7.3	7.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.252	0.273	0.304	0.336	0.339	0.344	0.348	0.346	0.325	0.302	0.279	0.252	(40)	
(41)		taud	2.477	2.457	2.435	2.395	2.415	2.415	2.399	2.418	2.466	2.525	2.547	2.515	(41)	
(42)		Ebn at Noon	272	287	292	291	293	291	288	284	281	272	259	259	(42)	
(43)		Edh at Noon	20	25	30	35	36	36	36	34	29	23	18	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	356	627	971	1351	1576	1719	1694	1512	1089	718	390	288	(44)	
(45)		RadStd	40	80	114	142	174	133	152	163	135	71	49	38	(45)	

Historical Trends

		DBAvg	Heating		Cooling	
--	--	-------	---------	--	---------	--