

RAX SEILBAHNBERGSTATION, Austria

WMO: 111800

Lat: 47.7175N

Lon: 15.7786E

Elev: 1558

StdP: 83.96

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -15.1	(c) -13.2	(d) -20.7	(e) 0.7	(f) -7.0	(g) -17.5	(h) 1.0	(i) -7.4	(j) 17.6	(k) -9.4	(l) 16.3	(m) -8.6	(n) 7.2	(o) 300	(p) 0.761

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.6	(c) 22.0	(d) 15.4	(e) 20.3	(f) 14.8	(g) 18.8	(h) 13.9	(i) 16.4	(j) 20.4	(k) 15.4	(l) 19.2	(m) 14.5	(n) 18.1	(o) 3.0	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 14.9	(b) 12.8	(c) 18.4	(d) 13.9	(e) 12.0	(f) 17.7	(g) 12.9	(h) 11.2	(i) 16.6	(j) 52.3	(k) 20.7	(l) 49.0	(m) 19.3	(n) 46.1	(o) 18.2	(p) 19.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.3	13.4	11.7	-16.8	24.7	2.5	1.7	-18.6	26.0	-20.0	27.0	-21.4	28.0	-23.2	29.2
			-16.8	18.0	2.5	0.9	-18.6	18.6	-20.1	19.2	-21.5	19.7	-23.4	20.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.1	-4.2	-3.6	-1.7	2.6	7.0	10.7	12.5	12.5	8.1	5.5	1.1	-2.0		
	DBStd	7.55	5.05	5.32	4.88	4.51	4.40	4.29	4.06	3.82	4.18	5.03	5.19	5.18		
	HDD10.0	2486	440	382	362	225	115	43	22	17	85	154	268	373		
	HDD18.3	5216	698	616	620	473	352	232	184	185	308	399	517	632		
	CDD10.0	321	0	0	0	2	21	63	99	94	27	13	1	0		
	CDD18.3	9	0	0	0	0	0	1	3	4	0	0	0	0		
	CDH23.3	15	0	0	0	0	0	2	3	10	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	5.2	6.0	5.9	5.5	5.1	5.1	4.6	4.8	4.6	4.9	5.0	5.2	5.8		
(15) Precipitation	PrecAvg	1071	52	52	77	66	116	141	136	123	101	76	71	60		
	PrecMax	1296	114	117	193	150	203	236	272	184	236	161	141	122		
	PrecMin	773	8	8	29	5	42	62	27	36	44	12	0	9		
	PrecStd	137	32	29	40	32	43	45	63	39	43	36	30	28		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.4	9.8	10.2	14.7	19.4	22.8	23.7	24.6	19.3	17.7	13.8	11.4		
		MCWB	2.7	2.6	4.0	8.6	13.3	15.5	16.4	15.9	13.5	9.4	7.0	3.5		
	2%	DB	6.8	7.2	8.0	12.3	17.2	20.6	21.7	22.1	17.1	15.5	11.1	8.1		
		MCWB	1.9	1.8	3.3	7.0	11.8	15.1	15.8	15.0	12.5	9.0	5.8	2.1		
	5%	DB	4.8	5.3	6.4	10.5	15.4	18.8	20.1	20.1	15.4	13.7	9.3	6.3		
		MCWB	0.8	1.2	2.7	6.4	11.0	14.0	14.9	14.5	11.8	8.4	5.0	1.3		
	10%	DB	2.8	3.5	5.0	8.7	13.4	16.9	18.5	18.4	14.0	12.1	7.9	4.6		
		MCWB	0.2	0.6	2.0	5.3	9.9	13.0	14.1	13.7	10.9	8.0	4.4	0.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.2	5.0	5.2	9.2	14.1	17.3	17.7	17.3	14.7	11.7	8.4	4.7		
		MCDB	7.2	6.6	8.2	13.0	18.2	20.9	21.6	21.7	17.7	14.7	11.1	8.1		
	2%	WB	2.9	2.9	4.1	8.0	12.5	15.7	16.5	16.2	13.5	10.5	7.0	3.6		
		MCDB	5.5	5.4	6.7	11.3	16.2	19.4	20.5	20.4	16.1	13.6	9.1	6.4		
	5%	WB	1.8	1.9	3.2	6.8	11.2	14.5	15.5	15.1	12.5	9.5	6.0	2.6		
		MCDB	4.0	4.3	5.6	9.9	14.6	18.0	19.3	19.2	14.8	12.3	8.4	5.0		
	10%	WB	0.5	0.8	2.4	5.7	10.1	13.4	14.5	14.2	11.3	8.5	4.9	1.5		
		MCDB	2.4	3.0	4.6	8.2	13.1	16.6	17.9	17.9	13.5	11.1	7.4	3.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.5	4.6	4.6	5.1	5.6	5.7	5.7	5.6	4.9	5.0	4.4	4.5		
		MCDBR	6.5	6.8	6.0	7.0	7.8	7.8	7.5	7.7	6.7	6.4	5.7	6.3		
	5% WB	MCWBR	4.3	4.3	4.2	4.5	5.1	5.6	4.8	5.1	5.5	5.0	3.9	3.7		
		MCWBR	5.9	6.0	5.5	6.4	7.3	7.2	7.0	7.1	6.3	5.7	5.2	6.0		
(40) Clear-Sky Solar Irradiance	taub		0.252	0.273	0.304	0.336	0.339	0.344	0.348	0.346	0.325	0.302	0.279	0.252		
		taud	2.477	2.457	2.435	2.395	2.415	2.415	2.399	2.418	2.466	2.525	2.547	2.515		
	Ebn at Noon		857	906	922	917	924	917	908	896	887	859	815	816		
		Edh at Noon	62	79	95	109	112	112	113	106	91	73	58	53		
(44) All-Sky Solar Radiation	RadAvg		1.12	1.98	3.06	4.26	4.97	5.42	5.34	4.77	3.43	2.27	1.23	0.91		
	RadStd		0.12	0.25	0.36	0.45	0.55	0.42	0.48	0.51	0.43	0.23	0.15	0.12		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (96 neighbors)		+0.55	N/A	N/A	+0.85	+0.45	+0.41	-114	-151	+88	+49

Nomenclature: See separate page