

WIENER NEUSTADT, Austria

WMO: 111820

Lat: 47.8322N

Lon: 16.2314E

Elev: 922

StdP: 14.21

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.8	15.7	5.5	7.6	12.2	10.5	9.7	18.1	29.4	42.8	26.0	38.6	5.2	240	0.536

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.2	89.3	69.7	85.9	68.6	82.7	66.9	71.1	85.6	69.5	83.0	68.1	80.3	9.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.4	100.7	76.9	64.8	95.0	75.6	63.4	90.3	74.3	35.5	85.9	34.1	83.2	32.8	80.6	79.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.0	20.8	18.3	DB	3.7	94.4	6.9	4.3	-1.3	97.4	-5.3	99.9	-9.2	102.3	-14.2	105.4
			WB	3.5	74.5	6.6	1.8	-1.3	75.8	-5.1	76.9	-8.8	77.9	-13.5	79.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.7	31.2	34.7	41.7	51.1	59.1	65.7	69.4	68.6	59.7	50.4	41.8	33.4
	DBStd	15.18	8.54	8.79	7.89	7.25	6.36	6.25	5.67	5.66	6.08	7.17	7.58	8.04
	HDD50	2234	584	431	271	73	6	0	0	0	3	85	264	517
	HDD65	5665	1048	847	722	420	203	66	22	27	178	455	697	980
	CDD50	2472	1	3	15	105	286	472	602	578	295	96	18	1
	CDD65	426	0	0	0	2	19	87	158	139	20	1	0	0
	CDH74	4200	0	0	0	38	231	873	1535	1333	182	8	0	0
	CDH80	1313	0	0	0	4	34	251	527	468	29	0	0	0
Wind	WSAvg	7.6	7.9	8.4	8.7	8.5	8.2	7.6	7.9	6.9	7.0	6.6	6.8	7.0
Precipitation	PrecAvg	30.5	1.6	1.5	2.0	2.0	3.3	4.0	3.7	3.5	2.7	2.2	2.1	1.8
	PrecMax	38.9	4.4	3.8	5.0	4.4	7.0	8.0	8.5	6.5	7.7	3.9	4.7	3.9
	PrecMin	20.7	0.2	0.1	0.6	0.3	0.7	1.2	0.4	0.9	0.4	0.4	0.0	0.2
	PrecStd	4.6	1.0	1.0	1.3	1.0	1.6	1.8	1.9	1.4	1.6	1.1	0.9	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.1	61.3	68.1	78.7	83.8	90.6	93.1	94.4	83.5	74.6	66.3	57.0
		MCWB	46.9	49.0	53.1	60.2	65.5	70.2	70.7	69.6	66.3	60.8	55.3	48.4
	2%	DB	52.1	56.3	63.6	73.3	79.8	86.3	89.2	89.3	78.9	69.2	61.6	52.5
		MCWB	44.7	46.9	51.2	57.5	64.0	69.4	70.0	69.0	64.7	58.9	53.6	45.6
	5%	DB	47.5	52.0	59.0	69.0	76.3	82.6	85.7	85.2	75.1	65.6	57.2	48.0
		MCWB	42.0	44.4	48.8	55.4	62.3	67.5	68.6	68.1	62.7	57.6	50.6	42.6
	10%	DB	43.6	48.0	54.8	65.3	72.5	79.1	82.4	81.4	71.5	62.1	53.2	44.4
		MCWB	39.0	42.0	46.8	53.5	60.1	65.5	66.9	66.3	61.2	55.3	48.1	39.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.4	50.0	54.1	60.9	67.9	72.7	73.6	72.7	68.1	62.5	56.7	49.3
		MCDB	55.2	59.2	65.4	75.4	80.4	85.9	88.8	87.8	79.3	70.8	64.0	55.4
	2%	WB	45.5	47.3	51.9	58.3	65.2	70.4	71.4	70.4	65.6	60.3	53.9	45.8
		MCDB	51.4	55.4	61.7	71.6	77.2	83.5	86.2	85.4	76.2	67.4	60.7	51.5
	5%	WB	42.2	44.7	49.6	56.4	63.2	68.5	69.6	68.8	63.8	58.2	51.2	42.9
		MCDB	46.8	51.6	57.8	67.5	74.0	80.5	82.7	82.6	73.3	64.4	56.5	47.8
	10%	WB	39.4	42.2	47.5	54.3	61.1	66.5	68.0	67.3	62.1	56.0	48.6	40.4
		MCDB	43.4	47.7	54.2	63.8	70.8	77.2	80.0	79.3	69.9	61.3	52.7	43.8
Mean Daily Temperature Range	5% DB	MDBR	11.4	13.9	16.7	19.7	18.6	18.8	19.2	19.5	17.2	15.7	11.9	10.7
		MCDBR	16.9	20.6	25.1	27.3	25.8	25.6	25.9	26.7	24.0	21.4	17.9	16.9
		MCWBR	11.5	13.3	14.8	14.1	12.5	11.3	10.0	10.5	11.5	12.7	11.4	11.6
	5% WB	MCDBR	16.1	19.3	23.4	25.2	23.8	24.1	23.5	24.2	22.1	19.5	16.5	15.9
		MCWBR	11.5	13.0	14.4	13.4	11.9	11.4	9.9	10.3	11.2	12.2	11.2	11.4
Clear-Sky Solar Irradiance	taub	0.309	0.335	0.374	0.417	0.417	0.423	0.428	0.429	0.400	0.370	0.340	0.309	
	taud	2.403	2.360	2.286	2.196	2.242	2.263	2.250	2.262	2.313	2.373	2.413	2.434	
	Ebn at Noon	243	260	266	264	269	267	264	258	254	243	227	228	
	Edh at Noon	22	28	35	43	42	42	42	39	34	28	22	19	
All-Sky Solar Radiation	RadAvg	335	598	964	1405	1654	1802	1757	1565	1122	708	374	263	
	RadStd	37	79	119	142	175	133	153	157	135	74	39	32	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (90 neighbors)		+1.01	N/A	N/A	+1.53	+0.81	+0.72	-214	-277	+157	+83

Nomenclature: See separate page