

WIENER NEUSTADT, Austria

WMO: 111820

Lat: 47.8322N

Lon: 16.2314E

Elev: 281

StdP: 97.99

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.8	-9.1	-14.7	1.1	-11.0	-11.9	1.4	-7.7	13.2	6.0	11.6	3.7	2.3	240	0.536

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	31.8	20.9	29.9	20.3	28.1	19.4	21.7	29.8	20.9	28.3	20.0	26.8	4.2	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	14.4	24.9	18.2	13.6	24.2	17.4	12.9	23.5	64.6	30.0	61.4	28.5	58.5	27.0	26.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.7	9.3	8.2	-15.7	34.6	3.8	2.4	-18.5	36.3	-20.7	37.7	-22.9	39.1	-25.7	40.8		
(5)			-15.9	23.6	3.6	1.0	-18.5	24.3	-20.6	24.9	-22.7	25.5	-25.3	26.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.4	-0.4	1.5	5.4	10.6	15.0	18.7	20.8	15.4	10.2	5.4	0.8	(6)	
(7)		DBStd	8.43	4.75	4.88	4.38	4.03	3.53	3.47	3.15	3.14	3.38	3.98	4.21	4.46	(7)
(8)		HDD10.0	1241	324	239	151	41	3	0	0	2	47	147	287	(8)	
(9)		HDD18.3	3147	582	471	401	233	113	37	12	15	99	253	387	544	(9)
(10)		CDD10.0	1373	1	2	8	58	159	262	334	321	164	53	10	1	(10)
(11)		CDD18.3	237	0	0	0	1	11	48	88	77	11	1	0	0	(11)
(12)		CDH23.3	2333	0	0	0	21	128	485	853	741	101	4	0	0	(12)
(13)		CDH26.7	729	0	0	0	2	19	139	293	260	16	0	0	0	(13)
(14)	Wind	WSAvg	3.4	3.5	3.7	3.9	3.8	3.7	3.4	3.5	3.1	3.0	3.0	3.1	(14)	
(15)	Precipitation	PrecAvg	775	41	37	52	52	85	101	95	88	69	55	54	46	(15)
(16)		PrecMax	987	111	96	128	112	179	204	215	166	196	98	119	99	(16)
(17)		PrecMin	525	4	2	15	8	19	31	10	23	10	10	0	6	(17)
(18)		PrecStd	116	26	25	32	25	40	45	48	36	40	27	24	21	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.9	16.3	20.1	26.0	28.8	32.5	34.0	34.7	28.6	23.7	19.0	13.9	(19)
(20)			MCWB	8.3	9.4	11.7	15.7	18.6	21.2	21.5	20.9	19.1	16.0	12.9	9.1	(20)
(21)		2%	DB	11.2	13.5	17.5	23.0	26.5	30.2	31.8	31.8	26.1	20.6	16.4	11.4	(21)
(22)			MCWB	7.1	8.3	10.7	14.2	17.8	20.8	21.1	20.6	18.2	15.0	12.0	7.6	(22)
(23)		5%	DB	8.6	11.1	15.0	20.6	24.6	28.1	29.9	29.6	23.9	18.7	14.0	8.9	(23)
(24)			MCWB	5.6	6.9	9.4	13.0	16.8	19.7	20.3	20.0	17.0	14.2	10.3	5.9	(24)
(25)		10%	DB	6.5	8.9	12.7	18.5	22.5	26.2	28.0	27.4	21.9	16.7	11.8	6.9	(25)
(26)			MCWB	3.9	5.5	8.2	11.9	15.6	18.6	19.4	19.1	16.2	13.0	8.9	4.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.1	10.0	12.3	16.1	20.0	22.6	23.1	22.6	20.1	17.0	13.7	9.6	(27)
(28)			MCD B	12.9	15.1	18.6	24.1	26.9	30.0	31.6	31.0	26.3	21.5	17.8	13.0	(28)
(29)		2%	WB	7.5	8.5	11.0	14.6	18.4	21.3	21.9	21.3	18.6	15.7	12.2	7.6	(29)
(30)			MCD B	10.8	13.0	16.5	22.0	25.1	28.6	30.1	29.7	24.6	19.6	16.0	10.8	(30)
(31)		5%	WB	5.7	7.0	9.8	13.5	17.3	20.3	20.9	20.5	17.7	14.5	10.7	6.0	(31)
(32)			MCD B	8.2	10.9	14.3	19.7	23.3	26.9	28.2	28.1	23.0	18.0	13.6	8.8	(32)
(33)		10%	WB	4.1	5.6	8.6	12.4	16.2	19.2	20.0	19.6	16.7	13.3	9.2	4.6	(33)
(34)			MCD B	6.4	8.7	12.3	17.7	21.6	25.1	26.7	26.3	21.1	16.3	11.5	6.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.3	7.7	9.3	10.9	10.3	10.5	10.6	10.8	9.5	8.7	6.6	5.9	(35)
(36)			MCD BR	9.4	11.5	13.9	15.2	14.4	14.2	14.4	14.8	13.3	11.9	9.9	9.4	(36)
(37)			MCWBR	6.4	7.4	8.2	7.9	6.9	6.3	5.6	5.8	6.4	7.0	6.3	6.4	(37)
(38)		5% WB	MCD BR	8.9	10.7	13.0	14.0	13.2	13.4	13.0	13.5	12.3	10.8	9.2	8.9	(38)
(39)			MCWBR	6.4	7.2	8.0	7.4	6.6	6.3	5.5	5.7	6.2	6.8	6.2	6.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.309	0.335	0.374	0.417	0.417	0.423	0.428	0.429	0.400	0.370	0.340	0.309	(40)	
(41)		taud	2.403	2.360	2.286	2.196	2.242	2.263	2.250	2.262	2.313	2.373	2.413	2.434	(41)	
(42)		Ebn at Noon	765	820	838	832	847	843	831	813	800	766	716	719	(42)	
(43)		Edh at Noon	68	88	111	134	133	131	131	124	108	87	68	60	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.05	1.89	3.04	4.43	5.21	5.68	5.54	4.93	3.54	2.23	1.18	0.83	(44)	
(45)		RadStd	0.12	0.25	0.38	0.45	0.55	0.42	0.48	0.49	0.43	0.23	0.12	0.10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (90 neighbors)		+0.56	N/A	N/A	+0.85	+0.45	+0.40	-119	-154	+87	+46

Nomenclature: See separate page