

KLEINZICKEN, Austria

WMO: 111920

Lat: 47.208N

Lon: 16.336E

Elev: 876

StdP: 14.24

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.1	15.2	5.1	7.4	11.6	10.3	9.6	17.5	18.7	33.4	16.4	32.6	2.0	330	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.9	88.7	70.1	85.2	69.1	82.2	67.6	71.7	84.9	70.1	82.8	68.6	80.1	6.2	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.5	104.4	76.8	65.9	98.7	75.0	64.4	93.6	73.4	35.9	85.1	34.6	82.9	33.3	80.3	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.3	13.7	11.5	3.5	92.8	6.9	4.6	-1.4	96.1	-5.5	98.8	-9.3	101.4	-14.3	104.8
			3.1	74.5	6.4	2.2	-1.5	76.1	-5.3	77.4	-8.9	78.6	-13.5	80.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.0	30.1	34.2	41.4	50.9	58.5	65.1	68.3	67.5	59.1	50.3	41.3	32.4
	DBStd	14.87	7.10	7.72	7.52	6.65	5.76	5.91	5.44	5.32	5.71	6.64	7.14	7.14
	HDD50	2308	618	443	275	69	4	0	0	0	2	80	271	546
	HDD65	5814	1083	863	731	422	212	71	30	33	193	454	711	1011
	CDD50	2314	0	0	9	97	268	454	569	543	274	90	10	0
	CDD65	345	0	0	0	0	11	75	134	111	14	0	0	0
	CDH74	3840	0	0	0	26	196	824	1447	1186	156	5	0	0
	CDH80	1157	0	0	0	1	25	228	477	407	19	0	0	0
Wind	WSAvg	4.2	3.9	4.3	4.9	5.2	4.8	4.2	4.3	3.7	3.9	3.4	3.7	3.6
Precipitation	PrecAvg	28.2	1.0	1.2	1.5	1.8	3.0	3.7	3.5	3.3	3.1	2.4	2.1	1.5
	PrecMax	38.1	2.7	3.8	3.1	3.5	5.4	6.7	6.0	6.6	6.5	6.1	5.4	3.1
	PrecMin	20.4	0.2	0.2	0.1	0.1	1.0	1.0	0.5	0.5	0.9	0.0	0.1	0.1
	PrecStd	4.2	0.7	1.1	0.9	0.8	1.2	1.5	1.5	1.5	1.6	1.5	1.2	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.4	60.1	68.3	77.7	83.1	89.6	92.3	93.3	82.6	74.2	65.0	54.3
		MCWB	45.7	48.5	53.2	60.7	66.3	71.0	71.7	69.8	66.3	61.9	56.4	48.7
	2%	DB	47.5	53.9	63.5	72.7	79.1	85.8	88.4	88.9	78.3	69.7	59.5	48.0
		MCWB	42.1	45.6	51.4	57.5	64.5	70.0	70.3	69.4	65.0	59.8	53.3	43.7
	5%	DB	42.8	49.5	59.2	69.1	75.6	82.3	85.0	84.7	74.8	65.9	55.4	44.2
		MCWB	39.2	43.0	49.2	55.8	62.5	68.1	68.9	68.7	63.5	57.9	51.1	40.8
	10%	DB	39.7	45.6	54.8	65.6	72.3	78.8	82.1	80.8	71.0	62.0	51.7	41.3
		MCWB	36.8	40.6	46.7	53.8	60.5	66.0	67.5	67.2	61.2	55.9	48.3	38.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.8	49.3	54.5	61.6	68.1	73.2	73.6	73.4	68.3	63.3	57.0	49.3
		MCDB	51.3	58.5	66.2	75.4	81.0	84.9	86.9	85.6	79.3	72.0	63.4	54.0
	2%	WB	42.6	46.3	51.9	58.9	65.5	70.9	71.7	71.1	66.3	60.8	54.0	44.4
		MCDB	46.4	53.3	62.0	71.2	76.6	83.3	85.1	84.6	76.1	67.9	58.5	47.4
	5%	WB	39.8	43.7	49.8	56.6	63.5	69.0	70.1	69.6	64.4	58.8	51.3	41.4
		MCDB	42.6	48.9	58.1	67.1	73.8	80.6	82.5	82.5	72.8	65.0	55.1	43.5
	10%	WB	37.2	41.0	47.3	54.5	61.5	67.2	68.6	67.9	62.3	56.6	48.7	39.1
		MCDB	39.3	45.0	54.2	63.9	70.7	77.2	79.7	79.0	69.3	61.6	51.4	40.9
Mean Daily Temperature Range	5% DB	MDBR	11.8	15.8	18.8	21.5	20.7	21.1	21.9	21.7	19.1	18.6	12.7	10.7
		MCDBR	17.0	23.6	28.2	29.3	27.6	27.3	27.9	29.4	25.3	24.5	19.9	15.8
		MCWBR	12.4	15.8	16.8	15.5	14.1	12.6	11.6	11.9	12.8	15.3	13.9	11.7
	5% WB	MCDBR	16.5	22.3	26.8	26.5	25.2	26.0	25.5	26.5	23.3	22.9	18.8	14.7
		MCWBR	12.3	15.4	16.4	14.3	13.3	12.4	11.3	11.6	12.3	14.6	13.4	11.5
Clear-Sky Solar Irradiance	taub	0.315	0.340	0.378	0.423	0.420	0.426	0.430	0.433	0.405	0.377	0.346	0.314	
	taud	2.399	2.351	2.278	2.173	2.229	2.253	2.244	2.247	2.297	2.348	2.391	2.429	
	Ebn at Noon	243	260	266	263	268	267	264	257	253	242	227	229	
	Edh at Noon	22	29	36	44	43	42	42	40	35	29	23	19	
All-Sky Solar Radiation	RadAvg	359	617	993	1419	1696	1849	1821	1616	1152	745	399	278	
	RadStd	39	86	119	140	166	130	139	164	137	75	44	37	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (90 neighbors)	+1.01	N/A	N/A	N/A	+1.62	+0.85	+0.74	-202	-272	+166	+103

Nomenclature: See separate page